

GLADHAMMAR, Sweden

WMO: 025590

Lat: 57.7068N

Lon: 16.4526E

Elev: 35

StdP: 100.91

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.6	-11.2	-16.8	0.9	-13.9	-13.5	1.2	-9.7	10.3	2.7	8.7	4.6	0.9	350	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	27.2	18.5	25.2	17.7	23.6	17.0	20.0	24.1	19.0	23.0	18.1	22.1	3.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.5	21.6	17.6	12.6	20.6	16.6	11.8	19.7	57.5	24.1	54.1	23.0	51.1	22.1	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.5	5.7	DB	-18.9	30.2	5.1	2.0	-22.5	31.6	-25.5	32.8	-28.4	33.9	-32.0	35.4	(4)
(5)			WB	-19.1	21.5	4.9	1.1	-22.6	22.3	-25.5	23.0	-28.2	23.6	-31.8	24.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	-1.5	-1.1	1.6	5.7	10.4	14.9	17.5	16.5	12.6	7.6	3.6	0.5	(6)	
	DBStd	7.53	4.51	4.49	4.16	3.43	3.34	2.80	2.65	2.48	2.70	3.48	3.45	4.67	(7)	
	HDD10.0	1687	358	310	262	136	36	2	0	0	8	91	191	294	(8)	
	HDD18.3	4028	616	543	519	379	247	107	49	67	173	334	441	552	(9)	
	CDD10.0	738	0	0	1	6	48	148	231	203	86	15	1	0	(10)	
	CDD18.3	38	0	0	0	0	0	4	22	11	1	0	0	0	(11)	
	CDH23.3	426	0	0	0	1	9	86	238	88	4	0	0	0	(12)	
	CDH26.7	77	0	0	0	0	1	16	48	13	0	0	0	0	(13)	
(14) Wind	WSAvg	2.6	2.8	2.8	2.9	2.6	2.6	2.6	2.4	2.3	2.5	2.5	2.7	2.7	(14)	
(15) Precipitation	PrecAvg	623	37	37	27	35	46	60	78	64	66	55	66	53	(15)	
	PrecMax	873	73	72	58	78	90	123	186	138	153	162	235	103	(16)	
	PrecMin	484	4	11	4	3	9	2	13	0	18	17	4	10	(17)	
	PrecStd	94	19	17	13	21	21	30	43	31	42	35	48	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.1	10.1	15.7	20.1	24.3	28.9	30.3	28.4	24.0	18.0	12.7	11.5	(19)	
		MCWB	7.0	6.8	8.9	12.5	15.3	17.7	19.4	19.7	16.6	14.1	10.9	9.6	(20)	
	2%	DB	7.1	7.9	12.4	17.1	21.7	25.6	27.9	25.5	21.3	15.6	10.9	9.3	(21)	
		MCWB	5.5	5.3	7.3	10.6	14.1	17.0	18.4	18.4	15.7	12.9	9.4	7.7	(22)	
	5%	DB	5.7	6.3	9.7	15.0	19.6	23.6	25.9	23.8	19.4	14.1	9.7	7.6	(23)	
		MCWB	4.3	4.4	5.9	9.2	12.9	16.1	18.5	17.6	14.8	11.9	8.4	6.3	(24)	
	10%	DB	4.3	4.9	7.7	12.5	17.6	21.7	24.1	22.2	17.8	12.7	8.5	6.1	(25)	
		MCWB	3.1	3.2	4.9	7.7	12.0	15.1	17.6	17.1	13.9	10.9	7.5	5.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	7.5	9.6	13.2	16.8	19.8	21.6	21.5	18.0	14.7	11.2	9.7	(27)	
		MCDB	8.8	9.4	14.2	18.7	22.5	24.2	26.6	25.6	21.7	16.8	12.2	11.1	(28)	
	2%	WB	5.7	5.8	7.7	11.5	15.2	18.1	20.3	19.7	16.6	13.4	9.6	8.0	(29)	
		MCDB	6.8	7.4	11.6	15.9	19.3	23.7	24.8	23.2	19.7	15.1	10.6	9.2	(30)	
	5%	WB	4.4	4.6	6.3	9.7	13.8	16.8	19.4	18.7	15.5	12.2	8.6	6.4	(31)	
		MCDB	5.5	6.2	9.1	14.0	18.0	21.9	23.8	21.9	18.2	13.7	9.5	7.4	(32)	
	10%	WB	3.1	3.4	5.1	8.2	12.6	15.8	18.4	17.9	14.5	11.2	7.6	5.2	(33)	
		MCDB	4.2	4.8	7.6	11.8	16.8	20.6	22.7	21.2	17.0	12.5	8.4	6.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	6.1	8.1	10.3	11.0	10.9	10.4	10.0	9.1	7.1	4.9	4.7	(35)	
		MCDBR	5.9	7.3	11.6	14.5	14.4	15.0	14.0	12.4	11.9	8.5	6.1	5.7	(36)	
	5% WB	MCWBR	5.1	5.3	7.3	8.5	7.9	7.3	6.2	6.4	6.8	6.0	5.1	5.0	(37)	
		MCWBR	5.8	6.8	10.5	13.0	12.2	13.0	11.5	10.7	10.4	7.9	5.7	5.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.293	0.325	0.341	0.379	0.376	0.366	0.394	0.386	0.354	0.344	0.321	0.282	(40)	
		taud	2.281	2.321	2.363	2.322	2.398	2.457	2.397	2.415	2.485	2.423	2.309	2.222	(41)	
	Ebn at Noon		567	712	810	830	859	874	836	817	792	686	521	456	(42)	
		Edh at Noon	48	71	89	108	107	102	107	98	79	64	47	37	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.36	0.93	2.44	4.15	5.51	6.03	5.48	4.40	2.97	1.32	0.48	0.26	(44)	
	RadStd		0.06	0.19	0.23	0.46	0.43	0.28	0.53	0.39	0.34	0.21	0.09	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.40	N/A	N/A	N/A	N/A	N/A	-124	-164	N/A	N/A

Nomenclature: See separate page