

LINKÖPING, Sweden

WMO: 025625

Lat: 58.406N

Lon: 15.681E

Elev: 172

StdP: 14.60

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 5.0	(c) 10.4	(d) 1.8	(e) 6.1	(f) 5.2	(g) 7.0	(h) 7.9	(i) 12.1	(j) 24.8	(k) 39.6	(l) 22.3	(m) 38.8	(n) 3.4	(o) 310	(p) 0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	82.3	65.0	78.8	63.8	75.3	62.4	67.8	76.3	65.8	74.5	64.2	72.2	8.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	92.3	70.1	62.8	86.1	68.6	60.9	80.4	67.4	32.2	77.4	30.7	74.2	29.4	72.4	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 20.5	(b) 18.2	(c) 16.2	(e) 0.3	(f) 86.6	(g) 8.1	(h) 3.5	(i) -5.5	(j) 89.1	(k) -10.3	(l) 91.2	(m) -14.8	(n) 93.1	(o) -20.7	(p) 95.7		
(a) 20.5	(b) 18.2	(c) 16.2	(e) -0.1	(f) 70.3	(g) 8.1	(h) 2.0	(i) -5.9	(j) 71.7	(k) -10.6	(l) 72.9	(m) -15.2	(n) 74.1	(o) -21.0	(p) 75.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.7	28.5	29.1	34.8	43.8	52.8	59.8	64.6	62.5	55.4	45.2	38.0	32.8		
	DBStd	14.28	8.86	8.16	7.97	6.20	6.24	5.13	5.08	4.72	5.34	6.21	6.54	8.73		
	HDD50	3048	668	584	472	201	39	2	0	15	172	360	535			
	HDD65	7147	1133	1004	936	635	379	171	72	105	289	614	809	1000		
	CDD50	1478	0	0	0	16	126	295	451	389	177	23	1	0		
	CDD65	105	0	0	0	0	2	15	58	28	2	0	0	0		
	CDH74	988	0	0	0	2	55	208	502	212	9	0	0	0		
	CDH80	189	0	0	0	0	3	34	117	35	0	0	0	0		
	WSAvg	7.6	8.0	7.8	8.0	7.8	7.6	7.7	6.9	6.7	7.4	7.5	7.8	8.0		
	PrecAvg	21.7	1.5	1.0	1.1	1.3	1.5	1.5	2.8	3.0	2.2	1.8	2.3	1.7		
(15) Precipitation	PrecMax	28.0	2.8	2.9	2.3	2.8	3.4	2.8	4.4	5.9	4.3	4.7	4.7	4.7		
	PrecMin	15.5	0.3	0.4	0.0	0.0	0.4	0.4	0.9	0.6	0.7	0.2	0.9	0.3		
	PrecStd	3.8	0.7	0.7	0.7	0.7	1.0	0.6	0.9	1.7	1.0	1.2	1.1	1.1		
	PrecStd	3.8	0.7	0.7	0.7	0.7	1.0	0.6	0.9	1.7	1.0	1.2	1.1	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.2	48.4	58.8	70.0	79.1	84.2	87.6	84.1	75.2	64.2	55.2	52.2		
		MCWB	45.4	44.1	47.7	53.9	61.5	63.4	67.1	67.6	62.2	57.3	52.0	48.4		
	2%	DB	44.5	44.7	53.6	64.5	75.0	79.2	82.8	79.1	71.5	59.1	51.8	48.6		
		MCWB	42.1	41.5	45.0	50.6	58.1	62.5	65.8	65.4	60.5	54.5	48.8	46.1		
	5%	DB	41.4	42.6	49.6	60.5	70.1	75.5	80.2	75.5	67.8	56.9	49.8	46.2		
		MCWB	39.3	39.8	42.8	48.7	57.1	60.9	64.8	63.9	58.8	53.2	47.5	44.0		
	10%	DB	39.5	39.4	46.1	55.7	66.0	71.5	75.6	72.0	64.4	53.9	47.8	43.2		
		MCWB	37.6	37.1	41.1	46.2	54.7	58.7	63.5	61.7	57.4	50.6	46.3	41.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.4	44.2	48.6	55.6	64.0	67.4	70.9	70.0	64.8	58.3	52.5	49.5		
		MCDB	47.2	46.5	56.0	67.2	75.1	78.1	80.1	78.5	71.4	62.7	54.6	52.0		
	2%	WB	41.9	41.9	45.6	51.9	61.0	64.2	68.6	67.4	61.8	55.5	49.4	46.3		
		MCDB	43.4	43.9	51.6	61.3	70.6	75.0	77.6	74.7	68.3	58.4	51.0	48.6		
	5%	WB	39.5	39.4	43.2	49.8	58.3	62.1	66.5	65.5	59.9	53.5	47.6	43.6		
		MCDB	41.2	41.5	47.9	58.6	67.6	72.5	76.0	72.7	65.9	56.5	49.2	45.2		
	10%	WB	37.5	37.1	41.1	47.4	55.7	60.2	64.8	63.6	58.3	51.6	45.5	41.2		
		MCDB	39.1	39.1	44.9	54.6	64.1	69.8	73.5	70.1	63.8	54.2	46.8	42.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	9.4	13.3	18.0	18.9	18.1	17.3	16.5	14.8	11.2	7.7	7.7		
		MCDBR	8.7	10.3	18.5	26.5	27.1	26.4	24.1	21.9	20.0	13.3	9.8	9.3		
		MCWBR	8.0	8.1	11.6	14.7	13.9	12.4	9.8	10.1	10.7	9.5	8.3	8.7		
	5% WB	MCDBR	8.7	9.1	16.8	22.6	22.9	21.9	20.4	19.2	17.8	12.7	9.2	9.5		
		MCWBR	8.3	7.7	11.3	13.5	13.1	11.2	9.9	10.1	10.6	9.9	8.2	9.1		
(40) Clear-Sky Solar Irradiance	taub		0.282	0.319	0.338	0.377	0.373	0.362	0.388	0.379	0.347	0.337	0.309	0.269		
	taud		2.240	2.297	2.352	2.311	2.386	2.440	2.388	2.409	2.483	2.424	2.297	2.178		
	Ebn at Noon		175	224	256	263	273	278	266	260	252	217	163	138		
	Edh at Noon		15	23	28	34	34	33	34	31	25	20	14	11		
(44) All-Sky Solar Radiation	RadAvg		110	304	784	1267	1647	1830	1644	1308	885	401	142	76		
	RadStd		16	51	85	141	142	86	186	134	118	65	27	8		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	-236	-284	N/A	N/A

Nomenclature: See separate page