

LINKÖPING, Sweden

WMO: 025625

Lat: 58.406N

Lon: 15.681E

Elev: 52

StdP: 100.70

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.0	-12.0	-16.8	0.9	-14.9	-13.9	1.1	-11.1	11.1	4.2	10.0	3.8	1.5	310	0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	27.9	18.3	26.0	17.6	24.1	16.9	19.9	24.6	18.8	23.6	17.9	22.3	3.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.2	21.2	17.1	12.3	20.3	16.1	11.5	19.6	56.9	25.2	53.5	23.5	50.5	22.5	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.1	7.2	-17.6	30.4	4.5	1.9	-20.8	31.7	-23.5	32.9	-26.0	34.0	-29.3	35.4		
(5)			-17.8	21.3	4.5	1.1	-21.1	22.1	-23.7	22.7	-26.2	23.4	-29.5	24.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.6	-2.0	-1.6	1.6	6.6	11.6	15.4	18.1	17.0	13.0	7.3	3.3	0.4	(6)
(7)		DBStd	7.93	4.92	4.53	4.43	3.44	3.47	2.85	2.82	2.62	2.97	3.45	3.64	4.85	(7)
(8)		HDD10.0	1693	371	324	262	112	22	1	0	0	8	96	200	297	(8)
(9)		HDD18.3	3971	629	558	520	353	211	95	40	58	161	341	449	556	(9)
(10)		CDD10.0	821	0	0	0	9	70	164	251	216	98	13	1	0	(10)
(11)		CDD18.3	58	0	0	0	0	1	8	32	16	1	0	0	0	(11)
(12)		CDH23.3	549	0	0	0	1	31	116	279	118	5	0	0	0	(12)
(13)		CDH26.7	105	0	0	0	0	2	19	65	19	0	0	0	0	(13)
(14)	Wind	WSAvg	3.4	3.6	3.5	3.6	3.5	3.4	3.4	3.1	3.0	3.3	3.3	3.5	3.6	(14)
(15)	Precipitation	PrecAvg	552	39	26	27	34	39	39	70	75	55	46	58	44	(15)
(16)		PrecMax	710	71	73	59	71	86	71	111	151	108	120	119	120	(16)
(17)		PrecMin	393	7	10	1	1	9	11	24	16	18	4	24	7	(17)
(18)		PrecStd	97	18	17	19	17	25	16	23	42	25	31	28	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	9.1	14.9	21.1	26.2	29.0	30.9	28.9	24.0	17.9	12.9	11.2	(19)
(20)			MCWB	7.4	6.7	8.7	12.1	16.4	17.4	19.5	19.8	16.8	14.1	11.1	9.1	(20)
(21)		2%	DB	6.9	7.0	12.0	18.1	23.9	26.2	28.2	26.2	22.0	15.1	11.0	9.2	(21)
(22)			MCWB	5.6	5.3	7.2	10.3	14.5	16.9	18.8	18.6	15.8	12.5	9.3	7.8	(22)
(23)		5%	DB	5.2	5.9	9.8	15.8	21.1	24.1	26.8	24.2	19.9	13.9	9.9	7.9	(23)
(24)			MCWB	4.0	4.3	6.0	9.3	14.0	16.1	18.2	17.7	14.9	11.8	8.6	6.6	(24)
(25)		10%	DB	4.1	4.1	7.8	13.2	18.9	22.0	24.2	22.2	18.0	12.2	8.8	6.2	(25)
(26)			MCWB	3.1	2.9	5.1	7.9	12.6	14.8	17.5	16.5	14.1	10.3	7.9	5.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	6.8	9.2	13.1	17.8	19.7	21.6	21.1	18.2	14.6	11.4	9.7	(27)
(28)			MCDWB	8.5	8.0	13.4	19.6	24.0	25.6	26.7	25.8	21.9	17.1	12.6	11.1	(28)
(29)		2%	WB	5.5	5.5	7.5	11.1	16.1	17.9	20.3	19.7	16.6	13.1	9.7	8.0	(29)
(30)			MCDWB	6.3	6.6	10.9	16.3	21.4	23.9	25.3	23.7	20.2	14.6	10.6	9.2	(30)
(31)		5%	WB	4.2	4.1	6.2	9.9	14.6	16.7	19.2	18.6	15.5	11.9	8.7	6.5	(31)
(32)			MCDWB	5.1	5.3	8.8	14.8	19.8	22.5	24.5	22.6	18.9	13.6	9.5	7.3	(32)
(33)		10%	WB	3.1	2.8	5.1	8.5	13.2	15.6	18.2	17.6	14.6	10.9	7.5	5.1	(33)
(34)			MCDWB	4.0	3.9	7.2	12.5	17.8	21.0	23.1	21.2	17.7	12.3	8.2	6.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.2	7.4	10.0	10.5	10.0	9.6	9.2	8.2	6.2	4.3	4.3	(35)
(36)			MCDBR	4.8	5.7	10.3	14.7	15.0	14.7	13.4	12.2	11.1	7.4	5.5	5.2	(36)
(37)			MCWBR	4.5	4.5	6.5	8.2	7.7	6.9	5.4	5.6	5.9	5.3	4.6	4.8	(37)
(38)		5% WB	MCDBR	4.8	5.1	9.3	12.6	12.7	12.2	11.3	10.7	9.9	7.1	5.1	5.3	(38)
(39)			MCWBR	4.6	4.3	6.3	7.5	7.3	6.2	5.5	5.6	5.9	5.5	4.5	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.282	0.319	0.338	0.377	0.373	0.362	0.388	0.379	0.347	0.337	0.309	0.269	(40)	
(41)		taud	2.240	2.297	2.352	2.311	2.386	2.440	2.388	2.409	2.483	2.424	2.297	2.178	(41)	
(42)		Ebn at Noon	553	706	806	829	860	875	840	820	795	683	514	435	(42)	
(43)		Edh at Noon	46	71	88	108	108	104	107	98	78	63	44	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.35	0.96	2.47	4.00	5.19	5.77	5.18	4.12	2.79	1.26	0.45	0.24	(44)	
(45)		RadStd	0.05	0.16	0.27	0.45	0.45	0.27	0.59	0.42	0.37	0.20	0.09	0.03	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (57 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	-131	-158	N/A	N/A	(47)

Nomenclature: See separate page