

LANDSORT, Sweden

WMO: 025670

Lat: 58.7429N

Lon: 17.8684E

Elev: 20

StdP: 101.08

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.5	-7.5	-12.5	1.3	-7.6	-10.8	1.5	-6.3	17.6	-0.6	16.1	-1.0	6.1	340	0.761

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.6	22.8	19.5	21.7	18.7	20.7	17.9	20.2	22.1	19.3	21.1	18.3	20.2	4.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.2	21.5	18.5	13.4	20.7	17.5	12.5	19.7	58.1	22.3	54.9	21.1	51.9	20.3	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	13.7	12.3	DB	-11.1	23.7	3.0	1.7	-13.3	24.9	-15.0	25.8	-16.7	26.8	-18.9	28.0	(4)
(5)			WB	-11.6	20.4	2.9	1.6	-13.7	21.5	-15.3	22.5	-16.9	23.4	-19.0	24.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-0.3	-0.5	1.1	4.1	8.7	13.6	17.5	17.5	13.4	8.6	4.5	1.6	(6)	
	DBStd	6.98	3.42	3.33	2.68	2.04	2.43	2.17	2.32	2.31	2.42	2.69	2.88	3.58	(7)	
	HDD10.0	1608	319	293	276	178	55	1	0	0	3	58	164	261	(8)	
	HDD18.3	3980	577	526	534	428	299	141	46	45	149	301	414	519	(9)	
	CDD10.0	707	0	0	0	0	14	110	232	231	104	16	0	0	(10)	
	CDD18.3	37	0	0	0	0	0	0	19	18	1	0	0	0	(11)	
	CDH23.3	19	0	0	0	0	0	0	11	8	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.4	7.4	7.2	6.5	5.8	5.5	5.5	5.2	5.5	6.3	7.2	7.6	7.8	(14)	
(15) Precipitation	PrecAvg	446	34	23	24	30	27	34	42	49	50	43	48	42	(15)	
	PrecMax	678	110	53	75	89	72	85	139	185	131	131	102	115	(16)	
	PrecMin	290	4	5	0	4	2	0	6	0	11	9	5	8	(17)	
	PrecStd	87	21	13	15	19	18	21	31	41	32	27	23	23	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.2	5.8	7.9	10.3	16.3	20.5	24.7	24.4	20.3	14.9	10.8	8.4	(19)	
		MCWB	5.2	3.9	5.3	6.7	12.0	15.5	20.3	20.1	17.5	13.3	10.2	7.3	(20)	
	2%	DB	5.3	4.6	6.0	8.6	14.2	19.0	23.1	22.7	18.6	13.9	9.7	7.5	(21)	
		MCWB	4.4	3.4	3.9	6.0	11.3	15.5	20.0	19.2	16.1	12.6	8.7	6.6	(22)	
	5%	DB	4.6	4.0	5.0	7.6	13.0	17.8	22.1	21.8	17.5	13.1	8.8	6.7	(23)	
		MCWB	3.8	3.0	3.3	5.6	10.6	14.9	19.2	18.6	15.2	11.8	7.9	5.9	(24)	
	10%	DB	3.9	3.4	4.2	6.8	11.9	16.8	21.0	20.8	16.6	12.2	8.2	5.7	(25)	
		MCWB	3.1	2.5	2.9	5.1	9.9	14.4	18.2	18.0	14.6	11.0	7.3	4.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	4.5	5.5	7.6	13.1	17.2	22.0	21.6	18.1	13.8	10.3	7.7	(27)	
		MCDB	6.0	5.1	7.3	9.4	15.0	18.9	23.5	22.9	19.6	14.4	10.5	8.1	(28)	
	2%	WB	4.7	3.7	4.3	6.6	11.9	16.2	20.5	20.2	16.6	12.9	8.9	6.8	(29)	
		MCDB	5.1	4.3	5.4	8.0	13.6	18.1	22.6	21.9	18.1	13.6	9.4	7.3	(30)	
	5%	WB	3.9	3.2	3.7	6.0	11.0	15.3	19.5	19.3	15.7	12.1	8.1	5.9	(31)	
		MCDB	4.4	3.8	4.6	7.2	12.6	17.2	21.5	21.1	17.0	12.9	8.7	6.5	(32)	
	10%	WB	3.2	2.7	3.1	5.3	10.1	14.6	18.7	18.4	15.0	11.2	7.4	5.0	(33)	
		MCDB	3.8	3.3	4.0	6.5	11.6	16.4	20.6	20.3	16.2	12.1	8.1	5.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.9	2.9	3.1	3.3	3.5	3.6	3.6	3.4	3.0	2.6	2.6	2.8	(35)	
		MCDBR	2.6	2.6	3.8	4.6	5.0	5.1	4.3	3.8	3.4	2.5	2.6	2.4	(36)	
	5% WB	MCWBR	2.7	2.2	2.7	2.8	3.1	3.1	2.7	2.7	2.5	2.5	2.7	2.4	(37)	
		MCWBR	2.5	2.5	3.5	4.0	4.5	4.3	3.6	3.3	2.9	2.4	2.3	2.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.291	0.324	0.341	0.378	0.373	0.364	0.393	0.383	0.351	0.341	0.316	0.277	(40)	
		taud	2.250	2.310	2.363	2.326	2.411	2.476	2.415	2.433	2.501	2.417	2.267	2.171	(41)	
	Ebn at Noon		532	696	801	827	859	873	834	816	789	673	486	406	(42)	
		Edh at Noon	45	69	87	107	105	100	104	95	76	62	45	34	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.31	0.89	2.41	4.05	5.42	5.98	5.50	4.36	2.87	1.26	0.42	0.21	(44)	
	RadStd		0.04	0.16	0.24	0.39	0.43	0.29	0.49	0.38	0.32	0.20	0.09	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (52 neighbors)		+0.38	N/A	N/A	N/A	N/A	N/A	-122	-149	N/A	N/A

Nomenclature: See separate page