

FAROSUND AR, Sweden

WMO: 025870

Lat: 57.9165N

Lon: 18.9533E

Elev: 43

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	18.7	22.2	11.9	10.1	20.3	14.8	11.7	24.0	39.1	33.0	34.9	31.8	10.8	90	0.708

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	76.2	65.9	73.4	64.7	71.1	63.6	68.7	73.1	66.9	71.2	65.2	69.5	11.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.1	99.8	71.6	65.2	93.3	69.4	63.4	87.5	68.0	33.0	73.2	31.5	71.1	30.2	69.4	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
35.4	30.5	26.6	16.0	80.5	5.3	2.9	12.2	82.6	9.1	84.2	6.1	85.8	2.3	87.9
			14.7	69.8	4.5	2.8	11.5	71.8	8.9	73.4	6.3	74.9	3.1	76.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	32.7	32.1	35.6	41.8	50.7	59.0	64.4	64.2	57.0	48.3	41.6	36.2
	DBStd	12.55	5.32	5.75	5.52	5.37	5.52	4.88	4.38	3.95	4.47	5.00	4.35	5.64
	HDD50	2572	536	501	447	252	57	2	0	0	4	94	253	426
	HDD65	6638	1001	921	912	696	443	187	64	62	240	519	702	891
	CDD50	1501	0	0	0	6	80	272	446	440	215	41	1	0
	CDD65	93	0	0	0	0	0	8	46	37	2	0	0	0
	CDH74	211	0	0	0	0	3	25	115	67	1	0	0	0
	CDH80	19	0	0	0	0	0	1	14	4	0	0	0	0
Wind	WSAvg	12.9	15.3	14.1	13.8	12.0	10.5	11.3	11.0	11.1	12.7	14.3	14.1	14.8
Precipitation	PrecAvg	20.9	1.7	1.3	1.0	1.2	1.4	1.3	2.6	2.1	1.9	2.0	2.4	2.1
	PrecMax	25.7	3.1	1.9	1.9	2.2	2.5	2.4	4.6	3.7	5.0	3.9	4.7	3.5
	PrecMin	16.7	0.4	0.6	0.5	0.3	0.4	0.4	0.2	0.0	0.7	0.7	0.5	0.7
	PrecStd	2.4	0.7	0.4	0.4	0.6	0.7	0.5	1.5	0.9	1.0	0.9	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.3	47.6	53.9	62.0	71.0	77.7	82.1	79.3	72.5	61.4	52.6	51.0
		MCWB	44.4	44.1	45.8	50.6	57.0	63.6	68.8	68.9	61.4	56.5	50.6	48.3
	2%	DB	44.2	43.7	48.5	56.6	65.9	72.8	76.9	75.6	68.1	58.7	50.4	48.0
		MCWB	41.7	40.9	42.8	48.2	55.5	61.7	67.0	66.0	60.2	54.9	48.3	45.5
	5%	DB	41.8	41.4	45.3	52.9	62.1	69.4	73.8	72.7	65.8	57.0	49.1	45.3
		MCWB	39.6	39.2	41.2	45.7	53.5	59.7	65.6	65.0	59.4	53.9	47.2	43.2
	10%	DB	39.9	39.6	42.7	49.9	58.9	66.7	71.5	70.6	63.6	55.3	47.7	43.2
		MCWB	38.1	37.8	39.8	44.3	51.6	58.1	64.6	64.0	58.4	52.5	46.1	41.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.0	43.9	46.5	52.2	60.0	66.8	71.7	71.9	63.9	57.7	51.3	48.6
		MCDB	47.1	46.2	52.2	60.0	67.6	73.9	77.7	77.4	68.4	60.1	52.4	50.4
	2%	WB	42.0	41.1	43.6	49.0	56.8	63.4	69.2	68.7	61.8	55.6	48.9	45.7
		MCDB	43.7	43.1	47.6	55.5	63.4	70.2	73.7	72.7	66.1	58.0	50.0	47.6
	5%	WB	39.9	39.4	41.7	46.6	54.7	61.2	67.5	66.8	60.4	54.2	47.5	43.4
		MCDB	41.4	41.1	44.5	52.0	60.6	66.8	71.8	70.7	64.0	56.3	48.7	44.9
	10%	WB	38.2	37.9	40.0	44.6	52.7	59.4	65.9	65.1	59.2	52.9	46.3	41.6
		MCDB	39.7	39.6	42.5	48.7	57.7	65.0	70.2	69.2	62.7	55.0	47.6	43.0
Mean Daily Temperature Range	5% DB	MDBR	5.6	5.9	7.7	10.1	11.2	10.7	9.4	9.2	8.1	6.6	5.2	5.2
		MCDBR	7.7	7.9	12.2	16.1	16.7	15.7	13.1	12.3	11.5	8.5	5.9	6.5
		MCWBR	7.2	6.4	8.2	9.2	9.1	7.8	6.3	6.1	6.1	6.4	5.4	6.2
	5% WB	MCDBR	7.4	7.7	11.5	15.1	15.0	14.1	10.7	10.3	9.9	8.3	5.8	6.5
		MCWBR	7.1	6.6	8.3	9.3	9.5	8.1	6.3	6.0	6.3	6.7	5.5	6.3
Clear-Sky Solar Irradiance	taub	0.300	0.329	0.344	0.379	0.374	0.365	0.396	0.388	0.357	0.346	0.327	0.291	
	taud	2.255	2.313	2.365	2.324	2.416	2.480	2.413	2.424	2.485	2.403	2.262	2.182	
	Ebn at Noon	173	223	255	263	273	277	265	259	250	215	158	134	
	Edh at Noon	15	23	28	34	33	32	33	31	25	21	15	12	
All-Sky Solar Radiation	RadAvg	100	276	763	1361	1842	2006	1846	1460	961	423	140	70	
	RadStd	16	51	75	133	134	94	151	114	104	66	28	12	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (33 neighbors)	+0.67	N/A	+2.14	N/A	N/A	N/A	-194	-254	N/A	N/A

Nomenclature: See separate page