

GOTSKA SANDON, SwedenWMO: **025890**Lat: **58.394N**Lon: **19.194E**Elev: **52**StdP: **14.67**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	18.5	21.8	10.3	9.3	20.7	13.7	11.1	23.8	32.2	32.9	29.8	34.6	9.8	110	0.684

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	75.8	66.5	73.1	65.0	70.8	63.9	68.4	73.4	66.6	71.2	65.0	69.5	8.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	98.0	70.9	64.8	91.9	69.4	63.0	86.2	67.9	32.7	73.5	31.3	71.1	30.0	69.8	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.4	25.3	22.6	13.9	79.1	5.7	4.4	9.8	82.3	6.5	84.9	3.2	87.4	-0.9	90.6		
(5)			12.8	70.2	5.2	3.3	9.1	72.6	6.0	74.5	3.1	76.3	-0.6	78.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.0	32.7	31.7	34.0	40.2	48.0	56.9	63.7	63.5	56.5	47.6	40.7	35.9		
	DBStd	12.38	5.13	5.64	4.76	4.81	5.47	4.62	4.77	4.12	4.61	4.97	4.73	5.47		
	HDD50	2777	536	512	497	299	103	3	0	0	6	105	278	438		
	HDD65	6997	1001	932	962	745	526	246	81	77	257	539	728	903		
	CDD50	1331	0	0	0	4	42	210	425	419	200	31	0	0		
	CDD65	78	0	0	0	0	0	4	42	31	1	0	0	0		
	CDH74	178	0	0	0	0	0	8	118	52	0	0	0	0		
	CDH80	15	0	0	0	0	0	0	12	3	0	0	0	0		
	WSAvg	11.6	13.7	12.5	11.9	10.8	9.7	9.9	9.4	10.0	11.5	12.7	13.1	13.9		
	PrecAvg	21.1	1.8	1.3	1.1	1.3	1.1	1.3	2.1	2.1	2.2	2.1	2.5	2.2		
	PrecMax	34.5	3.9	2.7	2.9	3.1	2.6	3.3	6.0	5.5	6.5	7.7	8.3	4.9		
(15) Precipitation	PrecMin	13.9	0.3	0.4	0.2	0.0	0.1	0.0	0.1	0.1	0.4	0.5	0.7	0.5		
	PrecStd	3.3	0.7	0.6	0.6	0.7	0.7	0.7	1.4	1.4	1.2	1.3	1.3	1.0		
	DB	43.7	42.2	46.8	59.7	68.4	74.8	81.7	78.3	70.8	59.7	51.7	47.3			
	MCWB	42.2	40.0	42.0	48.9	57.5	63.5	68.8	66.6	63.2	56.3	50.3	45.9			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	42.1	40.8	43.3	53.5	63.6	70.1	77.2	75.2	67.3	57.5	49.8	45.8			
	2% MCWB	40.8	39.1	40.0	46.2	55.1	60.6	67.9	66.1	61.1	54.8	48.4	44.5			
	5% DB	40.8	39.8	41.4	50.0	59.3	67.2	74.0	72.8	64.9	55.9	48.4	44.3			
	5% MCWB	39.6	38.3	38.8	44.3	52.2	59.2	66.0	64.8	59.9	53.5	47.1	43.0			
	10% DB	39.6	38.7	39.9	47.1	56.4	64.5	71.6	70.6	62.9	54.4	47.1	42.7			
	10% MCWB	38.4	37.4	37.8	42.9	50.7	57.9	64.8	64.1	58.8	52.3	45.8	41.6			
	0.4% WB	42.5	40.9	42.7	50.1	59.0	65.3	72.2	70.4	64.6	57.2	50.6	46.5			
	0.4% MCDB	43.1	41.4	45.6	58.0	66.2	72.1	77.5	75.8	68.4	58.6	51.1	47.1			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	41.2	39.7	40.6	46.8	55.9	62.2	69.4	67.8	62.3	55.4	48.6	44.8			
	2% MCDB	41.8	40.4	42.5	52.0	62.2	68.1	74.9	72.0	65.7	57.0	49.4	45.5			
	5% WB	40.0	38.6	39.4	44.9	53.3	60.4	67.5	66.3	60.8	54.0	47.4	43.2			
	5% MCDB	40.7	39.5	41.0	49.1	57.9	65.3	72.6	70.7	63.8	55.4	48.2	44.0			
	10% WB	38.5	37.6	38.2	43.2	51.4	58.9	65.8	64.9	59.4	52.7	46.0	41.7			
	10% MCDB	39.4	38.5	39.6	46.5	55.3	63.4	70.3	69.3	62.2	54.1	46.9	42.5			
	MDBR	4.8	5.5	7.3	10.0	11.7	11.5	11.2	11.0	8.8	6.3	4.9	4.8			
	5% DB	4.7	5.4	8.7	14.3	15.8	15.6	14.6	13.8	11.0	7.1	5.0	4.6			
(36) Mean Daily Temperature Range	5% DB	5.0	4.8	6.6	8.7	9.0	8.1	7.4	7.7	7.0	5.7	5.1	4.9			
	5% WB	5.0	5.1	8.0	12.8	14.0	14.0	13.2	12.1	9.8	6.2	4.8	4.7			
	MCWBR	5.4	4.8	6.5	8.3	8.8	8.2	7.4	7.5	6.9	5.6	5.1	5.1			
	MCWBR	5.4	4.8	6.5	8.3	8.8	8.2	7.4	7.5	6.9	5.6	5.1	5.1			
(40) Clear-Sky Solar Irradiance	taub	0.297	0.327	0.342	0.377	0.371	0.364	0.394	0.384	0.354	0.343	0.323	0.286			
	taud	2.251	2.317	2.372	2.334	2.429	2.488	2.424	2.435	2.498	2.409	2.257	2.171			
	Ebn at Noon	169	221	255	263	274	277	265	259	250	214	154	129			
	Edh at Noon	15	22	28	34	33	31	33	30	24	20	15	11			
(44) All-Sky Solar Radiation	RadAvg	94	269	763	1349	1838	2011	1862	1473	958	413	133	65			
	RadStd	15	51	76	125	139	98	159	112	101	66	30	11			

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.65	N/A	+2.12	N/A	N/A	N/A	-203	-333	N/A	N/A
(47) Regional (41 neighbors)		+0.65	N/A	N/A	N/A	N/A	N/A	-187	-241	N/A	N/A

Nomenclature: See separate page