

VISBY, Sweden

WMO: 025900

Lat: 57.661N

Lon: 18.343E

Elev: 138

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.0	19.0	8.3	8.5	18.1	12.2	10.3	21.7	32.2	36.1	29.6	34.9	5.3	70	0.681

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	78.2	65.1	75.0	63.7	72.0	62.7	67.9	73.9	66.0	71.8	64.4	70.1	10.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.9	95.9	70.7	64.0	89.7	69.0	62.2	84.1	67.5	32.3	74.0	30.8	71.7	29.6	70.1	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.6	24.6	22.0	DB	6.3	82.3	7.2	3.5	1.1	84.9	-3.1	86.9	-7.1	88.9	-12.4	91.5	(4)
(5)			WB	5.8	70.0	7.1	2.8	0.7	72.1	-3.5	73.7	-7.5	75.3	-12.6	77.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.7	31.4	30.9	33.8	41.5	49.6	57.7	62.7	62.4	55.4	46.8	39.9	34.8	(6)	
	DBStd	12.79	6.25	6.74	6.41	6.32	6.49	5.10	4.90	4.72	5.13	5.50	5.39	6.34	(7)	
	HDD50	2885	577	536	503	266	86	4	0	0	13	128	302	470	(8)	
	HDD65	7125	1042	956	968	705	477	227	105	106	289	563	752	935	(9)	
	CDD50	1304	0	0	0	11	74	234	394	386	175	29	1	0	(10)	
	CDD65	70	0	0	0	0	1	7	34	27	1	0	0	0	(11)	
	CDH74	370	0	0	0	0	11	47	195	112	5	0	0	0	(12)	
	CDH80	42	0	0	0	0	0	3	25	14	0	0	0	0	(13)	
	WSAvg	11.0	12.6	11.9	11.2	10.5	9.8	9.9	9.3	9.6	10.6	11.8	11.7	12.8	(14)	
	PrecAvg	20.6	1.9	1.2	1.1	1.1	1.1	1.4	2.3	2.1	2.1	2.0	2.2	2.1	(15)	
(16) Precipitation	PrecMax	28.3	3.6	2.6	3.1	3.6	3.1	4.4	6.1	5.0	6.1	5.0	5.3	4.8	(16)	
	PrecMin	12.3	0.2	0.4	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.3	0.4	0.4	(17)	
	PrecStd	3.3	0.9	0.5	0.7	0.7	0.8	0.9	1.5	1.2	1.3	1.1	0.9	1.0	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.6	45.8	53.2	67.4	75.4	79.0	83.1	82.0	73.3	62.2	52.2	48.6	(19)	
		MCWB	44.1	42.9	44.6	55.0	63.0	64.7	67.5	67.4	62.6	56.8	50.5	47.5	(20)	
	2%	DB	42.9	42.8	48.1	59.6	70.2	74.2	79.0	76.9	68.4	58.6	50.3	46.5	(21)	
		MCWB	41.7	40.8	42.6	49.5	58.1	61.7	65.3	64.9	60.4	55.3	49.0	45.2	(22)	
	5%	DB	41.1	41.0	44.6	55.8	65.5	70.5	75.5	73.8	65.9	56.6	48.6	44.6	(23)	
		MCWB	39.7	39.4	40.8	47.6	55.0	59.7	64.3	63.9	59.7	54.1	47.3	43.4	(24)	
	10%	DB	39.4	39.3	42.2	52.0	61.1	67.4	72.0	71.3	63.2	54.9	47.0	42.8	(25)	
		MCWB	38.2	37.8	39.5	45.0	52.7	58.2	63.6	63.3	58.4	52.4	45.9	41.7	(26)	
	0.4%	WB	44.4	43.2	46.1	55.7	64.5	67.6	71.0	71.2	65.1	57.6	51.5	48.0	(27)	
		MCDB	45.0	44.5	51.3	65.7	74.4	75.7	77.2	79.3	69.7	60.3	52.1	48.6	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.8	41.1	43.1	51.1	60.2	63.7	68.5	67.5	62.4	55.8	49.3	45.3	(29)	
		MCDB	42.5	42.2	46.3	57.7	67.3	71.2	75.0	72.6	66.1	58.0	50.0	46.0	(30)	
	5%	WB	39.8	39.4	41.3	48.7	56.6	61.2	66.5	65.9	60.6	54.4	47.5	43.2	(31)	
		MCDB	40.6	40.6	43.8	54.9	63.2	67.8	72.3	71.1	64.5	56.3	48.3	44.1	(32)	
	10%	WB	38.2	37.8	39.6	46.0	53.7	59.4	64.8	64.4	59.2	52.9	46.0	41.6	(33)	
		MCDB	39.0	39.0	41.7	50.6	60.3	65.3	70.6	69.4	62.6	54.6	46.8	42.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	7.5	10.5	14.7	16.2	14.3	13.8	13.5	11.8	8.8	6.5	6.2	(35)	
		MCDBR	6.8	7.8	14.1	20.9	22.7	20.3	19.6	17.5	15.4	10.6	6.7	6.3	(36)	
		MCWBR	6.8	6.6	9.7	12.5	13.0	10.6	9.5	8.9	9.5	8.0	6.7	6.3	(37)	
	5% WB	MCDBR	6.6	7.5	12.7	18.8	20.6	17.7	16.8	15.0	14.0	10.1	6.5	6.3	(38)	
		MCWBR	6.7	6.7	9.4	12.2	13.4	10.2	9.4	8.6	9.2	8.0	6.6	6.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.298	0.328	0.342	0.378	0.372	0.364	0.395	0.386	0.356	0.345	0.325	0.289	(40)	
	taud		2.270	2.322	2.367	2.324	2.414	2.478	2.412	2.423	2.485	2.407	2.273	2.199	(41)	
	Ebn at Noon		177	225	257	264	274	278	265	259	251	217	161	140	(42)	
	Edh at Noon		15	23	28	34	33	32	33	31	25	21	16	12	(43)	
(44) All-Sky Solar Radiation	RadAvg		105	283	764	1360	1831	1991	1825	1445	960	427	145	74	(44)	
	RadStd		17	52	75	138	133	92	149	116	106	67	27	13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.63	N/A	+2.43	N/A	N/A	N/A	-175	-211	N/A	N/A
Regional (33 neighbors)		+0.68	N/A	+2.34	N/A	N/A	N/A	-194	-254	N/A	N/A

Nomenclature: See separate page