

VISBY, Sweden

WMO: 025900

Lat: 57.661N

Lon: 18.343E

Elev: 42

StdP: 100.82

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-10.0	-7.2	-13.2	1.2	-7.7	-11.0	1.5	-5.7	14.4	2.3	13.2	1.6	2.3	70	0.681

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	25.7	18.4	23.9	17.6	22.2	17.1	20.0	23.3	18.9	22.1	18.0	21.2	4.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.8	13.7	21.5	17.8	12.8	20.6	16.8	12.0	19.7	57.3	23.3	53.9	22.0	51.0	21.2	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	11.0	9.8	DB	-14.3	28.0	4.0	2.0	-17.1	29.4	-19.5	30.5	-21.7	31.6	-24.7	33.0	(4)
(5)			WB	-14.6	21.1	3.9	1.6	-17.4	22.3	-19.7	23.2	-21.9	24.1	-24.8	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.6	-0.3	-0.6	1.0	5.3	9.8	14.3	17.1	16.9	13.0	8.2	4.4	1.6	(6)	
	DBStd	7.11	3.47	3.75	3.56	3.51	3.60	2.83	2.72	2.62	2.85	3.06	3.00	3.52	(7)	
	HDD10.0	1603	321	298	279	148	48	2	0	0	7	71	168	261	(8)	
	HDD18.3	3958	579	531	538	392	265	126	58	59	161	313	418	519	(9)	
	CDD10.0	724	0	0	0	6	41	130	219	214	97	16	1	0	(10)	
	CDD18.3	39	0	0	0	0	1	4	19	15	1	0	0	0	(11)	
	CDH23.3	206	0	0	0	0	6	26	108	62	3	0	0	0	(12)	
	CDH26.7	23	0	0	0	0	0	2	14	8	0	0	0	0	(13)	
(14) Wind	WSAvg	4.9	5.6	5.3	5.0	4.7	4.4	4.4	4.2	4.3	4.7	5.3	5.2	5.7	(14)	
(15) Precipitation	PrecAvg	524	47	30	29	28	29	35	58	54	54	51	56	53	(15)	
	PrecMax	718	92	67	79	91	79	112	154	128	156	128	134	122	(16)	
	PrecMin	312	5	9	0	1	0	3	0	1	0	7	9	9	(17)	
	PrecStd	84	22	13	19	18	20	22	37	31	33	28	23	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.5	7.7	11.8	19.7	24.1	26.1	28.4	27.8	23.0	16.8	11.2	9.2	(19)	
		MCWB	6.7	6.1	7.0	12.8	17.2	18.2	19.7	19.6	17.0	13.8	10.3	8.6	(20)	
	2%	DB	6.1	6.0	9.0	15.3	21.2	23.5	26.1	24.9	20.2	14.8	10.2	8.0	(21)	
		MCWB	5.4	4.9	5.9	9.7	14.5	16.5	18.5	18.3	15.8	12.9	9.4	7.3	(22)	
	5%	DB	5.0	5.0	7.0	13.2	18.6	21.4	24.2	23.2	18.8	13.7	9.2	7.0	(23)	
		MCWB	4.3	4.1	4.9	8.7	12.8	15.4	17.9	17.7	15.4	12.3	8.5	6.3	(24)	
	10%	DB	4.1	4.0	5.7	11.1	16.2	19.6	22.2	21.9	17.3	12.7	8.4	6.0	(25)	
		MCWB	3.4	3.2	4.2	7.2	11.5	14.5	17.5	17.4	14.7	11.4	7.7	5.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	6.2	7.8	13.2	18.0	19.8	21.7	21.8	18.4	14.2	10.8	8.9	(27)	
		MCDB	7.2	7.0	10.7	18.7	23.5	24.3	25.1	26.3	20.9	15.7	11.2	9.2	(28)	
	2%	WB	5.5	5.0	6.1	10.6	15.7	17.6	20.3	19.7	16.9	13.2	9.6	7.4	(29)	
		MCDB	5.9	5.7	7.9	14.3	19.6	21.8	23.9	22.6	19.0	14.5	10.0	7.8	(30)	
	5%	WB	4.3	4.1	5.1	9.3	13.7	16.2	19.2	18.8	15.9	12.4	8.6	6.2	(31)	
		MCDB	4.8	4.8	6.6	12.7	17.3	19.9	22.4	21.7	18.0	13.5	9.1	6.7	(32)	
	10%	WB	3.4	3.2	4.2	7.8	12.1	15.2	18.2	18.0	15.1	11.6	7.8	5.3	(33)	
		MCDB	3.9	3.9	5.4	10.3	15.7	18.5	21.5	20.8	17.0	12.6	8.2	5.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.7	4.2	5.9	8.2	9.0	8.0	7.7	7.5	6.5	4.9	3.6	3.5	(35)	
		MCDBR	3.8	4.4	7.8	11.6	12.6	11.3	10.9	9.7	8.6	5.9	3.7	3.5	(36)	
		MCWBR	3.8	3.7	5.4	6.9	7.2	5.9	5.3	4.9	5.3	4.5	3.7	3.5	(37)	
	5% WB	MCDBR	3.7	4.2	7.0	10.5	11.5	9.8	9.3	8.3	7.8	5.6	3.6	3.5	(38)	
		MCWBR	3.7	3.7	5.2	6.8	7.4	5.7	5.2	4.8	5.1	4.5	3.7	3.5	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.298	0.328	0.342	0.378	0.372	0.364	0.395	0.386	0.356	0.345	0.325	0.289	(40)	
	taud		2.270	2.322	2.367	2.324	2.414	2.478	2.412	2.423	2.485	2.407	2.273	2.199	(41)	
	Ebn at Noon		558	710	809	832	864	876	836	817	791	683	509	441	(42)	
	Edh at Noon		48	71	88	108	105	100	105	97	79	65	49	39	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.33	0.89	2.41	4.29	5.77	6.28	5.75	4.56	3.03	1.34	0.46	0.23	(44)	
	RadStd		0.05	0.17	0.24	0.43	0.42	0.29	0.47	0.36	0.33	0.21	0.09	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		+0.35	N/A	+1.35	N/A	N/A	N/A	-97	-117	N/A	N/A	
(47)	Regional (33 neighbors)	+0.38	N/A	+1.30	N/A	N/A	N/A	-108	-141	N/A	N/A	(47)

Nomenclature: See separate page