

OSTERGARNSHOLM, Sweden

WMO: 025980

Lat: 57.441N

Lon: 18.984E

Elev: 26

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.9	22.9	10.7	9.5	21.3	14.9	11.7	25.1	41.1	31.6	38.2	35.5	13.7	60	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	74.5	68.4	71.8	66.0	69.7	64.3	69.7	73.0	67.4	70.5	65.6	68.6	11.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.4	104.4	72.0	66.1	96.2	69.4	64.3	90.2	67.9	33.7	73.1	31.8	70.5	30.5	68.8	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.8	31.2	28.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.8	33.1	32.4	35.4	40.9	49.1	58.1	64.2	63.9	57.5	49.0	41.6	35.7
	DBStd	12.25	4.59	5.89	4.73	3.94	4.63	4.24	4.05	3.78	3.67	4.52	4.19	5.36
	HDD50	2590	524	494	453	274	72	2	0	0	1	75	251	444
	HDD65	6707	989	914	918	724	493	211	64	64	224	496	701	909
	CDD50	1430	0	0	0	0	44	244	440	431	227	44	0	0
	CDD65	71	0	0	0	0	0	2	39	30	0	0	0	0
	CDH74	95	0	0	0	0	0	4	56	35	0	0	0	0
	CDH80	1	0	0	0	0	0	0	0	1	0	0	0	0
	WSAvg	14.6	17.5	17.3	15.0	12.7	11.4	12.0	11.9	12.7	14.5	16.3	16.7	17.5
	PrecAvg	21.9	1.9	1.5	1.1	1.1	1.3	1.5	2.3	2.3	2.0	2.1	2.5	2.2
(15) Precipitation	PrecMax	28.5	3.5	2.2	2.4	2.1	3.2	3.9	5.3	5.0	4.4	3.6	5.5	4.3
	PrecMin	17.6	0.2	0.5	0.2	0.1	0.3	0.1	0.0	0.0	0.6	0.4	0.4	0.7
	PrecStd	2.5	0.7	0.5	0.6	0.6	0.7	0.8	1.5	1.2	1.0	0.9	1.0	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.0	46.0	51.8	55.9	63.8	72.1	78.4	78.3	68.4	61.6	50.2	47.1
		MCWB	42.1	42.4	44.8	48.1	56.1	61.5	69.6	70.1	60.9	57.3	47.8	44.5
	2%	DB	41.8	42.9	46.2	51.9	60.3	68.3	75.5	73.7	65.9	58.6	48.7	44.1
		MCWB	40.1	40.1	41.5	46.0	54.0	61.0	69.2	67.5	60.8	55.9	47.0	42.7
	5%	DB	40.5	40.8	43.1	48.9	58.0	66.4	73.2	71.2	64.5	56.6	48.0	43.1
		MCWB	39.1	38.9	40.0	44.6	53.3	60.3	67.7	65.8	60.3	54.3	46.6	41.9
	10%	DB	39.5	39.3	41.1	46.5	55.7	64.6	70.8	69.3	63.0	55.2	47.0	42.1
		MCWB	38.3	38.2	39.0	43.4	51.8	59.5	65.4	64.4	59.2	53.0	45.6	40.9
	0.4%	WB	42.5	43.3	44.9	49.3	58.7	65.3	73.3	72.8	63.9	58.5	48.9	45.0
		MCDB	43.5	44.8	50.5	54.7	61.6	69.5	76.1	75.9	66.9	60.1	49.8	45.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	40.7	40.5	42.0	46.6	55.8	63.0	70.7	69.1	62.2	56.4	47.8	43.2
		MCDB	41.4	42.1	44.9	50.2	58.8	66.6	74.1	71.7	64.6	57.8	48.3	43.7
	5%	WB	39.8	39.3	40.5	45.1	53.9	61.5	68.4	67.1	61.2	54.7	47.0	42.2
		MCDB	40.4	40.3	42.4	48.3	56.9	64.9	72.1	69.8	63.5	56.1	47.7	42.7
	10%	WB	38.4	38.2	39.3	43.6	52.3	60.2	66.4	65.7	60.1	53.3	46.0	41.0
		MCDB	39.3	39.3	40.9	46.2	55.3	63.5	69.7	68.5	62.4	54.8	46.9	41.8
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	5.0	6.7	8.5	8.9	9.6	8.7	8.2	7.2	5.9	4.9	4.7
		MCDBR	5.3	6.9	10.5	12.7	12.6	12.1	10.8	9.3	8.5	7.0	5.4	4.6
		MCWBR	5.2	5.4	7.4	8.1	7.2	6.8	5.5	5.8	5.5	5.8	5.1	4.5
	5% WB	MCDBR	5.4	6.7	9.5	11.9	10.6	10.5	8.9	8.3	7.2	6.7	4.9	4.5
		MCWBR	5.4	5.4	7.0	8.2	7.1	6.6	5.5	5.7	5.3	5.9	5.0	4.7
(40) Clear-Sky Solar Irradiance	taub	0.304	0.331	0.346	0.381	0.376	0.367	0.399	0.391	0.361	0.348	0.332	0.297	
	taud	2.262	2.314	2.356	2.318	2.409	2.473	2.403	2.415	2.475	2.397	2.265	2.198	
	Ebn at Noon	176	224	255	263	273	277	264	258	250	216	161	139	
	Edh at Noon	16	23	29	35	34	32	34	31	25	21	16	13	
(44) All-Sky Solar Radiation	RadAvg	106	285	764	1374	1850	2007	1835	1453	966	433	147	74	
	RadStd	17	51	75	140	132	92	144	116	106	67	26	13	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-189	-252	N/A	N/A

Nomenclature: See separate page