

OSTERGARNSHOLM, Sweden

WMO: 025980

Lat: 57.441N

Lon: 18.984E

Elev: 8

StdP: 101.23

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.7	-5.0	-11.8	1.4	-5.9	-9.5	1.7	-3.8	18.4	-0.2	17.1	1.9	6.1	60	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.8	23.6	20.2	22.1	18.9	21.0	17.9	20.9	22.8	19.6	21.4	18.7	20.4	5.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	14.9	22.2	18.9	13.7	20.8	17.9	12.9	19.9	60.6	22.9	56.2	21.4	53.1	20.4	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.5	14.0	12.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	0.6	0.2	1.9	4.9	9.5	14.5	17.9	17.7	14.2	9.4	5.3	2.0
	DBStd	6.81	2.55	3.27	2.63	2.19	2.57	2.36	2.25	2.10	2.04	2.51	2.33	2.98
	HDD10.0	1439	291	274	252	152	40	1	0	0	1	42	139	247
	HDD18.3	3726	549	508	510	402	274	117	36	36	124	276	389	505
	CDD10.0	794	0	0	0	0	24	136	244	239	126	24	0	0
	CDD18.3	39	0	0	0	0	0	1	22	17	0	0	0	0
	CDH23.3	53	0	0	0	0	0	2	31	19	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	0	1	0	0	0	0
Wind	WSAvg	6.5	7.8	7.7	6.7	5.7	5.1	5.4	5.3	5.7	6.5	7.3	7.5	7.8
Precipitation	PrecAvg	555	47	37	29	28	34	38	59	59	51	53	64	56
	PrecMax	723	90	55	60	54	82	99	134	128	113	92	139	108
	PrecMin	448	6	12	6	3	7	2	0	0	14	9	9	17
	PrecStd	63	19	12	14	14	18	21	38	31	26	22	26	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.7	7.8	11.0	13.3	17.7	22.3	25.8	25.7	20.2	16.4	10.1	8.4
		MCWB	5.6	5.8	7.1	9.0	13.4	16.4	20.9	21.2	16.1	14.1	8.8	7.0
	2%	DB	5.4	6.1	7.9	11.1	15.7	20.2	24.2	23.2	18.9	14.8	9.3	6.7
		MCWB	4.5	4.5	5.3	7.8	12.2	16.1	20.6	19.7	16.0	13.3	8.3	6.0
	5%	DB	4.7	4.9	6.2	9.4	14.4	19.1	22.9	21.8	18.1	13.7	8.9	6.2
		MCWB	4.0	3.8	4.4	7.0	11.8	15.7	19.8	18.8	15.7	12.4	8.1	5.5
	10%	DB	4.2	4.1	5.1	8.0	13.2	18.1	21.6	20.7	17.2	12.9	8.4	5.6
		MCWB	3.5	3.4	3.9	6.3	11.0	15.3	18.6	18.0	15.1	11.7	7.6	4.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.8	6.3	7.2	9.6	14.8	18.5	22.9	22.7	17.7	14.7	9.4	7.2
		MCDB	6.4	7.1	10.3	12.6	16.5	20.8	24.5	24.4	19.4	15.6	9.9	7.7
	2%	WB	4.8	4.7	5.6	8.1	13.2	17.2	21.5	20.6	16.8	13.5	8.8	6.2
		MCDB	5.2	5.6	7.1	10.1	14.9	19.2	23.4	22.1	18.1	14.4	9.1	6.5
	5%	WB	4.3	4.0	4.7	7.3	12.2	16.4	20.2	19.5	16.2	12.6	8.3	5.6
		MCDB	4.7	4.6	5.8	9.0	13.8	18.3	22.3	21.0	17.5	13.4	8.7	5.9
	10%	WB	3.5	3.5	4.1	6.4	11.3	15.7	19.1	18.7	15.6	11.9	7.8	5.0
		MCDB	4.0	4.1	5.0	7.9	13.0	17.5	20.9	20.3	16.9	12.7	8.3	5.5
Mean Daily Temperature Range	5% DB	MDBR	2.6	2.8	3.7	4.7	4.9	5.3	4.8	4.5	4.0	3.3	2.7	2.6
		MCDBR	2.9	3.8	5.9	7.1	7.0	6.7	6.0	5.2	4.7	3.9	3.0	2.6
		MCWBR	2.9	3.0	4.1	4.5	4.0	3.8	3.1	3.2	3.1	3.2	2.9	2.5
	5% WB	MCDBR	3.0	3.7	5.3	6.6	5.9	5.9	4.9	4.6	4.0	3.7	2.7	2.5
		MCWBR	3.0	3.0	3.9	4.5	4.0	3.7	3.1	3.2	3.0	3.3	2.8	2.6
Clear-Sky Solar Irradiance	taub	0.304	0.331	0.346	0.381	0.376	0.367	0.399	0.391	0.361	0.348	0.332	0.297	
	taud	2.262	2.314	2.356	2.318	2.409	2.473	2.403	2.415	2.475	2.397	2.265	2.198	
	Ebn at Noon	555	707	805	830	861	873	832	813	787	681	506	439	
	Edh at Noon	50	73	90	109	106	101	106	99	80	67	50	40	
All-Sky Solar Radiation	RadAvg	0.33	0.90	2.41	4.33	5.83	6.33	5.79	4.58	3.04	1.36	0.46	0.23	
	RadStd	0.05	0.16	0.24	0.44	0.41	0.29	0.46	0.37	0.34	0.21	0.08	0.04	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (22 neighbors)		+0.38	N/A	N/A	N/A	N/A	N/A	-105	-140	N/A	N/A	

Nomenclature: See separate page