

HALMSTAD, Sweden

WMO: **026040**Lat: **56.691N**Lon: **12.924E**Elev: **79**StdP: **14.65**Time Zone: **1.00 (EUC)**Period: **03-19**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.6	17.3	8.2	8.4	18.2	11.9	10.1	20.4	33.7	42.5	30.0	41.8	6.8	50	0.633

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	80.3	65.0	76.9	64.0	73.5	62.4	67.4	75.5	65.7	73.1	64.2	70.6	9.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.5	91.2	70.4	62.8	85.9	68.9	61.2	80.9	67.3	31.8	75.3	30.6	73.3	29.4	71.0	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.5	23.5	21.1	DB	7.7	84.3	6.0	3.6	3.4	86.9	-0.1	89.0	-3.4	91.1	-7.7	93.7	(4)
(5)			WB	6.8	70.7	5.8	1.9	2.6	72.0	-0.8	73.1	-4.1	74.1	-8.3	75.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.4	32.1	32.2	36.4	45.4	53.4	59.0	63.6	62.6	56.8	48.2	41.7	36.3	(6)	
	DBStd	12.68	7.26	6.15	6.71	6.03	6.78	4.88	4.68	4.06	4.66	5.77	6.24	7.50	(7)	
	HDD50	2460	555	498	421	165	35	1	0	0	6	101	253	425	(8)	
	HDD65	6508	1020	918	886	588	365	192	85	97	247	520	700	890	(9)	
	CDD50	1513	0	0	0	27	142	270	423	391	211	46	3	0	(10)	
	CDD65	86	0	0	0	0	7	11	43	23	2	0	0	0	(11)	
	CDH74	605	0	0	0	1	70	92	320	112	10	0	0	0	(12)	
	CDH80	82	0	0	0	0	8	7	56	10	1	0	0	0	(13)	
(14) Wind	WSAvg	9.9	11.2	10.3	10.1	9.3	9.1	9.1	8.3	8.9	10.1	10.3	10.9	11.5	(14)	
(15) Precipitation	PrecAvg	30.7	2.4	1.6	1.9	1.7	1.8	2.6	3.0	3.6	3.3	3.1	2.9	2.8	(15)	
	PrecMax	46.3	5.4	4.2	4.6	3.6	4.9	8.8	7.5	7.1	7.3	7.8	4.9	6.6	(16)	
	PrecMin	17.8	0.1	0.0	0.1	0.1	0.1	0.0	0.2	0.5	1.1	0.7	1.2	0.5	(17)	
	PrecStd	5.8	1.2	1.0	1.1	0.9	1.0	1.6	1.6	1.6	1.5	1.7	1.1	1.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.7	46.2	59.1	69.8	80.7	80.7	84.6	80.9	75.0	64.5	55.3	50.0	(19)	
		MCWB	45.8	42.7	47.6	54.8	62.6	64.4	65.8	65.5	63.1	57.7	52.8	48.8	(20)	
	2%	DB	44.7	43.1	51.5	64.8	75.2	76.9	80.8	77.1	69.9	59.4	52.2	48.0	(21)	
		MCWB	43.9	41.4	44.5	51.4	60.2	63.1	65.9	64.7	60.6	55.9	50.1	46.8	(22)	
	5%	DB	43.0	41.3	46.7	60.8	70.2	73.2	77.3	73.7	66.4	57.5	50.4	46.4	(23)	
		MCWB	42.1	40.1	42.4	49.9	58.0	61.5	64.9	63.7	59.6	54.3	48.9	45.5	(24)	
	10%	DB	41.3	40.6	44.5	56.9	66.1	68.4	73.6	70.2	64.3	55.7	49.7	44.8	(25)	
		MCWB	40.3	39.5	41.5	48.0	56.6	59.3	63.4	62.7	58.9	52.8	48.4	43.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.6	43.2	48.5	56.6	65.0	67.5	70.1	69.3	64.7	59.3	53.3	48.7	(27)	
		MCDB	45.9	43.9	56.6	66.4	76.1	76.6	79.8	76.7	70.6	62.6	55.1	49.2	(28)	
	2%	WB	43.7	41.5	45.1	53.3	62.2	64.9	68.0	66.9	62.3	56.9	51.2	46.4	(29)	
		MCDB	44.1	42.3	48.7	62.4	71.4	73.5	76.8	73.7	67.6	59.7	52.6	47.0	(30)	
	5%	WB	42.0	40.2	43.2	50.7	59.6	62.8	66.5	65.2	60.8	55.2	49.5	45.1	(31)	
		MCDB	42.6	41.1	45.4	58.0	68.3	70.0	74.5	71.4	65.1	57.8	50.3	45.6	(32)	
	10%	WB	40.2	38.8	41.7	48.6	56.9	60.6	64.8	63.7	59.4	53.8	48.0	43.6	(33)	
		MCDB	41.0	39.8	43.4	54.7	64.4	67.4	71.7	68.9	63.3	56.2	48.8	44.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	7.7	11.1	15.3	15.4	13.8	13.5	12.6	11.9	10.0	7.2	7.0	(35)	
		MCDBR	6.1	7.4	14.4	22.4	22.5	21.9	21.2	18.7	15.9	10.5	6.6	6.0	(36)	
	5% WB	MCWBR	6.3	6.2	9.7	13.0	12.1	11.7	10.5	9.9	9.5	8.0	6.2	6.2	(37)	
		MCWBR	6.1	6.8	11.9	19.3	20.3	17.5	17.8	15.3	13.1	9.8	6.4	6.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.307	0.332	0.352	0.388	0.385	0.376	0.400	0.400	0.367	0.353	0.331	0.298	(40)	
		taud	2.262	2.294	2.324	2.287	2.363	2.414	2.365	2.369	2.442	2.394	2.318	2.238	(41)	
	Ebn at Noon		182	227	254	262	271	275	265	256	248	218	171	151	(42)	
		Edh at Noon	16	24	30	36	36	34	35	33	27	22	16	13	(43)	
(44) All-Sky Solar Radiation	RadAvg		128	315	748	1247	1631	1720	1592	1276	895	426	160	88	(44)	
	RadStd		25	50	76	169	155	144	195	114	105	66	30	10	(45)	

Historical Trends

||
||
||