

FALSTERBO, Sweden

WMO: 026160

Lat: 55.3813N

Lon: 12.8158E

Elev: 16

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	20.6	23.5	13.0	10.7	23.0	16.5	12.7	25.9	38.1	39.0	35.3	36.9	11.7	30	0.727

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	76.3	66.4	73.6	65.5	71.2	64.2	68.2	73.5	66.7	71.7	65.3	70.0	10.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	96.8	71.0	64.7	91.6	69.6	63.3	87.1	68.3	32.5	73.7	31.3	71.9	30.2	70.1	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
34.2	30.7	27.8	16.7	79.5	4.6	3.4	13.4	82.0	10.7	84.0	8.1	85.9	4.7	88.4		
			15.4	69.7	4.2	2.3	12.4	71.3	9.9	72.7	7.5	74.0	4.5	75.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	34.7	34.3	37.5	44.5	52.8	59.7	64.7	64.9	58.7	50.9	43.5	37.8
	DBStd	11.98	5.69	5.22	4.77	4.46	4.65	3.87	4.18	3.96	3.91	4.89	5.07	5.88
	HDD50	2123	475	439	387	175	22	0	0	0	1	49	198	377
	HDD65	6034	940	859	852	616	378	165	58	52	190	438	644	842
	CDD50	1668	0	0	0	9	110	290	455	461	263	76	4	0
	CDD65	104	0	0	0	0	1	5	48	48	2	0	0	0
	CDH74	195	0	0	0	0	1	6	111	77	0	0	0	0
	CDH80	9	0	0	0	0	0	0	6	3	0	0	0	0
	WSAvg	14.7	16.7	15.4	14.5	12.9	12.7	13.2	12.5	13.4	14.9	15.8	16.4	17.3
	PrecAvg	19.8	1.4	1.0	1.2	1.3	1.5	1.8	1.9	2.1	2.0	1.9	1.8	1.7
(15) Precipitation	PrecMax	33.0	2.8	2.0	2.9	3.5	3.6	4.8	4.3	7.0	6.4	5.4	3.7	4.2
	PrecMin	13.3	0.0	0.3	0.1	0.2	0.2	0.0	0.3	0.2	0.3	0.2	0.7	0.2
	PrecStd	3.5	0.7	0.5	0.7	0.7	0.8	1.0	1.1	1.5	1.3	1.2	0.7	0.9
	PrecStd	3.5	0.7	0.5	0.7	0.7	0.8	1.0	1.1	1.5	1.3	1.2	0.7	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	46.6	44.6	49.5	60.5	70.7	74.3	80.3	79.0	71.5	61.7	55.2	49.2	49.2
	0.4% MCWB	44.7	42.2	45.2	52.4	60.8	64.7	67.9	66.4	64.8	58.4	53.6	47.5	47.5
	2% DB	44.6	43.2	46.4	56.1	65.6	70.7	77.0	76.1	68.3	59.5	52.9	47.6	47.6
	2% MCWB	42.9	41.3	43.1	50.0	57.7	62.5	67.2	65.9	62.3	56.7	51.1	46.1	46.1
	5% DB	43.0	42.0	44.6	53.4	62.4	68.2	74.3	73.6	66.1	58.1	51.2	46.4	46.4
	5% MCWB	41.5	40.5	41.9	48.4	55.9	61.1	65.9	65.6	60.8	55.5	49.3	45.0	45.0
	10% DB	41.7	40.9	43.1	50.9	59.8	66.1	71.8	71.2	64.2	56.9	49.7	44.9	44.9
	10% MCWB	40.4	39.5	40.9	46.8	54.3	60.0	64.6	64.5	59.6	54.4	48.0	43.6	43.6
	0.4% WB	45.3	43.1	45.7	53.6	62.0	66.7	70.5	69.9	66.3	59.2	54.0	48.4	48.4
	0.4% MCDB	46.2	43.8	48.3	58.7	69.0	72.0	76.6	74.9	70.1	60.9	54.8	48.9	48.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	43.2	41.9	43.8	51.0	58.9	64.0	68.7	68.2	63.6	57.5	51.4	46.6	46.6
	2% MCDB	44.1	42.7	45.7	54.9	64.0	68.6	74.5	72.9	66.9	59.0	52.4	47.3	47.3
	5% WB	41.9	40.8	42.5	49.0	56.8	62.3	67.2	66.7	61.9	56.3	49.7	45.1	45.1
	5% MCDB	42.8	41.7	44.1	52.5	60.8	66.8	72.6	71.3	65.0	57.7	50.9	46.1	46.1
	10% WB	40.5	39.6	41.3	47.2	55.2	60.7	65.6	65.4	60.5	54.9	48.3	43.8	43.8
	10% MCDB	41.5	40.7	42.7	50.3	59.0	65.1	70.7	69.9	63.3	56.5	49.4	44.9	44.9
(35) Mean Daily Temperature Range	MDBR	4.7	4.6	6.4	8.4	9.7	9.5	9.9	9.1	7.7	5.7	4.5	4.5	4.5
	5% DB	4.4	4.7	7.9	11.5	13.1	12.6	13.9	12.0	9.6	6.0	4.2	4.0	4.0
	5% WB	4.4	4.0	5.9	7.6	8.0	7.5	7.1	6.2	6.1	5.0	4.3	4.3	4.3
	MCDBR	4.2	4.5	7.4	10.4	11.4	11.3	12.2	10.5	8.7	5.7	4.1	4.0	4.0
	MCWBR	4.4	4.1	5.9	7.2	7.7	7.4	7.1	6.5	6.1	5.1	4.4	4.4	4.4
	MCWBR	4.4	4.1	5.9	7.2	7.7	7.4	7.1	6.5	6.1	5.1	4.4	4.4	4.4
(40) Clear-Sky Solar Irradiance	taub	0.318	0.340	0.363	0.393	0.389	0.383	0.405	0.405	0.374	0.360	0.340	0.309	0.309
	taud	2.298	2.313	2.296	2.284	2.356	2.396	2.355	2.362	2.429	2.402	2.338	2.272	2.272
	Ebn at Noon	189	230	253	262	271	273	264	256	249	221	179	163	163
	Edh at Noon	17	25	31	36	36	35	36	34	28	23	17	15	15
(44) All-Sky Solar Radiation	RadAvg	145	338	772	1333	1712	1826	1695	1365	968	478	185	97	97
	RadStd	26	55	84	159	173	139	205	98	92	69	31	10	10

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) -281	(l) N/A	(m) N/A
Regional (62 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-302	+112	N/A

Nomenclature: See separate page