

FALSTERBO, Sweden

WMO: 026160

Lat: 55.3813N

Lon: 12.8158E

Elev: 5

StdP: 101.26

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.3	-4.7	-10.6	1.5	-5.0	-8.6	1.8	-3.4	17.0	3.9	15.8	2.7	5.2	30	0.727

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.1	24.6	19.1	23.1	18.6	21.8	17.9	20.1	23.0	19.3	22.1	18.5	21.1	4.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	13.8	21.7	18.2	13.1	20.9	17.4	12.4	20.2	57.8	23.2	55.0	22.1	52.4	21.2	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	13.7	12.4	-8.5	26.4	2.6	1.9	-10.3	27.8	-11.8	28.9	-13.3	29.9	-15.2	31.3		
(5)			-9.2	20.9	2.3	1.3	-10.9	21.9	-12.3	22.6	-13.6	23.3	-15.3	24.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	1.5	1.3	3.1	6.9	11.6	15.4	18.2	18.3	14.9	10.5	6.4	3.2		
	DBStd	6.65	3.16	2.90	2.65	2.48	2.58	2.15	2.32	2.20	2.17	2.72	2.82	3.27		
	HDD10.0	1179	264	244	215	97	12	0	0	0	1	27	110	209		
	HDD18.3	3352	522	477	473	342	210	92	32	29	106	243	358	468		
	CDD10.0	927	0	0	0	5	61	161	253	256	146	42	2	0		
	CDD18.3	58	0	0	0	0	1	3	27	27	1	0	0	0		
	CDH23.3	108	0	0	0	0	1	3	62	43	0	0	0	0		
	CDH26.7	5	0	0	0	0	0	0	3	2	0	0	0	0		
(14) Wind	WSAvg	6.6	7.4	6.9	6.5	5.8	5.7	5.9	5.6	6.0	6.7	7.1	7.4	7.7		
(15) Precipitation	PrecAvg	502	36	25	31	34	39	45	49	54	52	47	46	43		
	PrecMax	838	70	50	74	88	91	123	109	177	162	138	93	106		
	PrecMin	337	1	7	3	4	6	0	7	6	7	4	17	5		
	PrecStd	90	18	12	18	19	21	26	29	37	33	30	19	22		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	7.0	9.7	15.8	21.5	23.5	26.8	26.1	22.0	16.5	12.9	9.5		
		MCWB	7.1	5.7	7.3	11.3	16.0	18.2	20.0	19.1	18.2	14.7	12.0	8.6		
	2%	DB	7.0	6.2	8.0	13.4	18.7	21.5	25.0	24.5	20.1	15.3	11.6	8.7		
		MCWB	6.0	5.2	6.2	10.0	14.3	17.0	19.6	18.9	16.8	13.7	10.6	7.8		
	5%	DB	6.1	5.6	7.0	11.9	16.9	20.1	23.5	23.1	18.9	14.5	10.6	8.0		
		MCWB	5.3	4.7	5.5	9.1	13.3	16.2	18.9	18.7	16.0	13.1	9.6	7.2		
	10%	DB	5.4	4.9	6.1	10.5	15.4	18.9	22.1	21.8	17.9	13.8	9.9	7.2		
		MCWB	4.6	4.2	5.0	8.2	12.4	15.6	18.1	18.1	15.3	12.5	8.9	6.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	6.2	7.6	12.0	16.7	19.3	21.4	21.0	19.0	15.1	12.2	9.1		
		MCDB	7.9	6.6	9.0	14.8	20.6	22.2	24.8	23.8	21.2	16.0	12.6	9.4		
	2%	WB	6.2	5.5	6.6	10.5	15.0	17.8	20.4	20.1	17.6	14.2	10.8	8.1		
		MCDB	6.7	6.0	7.6	12.7	17.8	20.3	23.6	22.7	19.4	15.0	11.3	8.5		
	5%	WB	5.5	4.9	5.8	9.5	13.8	16.8	19.5	19.3	16.6	13.5	9.8	7.3		
		MCDB	6.0	5.4	6.7	11.4	16.0	19.4	22.5	21.8	18.3	14.3	10.5	7.8		
	10%	WB	4.7	4.2	5.2	8.5	12.9	16.0	18.7	18.6	15.8	12.7	9.0	6.5		
		MCDB	5.3	4.8	6.0	10.2	15.0	18.4	21.5	21.0	17.4	13.6	9.7	7.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.6	2.6	3.5	4.7	5.4	5.3	5.5	5.1	4.3	3.2	2.5	2.5		
		MCDBR	2.4	2.6	4.4	6.4	7.3	7.0	7.7	6.7	5.3	3.4	2.3	2.2		
	5% WB	MCWBR	2.5	2.2	3.3	4.2	4.5	4.1	4.0	3.4	3.4	2.8	2.4	2.4		
		MCWBR	2.3	2.5	4.1	5.8	6.3	6.3	6.8	5.8	4.9	3.2	2.3	2.2		
(40) Clear-Sky Solar Irradiance	taub		0.318	0.340	0.363	0.393	0.389	0.383	0.405	0.405	0.374	0.360	0.340	0.309		
		taud	2.298	2.313	2.296	2.284	2.356	2.396	2.355	2.362	2.429	2.402	2.338	2.272		
	Ebn at Noon		597	726	799	827	854	862	833	807	785	697	564	513		
		Edh at Noon	55	78	99	115	113	110	113	106	87	71	54	46		
(44) All-Sky Solar Radiation	RadAvg		0.46	1.06	2.43	4.20	5.40	5.76	5.34	4.30	3.05	1.51	0.58	0.31		
	RadStd		0.08	0.17	0.27	0.50	0.54	0.44	0.65	0.31	0.29	0.22	0.10	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-156	N/A	N/A
(47)	Regional (62 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-168	+62	N/A

Nomenclature: See separate page