

SKILLINGE, Sweden

WMO: 026250

Lat: 55.4890N

Lon: 14.3144E

Elev: 13

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.3	22.1	12.1	10.2	20.2	16.1	12.4	24.0	38.4	33.8	33.5	35.2	7.1	310	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	74.7	66.0	72.3	65.3	70.1	64.0	68.2	72.4	66.6	70.4	65.2	68.9	9.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	97.4	70.6	65.0	92.5	69.1	63.6	87.9	67.8	32.4	72.4	31.2	70.6	30.1	69.1	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
30.3	26.7	23.3		DB	12.3	80.6	5.6	4.2	8.3	83.6	5.0	86.0	1.8	88.3	-2.3	91.4
				WB	11.5	70.1	5.5	2.5	7.5	71.9	4.3	73.4	1.2	74.8	-2.9	76.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.3	33.9	34.2	36.9	42.7	50.6	57.6	62.5	62.5	57.1	49.4	42.5	37.1
	DBStd	11.50	6.07	5.59	5.53	4.38	4.65	4.17	4.27	4.09	4.13	5.07	5.43	6.27
	HDD50	2322	498	443	406	223	49	1	0	0	2	72	229	399
	HDD65	6505	963	863	871	670	448	225	104	99	238	485	675	864
	CDD50	1342	0	0	0	3	66	229	386	388	215	52	3	0
	CDD65	52	0	0	0	0	0	3	25	22	2	0	0	0
	CDH74	117	0	0	0	0	1	13	70	32	1	0	0	0
	CDH80	10	0	0	0	0	0	2	5	3	0	0	0	0
Wind	WSAvg	10.5	12.3	12.3	11.7	10.3	9.6	8.4	7.7	8.6	9.7	11.2	12.0	12.1
Precipitation	PrecAvg	23.9	2.0	1.5	1.4	1.2	1.7	1.8	2.4	2.4	2.0	2.4	2.6	2.2
	PrecMax	28.9	4.2	3.4	2.3	2.2	4.4	3.2	6.8	8.8	5.2	5.1	6.3	5.0
	PrecMin	15.9	0.2	0.4	0.4	0.2	0.4	0.8	0.6	0.5	0.7	0.5	0.6	1.1
	PrecStd	3.6	1.1	0.6	0.6	0.6	0.9	0.7	1.5	2.0	0.8	1.3	1.3	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.6	48.2	53.9	59.2	69.5	74.8	80.1	78.0	71.8	60.9	55.4	49.9
		MCWB	45.7	46.1	47.9	51.3	58.3	63.8	65.9	67.0	65.9	57.3	53.5	48.4
	2%	DB	45.0	45.2	49.2	54.8	63.8	70.6	75.6	73.7	68.1	58.7	53.2	48.1
		MCWB	43.2	43.2	44.5	49.4	56.4	61.8	66.7	66.0	62.6	56.0	51.6	46.7
	5%	DB	43.3	43.1	46.2	51.8	60.8	67.7	73.0	71.6	65.7	57.5	51.2	46.6
		MCWB	41.8	41.4	43.1	47.5	55.1	60.0	66.1	65.3	60.7	55.0	49.4	45.2
	10%	DB	41.8	41.4	44.0	49.3	58.4	65.5	70.7	69.6	63.9	56.2	49.7	45.0
		MCWB	40.4	39.8	41.5	45.5	53.4	59.3	64.8	64.0	59.7	53.9	48.0	43.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.9	46.7	48.7	52.8	60.6	66.0	71.1	69.8	66.9	58.5	54.3	48.8
		MCDB	47.0	47.8	52.9	57.3	66.3	73.0	75.1	74.1	70.2	59.6	55.1	49.5
	2%	WB	43.7	43.7	45.6	50.1	57.8	63.5	68.8	67.8	63.6	56.8	51.9	46.9
		MCDB	44.6	44.8	48.3	53.7	61.9	68.6	73.0	71.9	66.9	58.3	53.0	47.8
	5%	WB	42.0	41.7	43.5	48.0	55.9	61.7	67.1	66.5	61.8	55.5	49.8	45.3
		MCDB	43.1	42.9	45.7	51.2	59.9	66.1	71.2	69.9	64.7	57.0	51.0	46.4
	10%	WB	40.5	40.0	41.7	46.0	54.1	60.2	65.6	65.3	60.4	54.2	48.2	43.7
		MCDB	41.6	41.3	43.6	48.9	58.0	64.3	69.7	68.4	63.2	55.9	49.5	44.9
Mean Daily Temperature Range	5% DB	MDBR	6.2	6.4	8.5	9.2	11.4	12.7	12.6	11.2	9.8	7.7	6.5	6.4
		MCDBR	6.2	7.9	12.5	13.9	15.2	17.1	16.3	13.6	12.3	8.7	6.6	6.5
		MCWBR	6.1	6.7	9.5	9.6	9.7	10.1	9.5	8.1	8.2	7.0	6.1	6.5
	5% WB	MCDBR	6.1	7.7	11.8	12.5	13.7	14.7	12.8	10.9	10.0	7.5	6.3	6.5
		MCWBR	6.1	6.7	9.5	9.4	9.6	9.6	8.7	7.6	7.4	6.6	6.1	6.5
Clear-Sky Solar Irradiance	taub	0.316	0.339	0.361	0.395	0.392	0.385	0.407	0.409	0.376	0.361	0.341	0.309	
	taud	2.300	2.320	2.312	2.290	2.356	2.404	2.360	2.361	2.429	2.398	2.333	2.282	
	Ebn at Noon	190	231	254	262	270	273	263	255	248	220	177	162	
	Edh at Noon	17	24	31	36	36	35	36	34	28	23	17	14	
All-Sky Solar Radiation	RadAvg	133	329	780	1372	1796	1930	1762	1416	996	473	182	93	
	RadStd	26	59	76	137	170	120	193	104	96	77	33	11	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (54 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-277	+106	N/A

Nomenclature: See separate page