

OSBY, Sweden

WMO: 026260

Lat: 56.374N

Lon: 13.938E

Elev: 90

StdP: 100.25

Time Zone: 1.00 (EUC)

Period: 82-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.5	-13.2	-19.3	0.7	-16.2	-16.0	0.9	-12.2	12.4	5.6	12.0	5.5	1.0	0	0.597

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	26.6	17.9	24.6	16.6	22.8	15.9	18.7	24.5	17.5	22.8	16.6	21.3	2.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.6	12.0	20.6	15.5	11.1	19.2	14.5	10.4	18.1	53.2	24.6	49.6	22.8	46.8	21.3	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.6	10.0	7.4	DB	-15.7	30.1	5.3	2.2	-19.5	31.7	-22.6	33.0	-25.6	34.3	-29.5	35.9	(4)
(5)			WB	-16.8	20.7	5.6	1.3	-20.8	21.6	-24.1	22.4	-27.2	23.1	-31.2	24.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.8	-1.7	-1.7	1.4	5.4	10.8	13.9	16.1	15.9	11.1	7.5	2.4	-0.2	(6)
(7)		DBStd	7.47	5.98	5.10	3.45	3.41	3.45	3.16	2.72	2.56	2.45	3.47	3.76	4.12	(7)
(8)		HDD10.0	1786	363	328	267	144	31	4	0	0	15	90	227	316	(8)
(9)		HDD18.3	4236	622	561	526	388	233	137	81	82	218	336	477	574	(9)
(10)		CDD10.0	616	0	0	0	6	56	121	189	184	47	12	0	0	(10)
(11)		CDD18.3	24	0	0	0	0	1	4	12	8	0	0	0	0	(11)
(12)		CDH23.3	329	0	0	0	2	14	66	145	100	2	0	0	0	(12)
(13)		CDH26.7	62	0	0	0	0	1	9	33	19	0	0	0	0	(13)
(14)	Wind	WSAvg	2.5	3.2	2.7	2.6	2.4	2.4	2.3	2.3	2.1	2.4	2.5	2.2	2.6	(14)
(15)	Precipitation	PrecAvg	800	66	57	45	42	59	69	93	79	70	77	76	66	(15)
(16)		PrecMax	1030	150	144	117	81	117	153	236	162	178	159	135	159	(16)
(17)		PrecMin	604	0	6	10	11	15	0	13	18	15	29	33	24	(17)
(18)		PrecStd	109	37	31	25	22	27	35	53	38	37	31	28	30	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.6	10.5	12.7	22.8	25.2	27.8	30.0	28.7	21.2	17.8	10.6	8.8	(19)
(20)			MCWB	7.5	8.6	8.2	14.0	16.5	18.0	20.1	18.6	15.5	14.3	9.1	7.6	(20)
(21)		2%	DB	7.1	7.8	9.3	17.7	23.1	25.1	27.0	25.7	18.0	14.8	9.5	7.4	(21)
(22)			MCWB	6.2	6.1	6.3	10.9	15.1	16.5	19.1	17.2	13.5	12.6	8.3	6.4	(22)
(23)		5%	DB	6.2	5.6	7.5	14.5	20.9	23.0	24.5	23.7	16.3	13.3	8.4	6.2	(23)
(24)			MCWB	5.2	4.5	5.4	9.3	13.7	15.7	17.0	16.6	12.7	11.3	7.4	5.2	(24)
(25)		10%	DB	5.2	4.4	6.2	11.8	18.5	20.7	22.4	21.5	15.2	12.2	7.5	5.1	(25)
(26)			MCWB	4.1	3.4	4.6	7.5	12.1	14.4	16.1	15.9	12.1	10.6	6.5	4.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	8.8	9.0	13.9	17.1	18.6	21.2	19.5	16.8	15.0	9.6	7.8	(27)
(28)			MCD B	8.2	10.0	11.2	22.2	24.3	25.4	27.8	24.9	20.4	17.4	10.2	8.4	(28)
(29)		2%	WB	6.4	6.1	6.9	11.4	15.4	17.3	19.6	18.2	14.8	13.0	8.5	6.5	(29)
(30)			MCD B	7.0	7.4	8.3	16.6	22.2	23.0	25.5	23.7	16.8	14.4	9.2	7.3	(30)
(31)		5%	WB	5.3	4.7	5.8	9.6	14.1	16.3	17.8	17.3	13.5	11.8	7.6	5.4	(31)
(32)			MCD B	6.0	5.5	7.1	14.1	19.9	21.7	23.0	22.2	15.3	12.9	8.3	6.1	(32)
(33)		10%	WB	4.2	3.6	4.7	8.0	12.6	15.1	16.6	16.4	12.6	10.8	6.6	4.3	(33)
(34)			MCD B	5.0	4.3	6.1	10.9	17.3	20.0	21.2	20.7	14.4	12.1	7.3	5.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.6	5.4	6.3	9.4	10.9	9.7	9.6	9.6	7.4	6.5	4.9	4.5	(35)
(36)			MCD BR	3.7	5.1	9.1	14.6	16.1	14.6	15.1	14.0	9.8	8.1	5.0	4.5	(36)
(37)			MCWBR	3.7	4.3	6.3	8.5	8.8	6.9	7.1	6.3	5.9	5.6	4.6	4.4	(37)
(38)		5% WB	MCD BR	3.8	4.9	7.7	13.2	15.1	13.3	13.9	12.1	7.9	6.5	4.7	4.4	(38)
(39)			MCWBR	3.9	4.5	5.8	8.0	8.6	6.6	7.1	6.2	5.6	5.1	4.6	4.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.301	0.327	0.348	0.383	0.381	0.373	0.395	0.396	0.363	0.351	0.329	0.293	(40)	
(41)		taud	2.269	2.303	2.330	2.303	2.362	2.408	2.363	2.367	2.443	2.405	2.335	2.250	(41)	
(42)		Ebn at Noon	590	727	811	832	858	870	839	812	790	695	553	496	(42)	
(43)		Edh at Noon	53	76	94	112	112	108	111	104	84	68	50	42	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.42	1.01	2.40	4.01	5.25	5.53	5.10	4.12	2.88	1.38	0.52	0.29	(44)	
(45)		RadStd	0.08	0.17	0.24	0.52	0.52	0.43	0.62	0.36	0.34	0.22	0.10	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (60 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-155	N/A	N/A

Nomenclature: See separate page