

MALMO AP, Sweden

WMO: 026360

Lat: 55.523N

Lon: 13.379E

Elev: 236

StdP: 14.57

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.3	17.7	8.6	8.6	15.3	13.6	11.1	20.3	31.4	39.6	28.8	40.1	5.0	350	0.661

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	79.0	64.9	76.0	64.2	73.2	63.0	67.6	74.7	65.7	72.5	64.3	70.9	10.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	92.7	70.4	63.1	87.2	68.6	61.6	82.7	67.1	32.1	74.9	30.7	72.5	29.5	70.9	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.7	23.0	20.7	DB	4.7	83.5	8.0	3.4	-1.1	85.9	-5.7	87.9	-10.2	89.7	-16.0	92.2	(4)
(5)			WB	4.1	71.0	7.8	1.7	-1.6	72.2	-6.1	73.2	-10.5	74.1	-16.2	75.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.6	32.2	32.6	36.2	44.2	51.6	57.6	62.5	62.1	55.7	48.1	40.6	35.0		
	DBStd	12.39	7.23	6.77	6.38	6.26	5.86	4.80	4.59	4.65	4.83	5.72	6.25	7.57		
	HDD50	2572	550	487	428	194	48	2	0	0	10	103	285	465		
	HDD65	6770	1015	907	893	625	415	227	107	114	279	525	733	930		
	CDD50	1340	0	0	0	20	99	231	387	376	182	43	2	0		
	CDD65	62	0	0	0	0	1	6	29	25	1	0	0	0		
	CDH74	496	0	0	0	1	7	64	263	159	2	0	0	0		
	CDH80	53	0	0	0	0	0	7	35	11	0	0	0	0		
(14) Wind	WSAvg	10.3	11.5	11.6	11.3	10.5	10.0	9.8	8.8	8.9	9.5	10.1	10.5	11.0		
(15) Precipitation	PrecAvg	27.8	2.1	1.7	1.6	1.6	2.0	2.4	2.7	3.1	2.6	2.5	2.8	2.6		
	PrecMax	35.4	4.6	4.1	3.3	2.8	4.6	5.1	8.2	9.1	6.1	5.3	5.4	5.0		
	PrecMin	21.3	0.0	0.3	0.4	0.4	0.6	0.0	0.0	0.7	0.8	1.2	0.6	1.2		
	PrecStd	3.7	1.2	0.7	0.8	0.7	0.9	1.2	2.0	2.1	1.5	1.1	1.1	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.8	48.1	55.5	69.5	74.7	80.0	84.0	81.3	73.4	62.9	54.8	50.0		
		MCWB	46.6	45.7	47.8	57.2	61.8	64.7	67.1	66.0	63.3	58.0	53.3	49.2		
	2%	DB	44.8	45.3	51.2	62.9	70.4	75.2	80.1	78.5	69.6	59.4	52.2	48.1		
		MCWB	43.7	43.9	45.4	51.9	59.0	63.4	65.9	64.8	61.5	56.2	50.5	47.0		
	5%	DB	43.0	43.5	47.7	58.9	66.9	71.3	76.9	75.2	66.4	57.6	50.3	46.3		
		MCWB	42.0	42.1	44.0	50.0	56.8	61.2	64.6	64.5	59.5	55.0	48.9	45.3		
	10%	DB	41.3	41.4	44.9	55.2	63.0	68.0	73.6	71.8	64.0	55.7	48.5	44.4		
		MCWB	40.3	40.1	42.3	48.4	54.8	59.3	63.4	63.0	58.3	53.4	47.4	43.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	46.4	49.4	58.1	63.8	68.3	70.1	69.7	65.0	59.3	53.8	49.5		
		MCDB	47.1	47.0	54.0	67.6	72.0	76.3	79.3	76.7	71.2	61.2	54.5	49.8		
	2%	WB	43.9	44.2	46.2	53.6	60.8	64.5	68.0	67.4	62.2	57.2	51.3	47.1		
		MCDB	44.4	45.1	49.2	60.9	67.8	72.3	75.9	73.4	67.1	59.1	52.2	47.6		
	5%	WB	42.0	42.3	44.4	51.2	58.4	62.2	66.3	65.6	60.6	55.6	49.2	45.0		
		MCDB	42.6	43.2	46.6	57.1	64.7	68.9	73.8	71.5	64.6	57.5	50.0	45.7		
	10%	WB	40.2	40.2	42.5	49.0	55.8	60.3	64.6	64.2	59.3	54.2	47.4	43.2		
		MCDB	41.0	41.3	44.7	54.1	61.7	66.4	71.5	70.3	62.9	56.0	48.2	43.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	7.9	11.1	15.3	16.7	16.1	16.6	15.8	13.5	10.4	7.8	7.5		
		MCDBR	6.8	8.4	15.1	20.8	22.1	22.1	23.5	20.8	16.7	11.3	7.2	7.2		
	5% WB	MCWBR	6.8	7.3	10.9	12.8	13.0	12.3	11.6	10.5	10.0	8.7	6.9	7.5		
		MCWBR	6.6	8.1	13.5	18.4	19.2	19.3	19.5	17.5	14.7	10.4	7.0	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.313	0.336	0.358	0.392	0.388	0.382	0.403	0.405	0.373	0.357	0.337	0.304		
		taud	2.292	2.313	2.306	2.278	2.346	2.387	2.348	2.351	2.420	2.401	2.336	2.264		
	Ebn at Noon		190	231	255	262	271	274	265	256	249	222	179	163		
		Edh at Noon	17	24	31	37	36	35	36	34	28	23	17	14		
(44) All-Sky Solar Radiation	RadAvg		143	336	774	1333	1714	1826	1695	1364	967	475	183	96		
	RadStd		27	53	87	161	171	140	206	99	93	69	32	9		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.81	N/A	N/A	N/A	N/A	N/A	N/A	-317	N/A	N/A
(47) Regional (60 neighbors)		+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-302	+112	N/A

Nomenclature: See separate page