

VAXJO AP, Sweden

WMO: 026410

Lat: 56.929N

Lon: 14.728E

Elev: 610

StdP: 14.37

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.5	12.1	3.0	6.6	8.6	8.3	8.6	16.3	23.9	38.6	21.1	37.6	3.6	0	0.604

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	80.7	63.6	77.4	62.4	74.9	61.5	67.0	75.2	65.0	73.1	63.3	71.3	8.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.3	92.3	70.1	62.4	86.3	68.0	60.6	80.7	66.1	31.8	74.6	30.4	72.2	29.1	70.5	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.2	17.2	15.5	DB	-0.4	85.6	6.5	3.0	-5.1	87.7	-8.9	89.5	-12.6	91.2	-17.3	93.4	(4)
			WB	-0.8	69.5	6.5	1.7	-5.5	70.7	-9.3	71.7	-12.9	72.7	-17.6	73.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.1	29.0	30.3	34.5	43.4	51.5	57.9	62.2	60.8	54.0	45.4	38.4	33.0
	DBStd	13.32	8.32	7.50	7.50	6.51	6.88	5.38	5.12	4.72	5.10	6.49	6.41	8.01
	HDD50	3029	651	551	482	215	63	4	0	1	20	168	348	526
	HDD65	7313	1116	971	946	649	419	221	120	146	330	607	797	991
	CDD50	1250	0	0	1	16	111	242	378	334	141	26	1	0
	CDD65	60	0	0	0	0	2	9	33	15	1	0	0	0
	CDH74	784	0	0	0	4	56	180	400	139	5	0	0	0
	CDH80	119	0	0	0	0	2	25	74	18	0	0	0	0
Wind	WSAvg	7.5	8.1	8.1	7.8	7.4	7.3	7.3	6.8	6.6	7.3	7.5	7.8	8.1
Precipitation	PrecAvg	26.6	2.0	1.5	1.6	1.6	1.9	2.4	3.0	2.5	2.9	2.4	2.5	2.3
	PrecMax	33.5	4.5	4.1	3.1	3.1	5.2	5.8	5.9	5.7	8.0	4.9	5.2	5.1
	PrecMin	18.8	0.2	0.2	0.1	0.2	0.5	0.0	0.1	0.5	0.7	0.6	0.7	0.6
	PrecStd	3.5	1.0	0.8	0.8	0.7	0.9	1.3	1.5	1.2	1.5	1.2	1.0	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.7	48.0	59.1	73.0	78.9	82.8	85.9	82.3	73.7	63.0	53.5	49.9
		MCWB	46.0	43.7	47.5	56.5	60.9	63.4	65.4	66.2	61.6	55.7	50.8	49.4
	2%	DB	43.9	44.5	53.8	66.2	75.2	79.0	82.1	77.4	69.8	58.9	50.4	46.8
		MCWB	43.0	42.7	44.6	51.5	58.9	61.9	64.3	64.2	60.1	55.2	48.9	46.0
	5%	DB	41.3	42.5	48.4	61.1	71.3	75.2	78.8	74.8	66.2	56.9	48.5	44.7
		MCWB	40.3	41.0	42.3	48.6	56.1	60.1	63.0	63.2	58.3	53.8	47.5	43.9
	10%	DB	39.4	40.6	44.7	56.9	66.2	71.3	75.1	71.5	62.8	54.0	46.7	42.8
		MCWB	38.6	39.2	40.9	46.3	54.3	58.3	62.6	61.8	56.6	51.4	46.1	42.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.7	44.9	49.5	57.2	63.2	67.0	69.0	69.1	64.1	57.9	51.8	48.9
		MCDB	46.1	45.6	56.0	69.7	74.8	76.0	77.4	77.3	70.7	61.3	53.0	49.1
	2%	WB	42.6	42.8	45.8	52.7	61.0	63.9	67.2	66.9	61.1	56.1	49.4	46.0
		MCDB	43.1	43.8	51.0	63.5	70.8	74.9	76.1	74.0	67.2	58.7	50.2	46.5
	5%	WB	40.3	40.6	43.3	49.9	58.2	61.6	65.4	64.6	59.3	54.1	47.4	43.7
		MCDB	40.8	41.4	47.3	57.3	66.9	71.5	74.2	71.3	64.5	56.4	48.0	44.2
	10%	WB	38.4	38.6	41.0	47.6	55.5	59.6	63.6	62.9	57.7	52.5	45.9	41.7
		MCDB	39.1	39.7	43.5	55.2	64.1	68.6	72.0	69.4	62.1	54.6	46.5	42.2
Mean Daily Temperature Range	5% DB	MDBR	8.4	9.8	14.5	19.8	20.3	19.8	18.4	17.5	15.6	11.6	7.6	7.6
		MCDBR	7.6	11.2	21.2	29.2	29.5	28.0	26.4	23.3	20.9	12.9	8.1	8.5
		MCWBR	7.6	9.0	13.5	16.4	14.9	13.4	11.4	11.6	12.2	9.4	7.5	8.7
	5% WB	MCDBR	7.5	8.8	18.4	24.4	23.5	23.2	21.2	19.3	18.2	11.7	7.6	8.3
		MCWBR	7.6	7.8	12.7	14.7	13.2	12.4	10.8	10.8	11.5	9.4	7.4	8.5
Clear-Sky Solar Irradiance	taub	0.290	0.321	0.339	0.375	0.373	0.363	0.386	0.384	0.353	0.342	0.318	0.281	
	taud	2.284	2.326	2.360	2.333	2.394	2.443	2.393	2.401	2.474	2.428	2.344	2.244	
	Ebn at Noon	188	232	259	266	274	279	269	261	253	222	176	156	
	Edh at Noon	16	23	29	34	34	33	34	32	26	21	15	12	
All-Sky Solar Radiation	RadAvg	126	319	781	1263	1648	1755	1598	1295	892	418	158	89	
	RadStd	23	59	82	169	166	109	201	126	115	75	30	8	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (58 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-290	N/A	N/A	

Nomenclature: See separate page