

VAXJO AP, Sweden

WMO: 026410

Lat: 56.929N

Lon: 14.728E

Elev: 186

StdP: 99.11

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.1	-11.1	-16.1	0.9	-13.0	-13.2	1.2	-8.7	10.7	3.7	9.5	3.1	1.6	0	0.604

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	27.1	17.6	25.2	16.9	23.8	16.4	19.4	24.0	18.3	22.9	17.4	21.9	3.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	13.2	21.1	16.9	12.3	20.0	15.9	11.5	19.0	56.1	23.7	52.7	22.3	49.8	21.4	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	7.7	6.9	DB	-18.0	29.8	3.6	1.7	-20.6	31.0	-22.7	32.0	-24.8	32.9	-27.4	34.1	(4)
(5)			WB	-18.2	20.8	3.6	0.9	-20.8	21.5	-22.9	22.1	-25.0	22.6	-27.6	23.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.3	-1.7	-0.9	1.4	6.3	10.9	14.4	16.8	16.0	12.2	7.4	3.6	0.6	(6)	
	DBStd	7.40	4.62	4.17	4.16	3.62	3.82	2.99	2.85	2.62	2.83	3.61	3.56	4.45	(7)	
	HDD10.0	1683	362	306	268	119	35	2	0	1	11	93	193	292	(8)	
	HDD18.3	4063	620	539	526	361	233	123	67	81	183	337	443	551	(9)	
	CDD10.0	694	0	0	1	9	62	134	210	186	78	14	1	0	(10)	
	CDD18.3	33	0	0	0	0	1	5	18	8	1	0	0	0	(11)	
	CDH23.3	436	0	0	0	2	31	100	222	77	3	0	0	0	(12)	
	CDH26.7	66	0	0	0	0	1	14	41	10	0	0	0	0	(13)	
(14) Wind	WSAvg	3.4	3.6	3.6	3.5	3.3	3.3	3.3	3.0	3.0	3.2	3.4	3.5	3.6	(14)	
(15) Precipitation	PrecAvg	675	52	37	41	40	49	61	75	63	74	60	64	59	(15)	
	PrecMax	851	115	103	79	79	131	147	149	146	204	124	132	129	(16)	
	PrecMin	478	5	6	2	4	12	0	3	12	19	14	19	15	(17)	
	PrecStd	88	26	21	21	19	24	33	38	30	38	30	26	29	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	8.9	15.1	22.8	26.1	28.2	30.0	27.9	23.2	17.2	11.9	9.9	(19)	
		MCWB	7.8	6.5	8.6	13.6	16.1	17.4	18.6	19.0	16.5	13.2	10.5	9.6	(20)	
	2%	DB	6.6	6.9	12.1	19.0	24.0	26.1	27.8	25.2	21.0	14.9	10.2	8.2	(21)	
		MCWB	6.1	5.9	7.0	10.8	14.9	16.6	18.0	17.9	15.6	12.9	9.4	7.8	(22)	
	5%	DB	5.2	5.8	9.1	16.2	21.8	24.0	26.0	23.8	19.0	13.8	9.2	7.1	(23)	
		MCWB	4.6	5.0	5.7	9.2	13.4	15.6	17.2	17.3	14.6	12.1	8.6	6.6	(24)	
	10%	DB	4.1	4.8	7.0	13.9	19.0	21.8	23.9	21.9	17.1	12.2	8.2	6.0	(25)	
		MCWB	3.6	4.0	4.9	7.9	12.4	14.6	17.0	16.5	13.7	10.8	7.8	5.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	7.2	9.7	14.0	17.3	19.4	20.6	20.6	17.9	14.4	11.0	9.4	(27)	
		MCDB	7.8	7.5	13.3	20.9	23.8	24.4	25.2	25.1	21.5	16.3	11.7	9.5	(28)	
	2%	WB	5.9	6.0	7.7	11.5	16.1	17.7	19.5	19.4	16.1	13.4	9.7	7.8	(29)	
		MCDB	6.2	6.6	10.6	17.5	21.6	23.8	24.5	23.3	19.6	14.8	10.1	8.1	(30)	
	5%	WB	4.6	4.8	6.3	10.0	14.5	16.4	18.6	18.1	15.2	12.3	8.6	6.5	(31)	
		MCDB	4.9	5.2	8.5	14.0	19.4	21.9	23.4	21.8	18.1	13.5	8.9	6.8	(32)	
	10%	WB	3.6	3.7	5.0	8.7	13.0	15.3	17.6	17.2	14.3	11.4	7.7	5.4	(33)	
		MCDB	3.9	4.3	6.4	12.9	17.9	20.3	22.2	20.8	16.7	12.5	8.1	5.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	5.4	8.0	11.0	11.3	11.0	10.2	9.7	8.7	6.4	4.2	4.2	(35)	
		MCDBR	4.2	6.2	11.8	16.2	16.4	15.6	14.7	12.9	11.6	7.2	4.5	4.7	(36)	
	5% WB	MCWBR	4.2	5.0	7.5	9.1	8.3	7.5	6.4	6.5	6.8	5.2	4.2	4.8	(37)	
		MCDWR	4.2	4.9	10.2	13.6	13.1	12.9	11.8	10.7	10.1	6.5	4.2	4.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.290	0.321	0.339	0.375	0.373	0.363	0.386	0.384	0.353	0.342	0.318	0.281	(40)	
		taud	2.284	2.326	2.360	2.333	2.394	2.443	2.393	2.401	2.474	2.428	2.344	2.244	(41)	
	Edn at Noon		594	731	818	839	865	879	847	823	799	699	554	493	(42)	
		Edh at Noon	50	72	90	108	108	104	108	100	81	66	48	39	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.40	1.01	2.46	3.98	5.19	5.53	5.04	4.08	2.81	1.32	0.50	0.28	(44)	
	RadStd		0.07	0.18	0.26	0.53	0.52	0.34	0.63	0.40	0.36	0.24	0.10	0.03	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (58 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-161	N/A	N/A	

Nomenclature: See separate page