

OLANDS SODRA UDDE, Sweden

WMO: 026440

Lat: 56.1977N

Lon: 16.4005E

Elev: 7

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	18.9	22.1	13.2	10.7	20.4	16.6	12.7	23.6	36.6	35.4	33.9	35.0	13.3	10	0.736

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.8	73.0	68.1	70.8	66.8	69.0	65.3	69.0	72.0	67.4	70.3	65.8	68.7	10.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.6	101.5	71.2	66.1	96.2	69.8	64.5	90.7	68.0	33.1	72.4	31.8	70.4	30.6	68.8	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.4	29.3	26.5	DB	15.6	74.1	5.7	4.0	11.5	76.9	8.1	79.3	4.9	81.5	0.7	84.4	(4)
(5)			WB	14.2	69.3	4.8	3.3	10.8	71.7	7.9	73.6	5.2	75.4	1.7	77.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.9	33.6	33.4	35.7	41.2	49.4	57.2	62.5	63.2	57.0	49.0	42.4	37.1	(6)	
	DBStd	11.64	5.70	5.30	4.57	3.74	4.34	3.62	4.16	3.97	4.27	4.88	5.03	6.06	(7)	
	HDD50	2457	510	465	443	264	64	1	0	0	2	76	231	401	(8)	
	HDD65	6667	975	885	908	714	485	234	101	82	242	496	679	866	(9)	
	CDD50	1317	0	0	0	1	45	217	387	409	211	45	2	0	(10)	
	CDD65	51	0	0	0	0	0	1	23	26	1	0	0	0	(11)	
	CDH74	39	0	0	0	0	0	0	23	16	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	13.9	16.1	15.5	14.0	12.7	12.3	11.7	11.3	12.1	13.4	15.0	15.7	16.8	(14)	
(15) Precipitation	PrecAvg	18.5	1.1	1.0	0.8	0.9	1.5	1.6	2.1	1.9	1.9	2.0	2.0	1.7	(15)	
	PrecMax	24.7	2.5	1.9	1.9	2.3	4.3	3.7	5.9	4.4	7.8	5.8	5.5	3.3	(16)	
	PrecMin	12.4	0.0	0.3	0.0	0.0	0.2	0.0	0.2	0.0	0.4	0.4	0.3	0.8	(17)	
	PrecStd	2.7	0.6	0.4	0.4	0.6	0.7	0.7	1.4	1.2	1.6	1.2	1.1	0.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.3	43.2	45.8	54.0	63.3	69.7	76.9	76.0	70.3	59.8	53.7	48.6	(19)	
		MCWB	44.0	41.1	41.9	48.9	57.4	63.9	70.0	69.3	65.8	57.8	52.1	47.1	(20)	
	2%	DB	43.6	41.6	43.6	50.6	59.9	66.6	73.5	73.0	66.7	57.9	51.7	47.0	(21)	
		MCWB	42.4	40.1	41.0	46.7	55.5	62.0	68.7	67.8	62.7	56.0	50.2	45.7	(22)	
	5%	DB	42.2	40.5	42.2	48.5	57.7	64.8	71.1	71.1	64.5	56.6	50.0	45.9	(23)	
		MCWB	41.0	39.2	40.3	45.4	54.2	60.9	67.2	66.9	61.3	54.8	48.5	44.6	(24)	
	10%	DB	40.8	39.6	41.1	46.5	55.9	63.0	69.3	69.2	62.9	55.3	48.5	44.4	(25)	
		MCWB	39.8	38.4	39.5	44.0	52.8	59.5	65.8	65.5	60.0	53.6	47.1	43.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.4	42.1	43.1	50.6	58.8	65.0	71.9	70.7	67.0	58.4	52.9	47.7	(27)	
		MCDB	44.7	42.7	44.6	53.2	61.8	67.7	75.3	74.2	69.8	59.3	53.5	48.0	(28)	
	2%	WB	42.8	40.5	41.8	47.5	56.3	62.8	69.5	68.9	63.8	56.5	50.5	46.1	(29)	
		MCDB	43.3	41.2	43.0	49.7	58.9	65.4	72.6	72.1	65.8	57.5	51.4	46.6	(30)	
	5%	WB	41.2	39.6	40.8	45.8	54.7	61.3	67.7	67.5	62.1	55.2	48.7	44.9	(31)	
		MCDB	41.8	40.3	41.9	48.1	57.3	63.9	70.6	70.5	63.9	56.3	49.7	45.8	(32)	
	10%	WB	40.0	38.7	39.8	44.3	53.1	59.9	66.2	66.1	60.7	53.9	47.4	43.3	(33)	
		MCDB	40.7	39.5	40.8	46.3	55.5	62.5	69.3	68.9	62.5	55.2	48.3	44.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	4.6	5.2	6.4	6.9	6.9	7.0	6.8	6.3	5.3	4.5	5.0	(35)	
		MCDBR	4.0	4.5	6.4	9.5	9.5	9.5	9.5	8.6	7.9	5.2	4.1	3.9	(36)	
	5% WB	MCWBR	4.4	4.0	5.1	6.8	6.9	7.2	6.5	6.4	6.1	4.7	4.4	4.3	(37)	
		MCWBR	3.7	4.2	5.9	8.7	8.7	8.4	8.8	8.1	6.9	4.9	4.1	4.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.311	0.338	0.355	0.388	0.385	0.376	0.403	0.400	0.371	0.358	0.340	0.304	(40)	
		taud	2.294	2.322	2.335	2.311	2.390	2.444	2.388	2.394	2.451	2.398	2.307	2.257	(41)	
	Ebn at Noon		186	228	255	263	272	275	264	257	249	218	171	155	(42)	
		Edh at Noon	17	24	30	35	35	33	35	32	27	22	17	14	(43)	
(44) All-Sky Solar Radiation	RadAvg		123	317	793	1398	1858	2014	1812	1472	1003	463	174	89	(44)	
	RadStd		20	60	70	154	158	118	175	124	108	75	29	12	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (32 neighbors)		+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-227	N/A	N/A	

Nomenclature: See separate page