

OLANDS SODRA UDDE, Sweden

WMO: 026440

Lat: 56.1977N

Lon: 16.4005E

Elev: 2

StdP: 101.30

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.3	-5.5	-10.5	1.5	-6.4	-8.5	1.8	-4.6	16.3	1.9	15.2	1.7	5.9	10	0.736

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.8	22.8	20.0	21.6	19.3	20.5	18.5	20.5	22.2	19.6	21.3	18.8	20.4	4.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.5	21.8	18.9	13.7	21.0	18.0	13.0	20.0	59.1	22.4	56.1	21.4	53.2	20.5	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.5	13.1	11.8	DB	-9.1	23.4	3.2	2.2	-11.4	25.0	-13.3	26.3	-15.1	27.5	-17.4	29.1	(4)
(5)			WB	-9.9	20.7	2.7	1.8	-11.8	22.0	-13.4	23.1	-14.9	24.1	-16.8	25.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	0.9	0.8	2.1	5.1	9.6	14.0	16.9	17.3	13.9	9.5	5.8	2.8
	DBStd	6.47	3.17	2.95	2.54	2.08	2.41	2.01	2.31	2.20	2.37	2.71	2.79	3.37
	HDD10.0	1365	283	258	246	147	36	1	0	0	1	42	128	223
	HDD18.3	3704	542	492	504	397	269	130	56	46	134	276	377	481
	CDD10.0	732	0	0	0	1	25	121	215	227	117	25	1	0
	CDD18.3	28	0	0	0	0	0	1	13	14	1	0	0	0
	CDH23.3	22	0	0	0	0	0	0	13	9	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.2	7.2	6.9	6.3	5.7	5.5	5.2	5.1	5.4	6.0	6.7	7.0	7.5
Precipitation	PrecAvg	469	29	25	20	23	38	41	54	49	49	50	52	42
	PrecMax	628	63	49	47	59	108	95	150	113	197	148	140	83
	PrecMin	315	1	8	0	1	5	0	6	0	9	9	7	20
	PrecStd	69	16	11	11	15	19	19	36	31	40	31	28	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.4	6.2	7.6	12.2	17.4	21.0	24.9	24.4	21.3	15.4	12.0	9.2
		MCWB	6.7	5.1	5.5	9.4	14.1	17.7	21.1	20.7	18.8	14.3	11.2	8.4
	2%	DB	6.4	5.4	6.4	10.3	15.5	19.2	23.1	22.8	19.3	14.4	10.9	8.3
		MCWB	5.8	4.5	5.0	8.2	13.0	16.7	20.4	19.9	17.1	13.3	10.1	7.6
	5%	DB	5.7	4.7	5.7	9.1	14.3	18.2	21.7	21.7	18.1	13.7	10.0	7.7
		MCWB	5.0	4.0	4.6	7.4	12.3	16.1	19.5	19.4	16.3	12.6	9.2	7.0
	10%	DB	4.9	4.2	5.0	8.1	13.3	17.2	20.7	20.7	17.2	13.0	9.2	6.9
		MCWB	4.3	3.6	4.2	6.7	11.6	15.3	18.8	18.6	15.6	12.0	8.4	6.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	5.6	6.2	10.3	14.9	18.3	22.2	21.5	19.4	14.7	11.6	8.7
		MCDB	7.0	5.9	7.0	11.8	16.6	19.9	24.1	23.5	21.0	15.2	12.0	8.9
	2%	WB	6.0	4.7	5.5	8.6	13.5	17.1	20.8	20.5	17.7	13.6	10.3	7.8
		MCDB	6.3	5.1	6.1	9.9	15.0	18.6	22.5	22.3	18.8	14.2	10.8	8.1
	5%	WB	5.1	4.2	4.9	7.7	12.6	16.3	19.8	19.7	16.7	12.9	9.3	7.2
		MCDB	5.4	4.6	5.5	9.0	14.0	17.7	21.4	21.4	17.7	13.5	9.9	7.7
	10%	WB	4.4	3.7	4.3	6.8	11.7	15.5	19.0	18.9	15.9	12.2	8.5	6.3
		MCDB	4.9	4.2	4.9	7.9	13.1	17.0	20.7	20.5	17.0	12.9	9.1	6.8
Mean Daily Temperature Range	5% DB	MDBR	2.7	2.6	2.9	3.5	3.8	3.9	3.9	3.8	3.5	2.9	2.5	2.8
		MCDBR	2.2	2.5	3.5	5.3	5.3	5.3	4.8	4.4	2.9	2.3	2.2	
		MCWBR	2.5	2.2	2.8	3.8	3.8	4.0	3.6	3.5	3.4	2.6	2.5	2.4
	5% WB	MCDBR	2.1	2.4	3.3	4.8	4.8	4.6	4.9	4.5	3.8	2.7	2.3	2.3
		MCWBR	2.4	2.2	2.7	3.7	3.6	3.7	3.5	3.6	3.2	2.6	2.5	2.5
Clear-Sky Solar Irradiance	taub	0.311	0.338	0.355	0.388	0.385	0.376	0.403	0.400	0.371	0.358	0.340	0.304	
	taud	2.294	2.322	2.335	2.311	2.390	2.444	2.388	2.394	2.451	2.398	2.307	2.257	
	Ebn at Noon	585	719	804	828	856	868	833	809	784	688	538	488	
	Edh at Noon	53	75	94	111	109	105	109	102	84	70	53	43	
All-Sky Solar Radiation	RadAvg	0.39	1.00	2.50	4.41	5.86	6.35	5.71	4.64	3.16	1.46	0.55	0.28	
	RadStd	0.06	0.19	0.22	0.48	0.50	0.37	0.55	0.39	0.34	0.24	0.09	0.04	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (32 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	-126	N/A	N/A

Nomenclature: See separate page