

OLANDSBRON LAG, Sweden

WMO: 026460

Lat: 56.6669N

Lon: 16.4608E

Elev: 10

StdP: 101.20

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.6	-7.4	-13.0	1.2	-8.3	-10.7	1.5	-6.1	18.0	3.3	15.9	4.3	4.7	0	0.740

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.3	23.6	18.2	22.4	18.0	21.3	17.6	20.1	22.1	19.2	21.1	18.4	20.3	5.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.0	21.1	18.4	13.3	20.4	17.6	12.6	19.7	57.5	22.3	54.6	21.2	52.3	20.3	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
14.9	13.3	12.0	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-11.2	26.8	4.3	2.0	-14.3	28.2	-16.8	29.3	-19.2	30.4	-22.3	31.9		
			-12.3	21.1	4.2	0.6	-15.3	21.5	-17.8	21.9	-20.1	22.2	-23.2	22.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-0.2	0.2	2.0	6.0	10.8	15.2	18.2	17.8	13.8	9.3	5.4	1.6	(6)
(7)		DBStd	7.14	3.68	3.51	3.29	2.66	2.40	2.24	2.43	1.97	2.27	3.00	2.88	3.98	(7)
(8)		HDD10.0	1426	318	274	247	121	18	1	0	0	1	49	139	259	(8)
(9)		HDD18.3	3672	576	507	505	368	234	96	32	33	136	279	387	517	(9)
(10)		CDD10.0	842	0	0	0	2	42	157	253	242	116	28	1	0	(10)
(11)		CDD18.3	47	0	0	0	0	0	3	27	17	1	0	0	0	(11)
(12)		CDH23.3	83	0	0	0	0	0	2	69	11	0	0	0	0	(12)
(13)		CDH26.7	24	0	0	0	0	0	0	24	1	0	0	0	0	(13)
(14)	Wind	WSAvg	6.1	6.7	6.4	5.9	5.7	6.1	6.0	5.6	5.5	6.2	6.0	6.5	6.8	(14)
(15)	Precipitation	PrecAvg	501	36	32	29	28	38	40	59	53	55	40	49	42	(15)
(16)		PrecMax	782	78	79	93	64	145	112	126	120	150	134	102	112	(16)
(17)		PrecMin	299	1	2	2	5	4	0	2	4	11	2	13	4	(17)
(18)		PrecStd	104	21	19	18	14	27	24	37	28	32	28	21	25	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.3	7.9	11.8	15.1	19.2	23.2	27.0	24.5	21.1	16.3	12.6	9.7	(19)
(20)			MCWB	6.3	4.9	6.7	9.8	12.9	16.6	19.9	18.8	16.5	13.5	10.8	8.2	(20)
(21)		2%	DB	6.6	6.5	9.2	12.7	17.0	21.3	24.6	23.0	19.5	15.1	11.1	8.6	(21)
(22)			MCWB	5.2	4.4	5.5	8.2	12.6	16.1	18.9	17.9	15.8	13.3	9.8	7.3	(22)
(23)		5%	DB	5.5	5.4	7.4	11.2	15.6	20.0	23.0	22.1	18.2	14.1	10.1	7.7	(23)
(24)			MCWB	4.3	4.0	5.1	7.8	11.7	15.2	18.6	18.1	15.2	12.6	8.9	6.5	(24)
(25)		10%	DB	4.5	4.5	6.0	9.9	14.2	18.8	21.8	21.1	17.2	13.3	9.1	6.7	(25)
(26)			MCWB	3.6	3.4	4.3	7.0	11.1	14.9	18.2	17.7	14.6	12.0	8.0	5.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	5.7	7.6	10.5	15.4	18.2	21.4	21.0	18.0	14.8	11.5	8.8	(27)
(28)			MCDWB	7.6	6.8	10.5	13.5	17.6	20.5	23.8	22.7	20.0	15.5	12.0	9.3	(28)
(29)		2%	WB	5.5	4.7	6.2	9.4	13.6	17.4	20.5	19.8	16.7	13.8	9.9	7.5	(29)
(30)			MCDWB	6.2	5.8	8.2	11.6	15.5	19.7	22.9	21.6	18.2	14.5	10.9	8.2	(30)
(31)		5%	WB	4.4	4.2	5.3	8.3	12.5	16.6	19.6	19.1	15.9	13.0	9.0	6.8	(31)
(32)			MCDWB	5.2	5.2	6.9	10.5	14.5	18.9	21.8	20.7	17.6	13.7	9.9	7.5	(32)
(33)		10%	WB	3.6	3.4	4.5	7.4	11.7	15.8	18.8	18.5	15.1	12.2	8.1	5.7	(33)
(34)			MCDWB	4.4	4.4	5.8	9.3	13.6	18.0	20.9	20.0	16.7	13.2	8.9	6.5	(34)
(35)	Mean Daily Temperature Range	MDBR	3.4	3.4	4.6	5.5	5.4	5.4	5.3	4.9	4.5	3.7	3.0	3.0	(35)	
(36)		5% DB	MCDBR	3.6	4.1	6.9	7.7	7.3	7.6	7.3	6.1	5.6	4.2	3.4	2.9	(36)
(37)			MCWBR	3.1	3.0	4.0	4.0	4.0	3.9	3.5	3.3	3.1	2.9	2.9	2.8	(37)
(38)		5% WB	MCDBR	3.4	3.9	6.0	6.8	6.5	6.3	6.2	5.3	4.8	3.6	3.2	2.7	(38)
(39)			MCWBR	3.1	3.0	3.9	4.0	4.1	3.8	3.6	3.4	3.0	2.8	2.9	2.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.304	0.333	0.349	0.384	0.380	0.372	0.399	0.395	0.365	0.353	0.334	0.297	(40)	
(41)		taud	2.294	2.324	2.351	2.319	2.391	2.444	2.387	2.398	2.461	2.406	2.309	2.247	(41)	
(42)		Ebn at Noon	583	718	808	831	859	871	835	813	788	688	534	480	(42)	
(43)		Edh at Noon	51	74	92	110	109	104	109	101	82	68	51	41	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.37	0.96	2.48	4.35	5.77	6.27	5.67	4.60	3.12	1.42	0.53	0.28	(44)	
(45)		RadStd	0.06	0.19	0.22	0.48	0.46	0.35	0.54	0.39	0.34	0.23	0.09	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (32 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	-96	-143	N/A	N/A

Nomenclature: See separate page