

VAXJO, Sweden

WMO: 026480

Lat: 56.8463N

Lon: 14.8296E

Elev: 656

StdP: 14.35

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.2	13.9	4.2	7.0	11.2	8.5	8.7	16.7	23.5	36.4	20.7	36.5	4.8	340	0.583

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	79.4	64.1	76.4	63.3	73.3	61.7	67.1	74.9	65.3	72.6	63.4	70.5	6.9	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.5	93.0	70.4	62.5	86.8	68.4	60.6	80.9	66.4	32.0	74.6	30.5	72.4	29.1	70.5	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.9	15.8	14.0	DB	4.1	83.7	6.1	3.3	-0.3	86.1	-3.9	88.0	-7.3	89.8	-11.8	92.2	(4)
			WB	3.7	70.1	5.9	2.0	-0.6	71.6	-4.1	72.8	-7.4	73.9	-11.7	75.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.0	29.0	29.4	34.6	43.7	51.5	57.9	62.7	61.1	54.3	45.0	37.8	32.3
	DBStd	13.39	7.51	6.91	7.29	6.11	5.89	5.40	5.35	4.60	4.83	6.08	6.19	7.67
	HDD50	3067	650	576	476	206	50	3	0	0	17	176	366	547
	HDD65	7353	1115	996	941	640	419	221	112	137	323	622	815	1012
	CDD50	1257	0	0	0	15	97	242	393	345	145	20	0	0
	CDD65	66	0	0	0	0	0	9	40	17	0	0	0	0
	CDH74	540	0	0	0	0	8	111	309	109	3	0	0	0
	CDH80	75	0	0	0	0	0	12	51	12	0	0	0	0
Wind	WSAvg	6.9	7.6	7.5	7.8	7.4	7.1	6.5	6.0	5.4	6.2	6.9	7.5	7.6
Precipitation	PrecAvg	26.6	2.0	1.5	1.6	1.6	1.9	2.4	3.0	2.5	2.9	2.4	2.5	2.3
	PrecMax	33.5	4.5	4.1	3.1	3.1	5.2	5.8	5.9	5.7	8.0	4.9	5.2	5.1
	PrecMin	18.8	0.2	0.2	0.1	0.2	0.5	0.0	0.1	0.5	0.7	0.6	0.7	0.6
	PrecStd	3.5	1.0	0.8	0.8	0.7	0.9	1.3	1.5	1.2	1.5	1.2	1.0	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.0	47.2	57.8	68.2	75.1	81.7	85.2	81.5	73.0	61.9	52.2	48.9
		MCWB	44.5	42.8	46.9	53.0	61.9	64.0	65.8	65.0	62.2	56.0	50.7	47.9
	2%	DB	42.8	43.2	52.8	63.6	71.4	77.4	80.5	77.1	68.8	57.4	49.8	46.3
		MCWB	41.5	41.1	44.1	50.6	58.0	62.6	65.1	63.4	59.9	54.3	48.5	45.5
	5%	DB	40.7	40.8	47.7	59.4	67.6	73.4	77.5	73.7	65.4	55.2	47.8	43.8
		MCWB	39.6	39.1	41.7	48.6	55.7	60.3	64.0	62.6	58.3	52.8	46.4	42.9
	10%	DB	38.8	38.6	44.1	55.2	63.2	69.7	74.3	70.6	62.2	53.3	46.2	41.9
		MCWB	37.7	37.3	40.2	46.2	53.4	58.1	63.2	61.6	56.5	51.1	45.1	41.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.9	44.2	48.7	55.2	63.7	67.5	69.8	69.3	64.3	57.3	51.1	48.6
		MCDB	45.8	45.4	55.3	64.1	73.0	75.8	78.2	77.1	69.4	59.4	51.7	49.0
	2%	WB	41.9	41.6	45.0	51.7	60.7	64.0	67.6	66.5	61.0	55.1	48.7	45.6
		MCDB	42.6	42.9	50.1	59.7	67.7	74.1	76.1	72.7	66.9	56.9	49.6	46.2
	5%	WB	39.8	39.3	42.9	49.2	57.5	61.4	65.9	64.4	59.1	53.3	46.7	43.1
		MCDB	40.5	40.4	46.8	56.4	63.8	70.7	74.0	70.0	63.9	54.9	47.6	43.7
	10%	WB	37.8	37.3	40.6	47.1	55.0	59.4	64.3	62.6	57.3	51.5	45.3	41.0
		MCDB	38.6	38.6	43.8	54.0	61.5	67.8	71.6	68.6	61.1	53.0	46.2	41.7
Mean Daily Temperature Range	5% DB	MDBR	7.0	8.0	12.3	16.7	16.9	16.9	16.2	15.2	13.0	10.0	7.0	6.8
		MCDBR	7.0	10.0	18.9	23.6	22.9	23.5	22.2	20.0	18.1	11.4	7.6	8.0
		MCWBR	6.9	7.8	11.5	13.3	12.6	11.7	9.7	9.4	10.2	8.5	7.2	8.1
	5% WB	MCDBR	7.2	8.3	16.5	19.9	19.2	20.5	18.5	17.0	16.3	10.6	7.4	8.0
MCWBR		7.2	6.9	11.1	12.2	11.8	11.6	9.5	9.9	10.1	8.4	7.2	8.0	
Clear-Sky Solar Irradiance	taub		0.291	0.321	0.339	0.374	0.372	0.362	0.385	0.383	0.353	0.342	0.318	0.281
	taud		2.287	2.329	2.363	2.337	2.396	2.445	2.394	2.402	2.474	2.428	2.345	2.247
	Ebn at Noon		189	232	260	267	275	279	269	261	254	222	176	157
	Edh at Noon		16	23	29	34	34	33	34	32	26	21	15	13
All-Sky Solar Radiation	RadAvg		127	320	780	1265	1651	1756	1601	1297	895	420	159	90
	RadStd		23	58	81	169	167	112	201	125	115	75	30	8

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (57 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-284	N/A	N/A	

Nomenclature: See separate page