

VAXJO, Sweden

WMO: 026480

Lat: 56.8463N

Lon: 14.8296E

Elev: 200

StdP: 98.95

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.7	-10.1	-15.4	1.0	-11.6	-13.1	1.2	-8.5	10.5	2.5	9.3	2.5	2.1	340	0.583

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	26.4	17.9	24.7	17.4	22.9	16.5	19.5	23.8	18.5	22.6	17.5	21.4	3.1	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.0	13.3	21.4	17.0	12.4	20.2	15.9	11.6	19.1	56.5	23.7	53.0	22.4	49.9	21.4	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 8.0	7.1	6.3		-15.5	28.7	3.4	1.8	-17.9	30.0	-19.9	31.1	-21.9	32.1	-24.3	33.4	
(5)			DB	-15.7	21.2	3.3	1.1	-18.1	22.0	-20.0	22.7	-21.9	23.3	-24.3	24.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-1.6	-1.4	1.5	6.5	10.8	14.4	17.0	16.2	12.4	7.2	3.2	0.2
	DBStd	7.44	4.17	3.84	4.05	3.39	3.27	3.00	2.97	2.56	2.69	3.38	3.44	4.26
	HDD10.0	1704	361	320	264	114	28	2	0	0	9	98	203	304
	HDD18.3	4085	619	553	523	356	233	123	62	76	179	346	453	562
	CDD10.0	698	0	0	0	8	54	134	218	192	81	11	0	0
	CDD18.3	37	0	0	0	0	0	5	22	9	0	0	0	0
	CDH23.3	300	0	0	0	0	4	62	172	61	2	0	0	0
	CDH26.7	42	0	0	0	0	0	7	28	7	0	0	0	0
(14) Wind	WSAvg	3.1	3.4	3.4	3.5	3.3	3.2	2.9	2.7	2.4	2.8	3.1	3.3	3.4
(15) Precipitation	PrecAvg	675	52	37	41	40	49	61	75	63	74	60	64	59
	PrecMax	851	115	103	79	79	131	147	149	146	204	124	132	129
	PrecMin	478	5	6	2	4	12	0	3	12	19	14	19	15
	PrecStd	88	26	21	21	19	24	33	38	30	38	30	26	29
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.8	8.4	14.4	20.1	23.9	27.6	29.6	27.5	22.8	16.6	11.2	9.4
		MCWB	6.9	6.0	8.3	11.7	16.6	17.8	18.8	18.3	16.8	13.3	10.4	8.8
	2%	DB	6.0	6.2	11.5	17.5	21.9	25.2	26.9	25.1	20.4	14.1	9.9	7.9
		MCWB	5.3	5.1	6.7	10.3	14.5	17.0	18.4	17.4	15.5	12.4	9.2	7.5
	5%	DB	4.8	4.9	8.7	15.2	19.8	23.0	25.3	23.2	18.6	12.9	8.8	6.6
		MCWB	4.2	3.9	5.4	9.2	13.2	15.7	17.8	17.0	14.6	11.6	8.0	6.0
	10%	DB	3.8	3.7	6.7	12.9	17.3	20.9	23.5	21.4	16.8	11.8	7.9	5.5
		MCWB	3.2	2.9	4.6	7.9	11.9	14.5	17.4	16.5	13.6	10.6	7.3	5.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	6.8	9.3	12.9	17.6	19.7	21.0	20.7	17.9	14.0	10.6	9.2
		MCDB	7.7	7.4	12.9	17.8	22.8	24.3	25.7	25.0	20.8	15.2	10.9	9.5
	2%	WB	5.5	5.3	7.2	11.0	15.9	17.8	19.8	19.2	16.1	12.8	9.3	7.6
		MCDB	5.9	6.1	10.1	15.4	19.9	23.4	24.5	22.6	19.4	13.8	9.8	7.9
	5%	WB	4.3	4.0	6.1	9.6	14.2	16.3	18.9	18.0	15.0	11.8	8.2	6.2
		MCDB	4.7	4.7	8.2	13.5	17.7	21.5	23.3	21.1	17.7	12.7	8.6	6.5
	10%	WB	3.2	2.9	4.8	8.4	12.8	15.2	17.9	17.0	14.1	10.8	7.4	5.0
		MCDB	3.7	3.7	6.5	12.2	16.4	19.9	22.0	20.4	16.2	11.7	7.9	5.4
(35) Mean Daily Temperature Range	5% DB	MDBR	3.9	4.4	6.8	9.3	9.4	9.4	9.0	8.5	7.2	5.6	3.9	3.8
		MCDBR	3.9	5.6	10.5	13.1	12.7	13.1	12.3	11.1	10.1	6.3	4.2	4.5
		MCWBR	3.8	4.3	6.4	7.4	7.0	6.5	5.4	5.2	5.7	4.7	4.0	4.5
	5% WB	MCDWR	4.0	4.6	9.1	11.1	10.7	11.4	10.3	9.5	9.0	5.9	4.1	4.4
		MCWBR	4.0	3.8	6.2	6.8	6.6	6.4	5.3	5.5	5.6	4.7	4.0	4.4
(40) Clear-Sky Solar Irradiance	taub		0.291	0.321	0.339	0.374	0.372	0.362	0.385	0.383	0.353	0.342	0.318	0.281
	taud		2.287	2.329	2.363	2.337	2.396	2.445	2.394	2.402	2.474	2.428	2.345	2.247
	Ebn at Noon		596	732	820	841	866	880	848	823	800	701	556	496
	Edh at Noon		50	72	90	107	108	104	108	100	81	66	48	40
(44) All-Sky Solar Radiation	RadAvg		0.40	1.01	2.46	3.99	5.21	5.54	5.05	4.09	2.82	1.32	0.50	0.28
	RadStd		0.07	0.18	0.25	0.53	0.53	0.35	0.63	0.40	0.36	0.24	0.10	0.03

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (57 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	-158	N/A	N/A	

Nomenclature: See separate page