

KOSTA, Sweden

WMO: 026610

Lat: 56.840N

Lon: 15.470E

Elev: 761

StdP: 14.30

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.5	11.0	1.4	6.1	6.9	7.2	8.2	12.9	15.4	36.4	14.0	36.2	1.0	350	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.8	79.7	63.2	76.5	62.3	73.5	60.9	66.6	74.0	64.8	71.9	63.1	69.9	4.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.3	92.9	68.9	62.4	86.8	67.2	60.5	81.0	65.4	31.7	73.4	30.2	71.7	29.0	70.0	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.1	10.3	9.4	DB	0.3	85.1	6.8	3.3	-4.6	87.5	-8.6	89.5	-12.5	91.3	-17.4	93.7	(4)
			WB	-1.5	68.7	7.1	1.6	-6.6	69.9	-10.8	70.9	-14.8	71.8	-19.9	73.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.1	27.7	28.7	33.5	42.5	50.9	57.0	61.6	60.1	53.0	44.2	37.0	31.6
	DBStd	13.54	7.99	7.79	7.59	6.14	6.71	5.17	5.19	4.51	5.10	6.60	6.82	8.07
	HDD50	3301	691	597	513	234	70	6	0	1	27	199	391	572
	HDD65	7685	1156	1017	978	674	436	245	134	164	360	644	840	1037
	CDD50	1133	0	0	0	10	99	216	358	313	118	19	0	0
	CDD65	43	0	0	0	0	0	5	27	11	0	0	0	0
	CDH74	589	0	0	0	0	28	126	330	101	4	0	0	0
	CDH80	81	0	0	0	0	0	14	55	12	0	0	0	0
Wind	WSAvg	4.1	5.0	4.6	4.5	4.2	4.0	3.5	3.1	3.2	3.5	4.0	4.8	5.0
Precipitation	PrecAvg	26.7	1.9	1.6	1.4	1.4	2.1	2.4	3.2	3.0	2.6	2.4	2.6	2.2
	PrecMax	31.1	3.3	3.2	2.5	3.0	5.4	5.6	6.7	5.8	7.8	4.8	5.6	5.2
	PrecMin	21.2	0.1	0.4	0.4	0.2	0.3	0.0	0.2	0.9	0.5	0.9	0.5	0.7
	PrecStd	2.7	0.9	0.7	0.6	0.8	1.0	1.3	1.6	1.3	1.8	1.1	1.1	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.2	48.5	58.0	69.7	77.2	82.1	85.3	80.9	73.5	63.7	52.2	49.0
		MCWB	43.6	42.0	46.9	54.1	59.6	61.0	65.9	64.5	62.5	56.3	50.8	48.1
	2%	DB	42.3	43.2	53.2	64.2	73.8	77.8	80.9	76.5	69.2	58.2	49.9	46.2
		MCWB	41.1	40.6	43.7	51.3	57.8	60.6	64.2	63.9	60.4	54.5	48.6	45.5
	5%	DB	40.2	40.7	47.8	59.6	69.9	73.6	77.8	73.4	65.5	55.5	47.8	43.8
		MCWB	38.8	39.3	41.5	48.9	56.6	59.5	63.5	62.4	58.1	53.2	46.8	42.9
	10%	DB	38.1	38.6	43.7	55.2	65.3	69.8	74.2	70.3	62.1	53.2	46.1	41.7
		MCWB	36.8	37.3	40.0	46.3	54.1	57.5	62.3	61.1	56.0	51.2	45.3	41.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.1	43.6	49.0	55.4	63.0	66.6	69.3	68.9	64.5	57.6	51.3	48.4
		MCDB	44.7	45.1	56.0	66.0	72.7	73.7	77.6	75.5	69.5	60.4	51.7	48.8
	2%	WB	41.6	41.1	44.9	52.2	60.8	63.3	67.1	66.3	61.3	55.5	48.9	45.6
		MCDB	42.1	42.7	50.3	62.6	70.4	71.6	75.4	71.9	66.7	57.2	49.6	46.0
	5%	WB	39.2	39.4	42.6	49.8	58.3	60.8	65.5	64.3	59.1	53.6	46.9	43.1
		MCDB	39.9	40.7	47.0	57.4	65.3	70.8	73.8	69.7	64.0	55.4	47.5	43.6
	10%	WB	37.0	37.2	40.4	47.3	55.6	58.7	63.6	62.7	57.1	51.6	45.3	41.0
		MCDB	37.6	38.5	43.4	53.8	63.2	68.0	71.4	68.2	60.5	53.0	46.0	41.7
Mean Daily Temperature Range	5% DB	MDBR	8.6	10.0	14.7	19.6	20.6	19.8	18.8	17.3	15.8	11.7	7.8	7.8
		MCDBR	8.0	11.7	21.6	28.0	27.9	27.6	25.6	22.9	20.9	14.3	8.0	8.2
		MCWBR	8.0	8.7	13.6	16.0	14.5	12.7	11.2	11.7	12.7	10.7	7.5	8.1
	5% WB	MCDBR	8.1	10.1	18.9	24.2	22.8	22.5	21.3	19.2	18.3	12.8	7.5	8.1
		MCWBR	8.2	8.0	12.9	16.0	14.3	12.4	11.1	11.3	12.1	10.3	7.3	8.0
Clear-Sky Solar Irradiance	taub	0.291	0.320	0.337	0.371	0.369	0.359	0.384	0.380	0.351	0.341	0.317	0.280	
	taud	2.296	2.338	2.371	2.347	2.403	2.451	2.398	2.408	2.478	2.431	2.341	2.249	
	Ebn at Noon	190	233	261	268	276	280	269	262	254	223	177	158	
	Edh at Noon	16	23	28	34	34	33	34	31	26	21	15	13	
All-Sky Solar Radiation	RadAvg	127	320	780	1265	1652	1756	1601	1298	895	420	159	90	
	RadStd	23	58	80	169	167	112	201	125	115	75	30	8	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (50 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-268	N/A	N/A

Nomenclature: See separate page