

KOSTA, Sweden

WMO: 026610

Lat: 56.840N

Lon: 15.470E

Elev: 232

StdP: 98.57

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.7	-11.7	-17.0	0.9	-13.9	-13.8	1.2	-10.6	6.9	2.4	6.3	2.3	0.4	350	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	26.5	17.3	24.7	16.8	23.0	16.1	19.2	23.3	18.2	22.2	17.3	21.0	2.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.3	20.5	16.9	12.4	19.6	15.8	11.6	18.6	55.8	23.0	52.5	22.1	49.5	21.1	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.6	4.2	-17.6	29.5	3.8	1.8	-20.4	30.8	-22.6	31.9	-24.7	33.0	-27.5	34.3		
(5)			-18.6	20.4	3.9	0.9	-21.5	21.1	-23.8	21.6	-26.0	22.1	-28.8	22.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-2.4	-1.8	0.8	5.8	10.5	13.9	16.4	15.6	11.7	6.8	2.8	-0.2	(6)
(7)		DBStd	7.52	4.44	4.33	4.21	3.41	3.73	2.87	2.89	2.50	2.83	3.67	3.79	4.48	(7)
(8)		HDD10.0	1834	384	332	285	130	39	3	0	1	15	111	217	318	(8)
(9)		HDD18.3	4269	642	565	543	374	242	136	74	91	200	358	467	576	(9)
(10)		CDD10.0	629	0	0	0	6	55	120	199	174	66	11	0	0	(10)
(11)		CDD18.3	24	0	0	0	0	0	3	15	6	0	0	0	0	(11)
(12)		CDH23.3	327	0	0	0	0	16	70	183	56	2	0	0	0	(12)
(13)		CDH26.7	45	0	0	0	0	0	8	31	7	0	0	0	0	(13)
(14)	Wind	WSAvg	1.8	2.2	2.1	2.0	1.9	1.8	1.6	1.4	1.4	1.5	1.8	2.2	2.2	(14)
(15)	Precipitation	PrecAvg	679	49	40	35	35	53	62	81	75	66	62	65	57	(15)
(16)		PrecMax	791	85	81	63	75	138	141	170	148	197	121	142	133	(16)
(17)		PrecMin	538	3	9	9	6	8	0	5	22	12	22	12	18	(17)
(18)		PrecStd	69	23	18	15	21	26	33	41	32	46	28	28	25	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.4	9.1	14.4	20.9	25.1	27.8	29.6	27.2	23.0	17.6	11.2	9.4	(19)
(20)			MCWB	6.5	5.6	8.3	12.3	15.3	16.1	18.8	18.1	17.0	13.5	10.5	9.0	(20)
(21)		2%	DB	5.7	6.2	11.8	17.9	23.2	25.4	27.2	24.7	20.7	14.6	10.0	7.9	(21)
(22)			MCWB	5.1	4.8	6.5	10.7	14.3	15.9	17.9	17.7	15.8	12.5	9.2	7.5	(22)
(23)		5%	DB	4.5	4.8	8.8	15.3	21.1	23.1	25.4	23.0	18.6	13.0	8.8	6.6	(23)
(24)			MCWB	3.8	4.0	5.3	9.4	13.7	15.3	17.5	16.9	14.5	11.8	8.2	6.1	(24)
(25)		10%	DB	3.4	3.7	6.5	12.9	18.5	21.0	23.5	21.3	16.7	11.8	7.8	5.4	(25)
(26)			MCWB	2.6	2.9	4.5	8.0	12.3	14.2	16.8	16.2	13.3	10.6	7.4	5.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	6.4	9.4	13.0	17.2	19.2	20.7	20.5	18.1	14.2	10.7	9.1	(27)
(28)			MCDWB	7.0	7.3	13.3	18.9	22.6	23.2	25.4	24.2	20.8	15.8	10.9	9.3	(28)
(29)		2%	WB	5.3	5.1	7.2	11.2	16.0	17.4	19.5	19.1	16.3	13.0	9.4	7.6	(29)
(30)			MCDWB	5.6	5.9	10.2	17.0	21.4	22.0	24.1	22.2	19.3	14.0	9.8	7.8	(30)
(31)		5%	WB	4.0	4.1	5.9	9.9	14.6	16.0	18.6	18.0	15.1	12.0	8.3	6.2	(31)
(32)			MCDWB	4.4	4.8	8.4	14.1	18.5	21.5	23.2	21.0	17.8	13.0	8.6	6.4	(32)
(33)		10%	WB	2.8	2.9	4.7	8.5	13.1	14.8	17.6	17.0	14.0	10.9	7.4	5.0	(33)
(34)			MCDWB	3.1	3.6	6.3	12.1	17.4	20.0	21.9	20.1	15.8	11.7	7.8	5.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.8	5.5	8.2	10.9	11.4	11.0	10.4	9.6	8.8	6.5	4.3	4.3	(35)
(36)			MCDBR	4.5	6.5	12.0	15.6	15.5	15.3	14.2	12.7	11.6	8.0	4.4	4.6	(36)
(37)			MCWBR	4.5	4.8	7.5	8.9	8.1	7.1	6.2	6.5	7.1	6.0	4.2	4.5	(37)
(38)		5% WB	MCDWB	4.5	5.6	10.5	13.4	12.7	12.5	11.8	10.6	10.2	7.1	4.2	4.5	(38)
(39)			MCWBR	4.6	4.4	7.2	8.9	7.9	6.9	6.2	6.3	6.7	5.7	4.0	4.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.291	0.320	0.337	0.371	0.369	0.359	0.384	0.380	0.351	0.341	0.317	0.280	(40)	
(41)		taud	2.296	2.338	2.371	2.347	2.403	2.451	2.398	2.408	2.478	2.431	2.341	2.249	(41)	
(42)		Ebn at Noon	598	734	822	845	869	882	849	827	802	703	557	498	(42)	
(43)		Edh at Noon	50	72	89	106	107	103	107	99	81	66	48	40	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.40	1.01	2.46	3.99	5.21	5.54	5.05	4.09	2.82	1.32	0.50	0.28	(44)	
(45)		RadStd	0.07	0.18	0.25	0.53	0.53	0.35	0.63	0.40	0.36	0.24	0.10	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (50 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-149	N/A	N/A

Nomenclature: See separate page