

KALMAR OLAND, SwedenWMO: **026700**Lat: **56.678N**Lon: **16.292E**Elev: **13**StdP: **14.69**Time Zone: **1.00 (EUC)**Period: **96-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.9	13.8	3.9	6.7	9.6	9.4	8.9	17.1	28.8	41.1	25.1	39.1	4.2	350	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	78.3	65.4	75.4	64.2	72.9	62.7	68.1	74.7	66.3	72.5	64.7	70.5	9.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.7	94.7	70.9	64.0	89.2	69.4	62.2	83.7	68.0	32.4	74.7	31.0	72.5	29.7	70.5	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.1	19.0	16.8	DB	0.5	83.6	8.4	3.7	-5.6	86.3	-10.5	88.4	-15.2	90.5	-21.3	93.2	(4)
(5)			WB	0.1	70.2	8.4	2.1	-6.0	71.7	-10.9	72.9	-15.6	74.1	-21.6	75.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.8	30.8	32.0	35.3	42.2	50.7	58.2	62.5	61.9	54.9	46.7	39.5	33.7
	DBStd	12.93	8.15	7.67	7.13	5.65	5.74	4.89	4.44	4.45	4.91	6.13	6.51	8.42
	HDD50	2829	595	505	455	240	60	2	0	0	13	135	318	506
	HDD65	7068	1060	925	920	683	443	210	103	117	302	568	766	971
	CDD50	1294	0	0	1	7	83	249	389	369	162	32	2	0
	CDD65	55	0	0	0	0	0	6	27	21	1	0	0	0
	CDH74	415	0	0	0	0	7	66	220	120	2	0	0	0
	CDH80	47	0	0	0	0	1	9	22	15	0	0	0	0
Wind	WSAvg	8.0	8.5	8.6	8.4	8.1	7.9	8.1	7.4	7.4	7.6	7.9	8.0	8.6
Precipitation	PrecAvg	19.7	1.4	1.3	1.1	1.1	1.5	1.6	2.3	2.1	2.2	1.6	1.9	1.7
	PrecMax	30.8	3.1	3.1	3.7	2.5	5.7	4.4	5.0	4.7	5.9	5.3	4.0	4.4
	PrecMin	11.8	0.0	0.1	0.1	0.2	0.2	0.0	0.1	0.2	0.4	0.1	0.5	0.2
	PrecStd	4.1	0.8	0.7	0.7	0.6	1.1	0.9	1.5	1.1	1.3	1.1	0.8	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.8	50.0	59.0	65.3	73.6	80.6	82.7	81.6	72.9	62.9	55.5	51.7
		MCWB	45.9	44.2	47.2	53.6	59.0	64.1	66.8	67.8	62.8	57.0	51.5	49.2
	2%	DB	45.4	46.8	53.0	60.1	68.9	75.2	79.1	76.9	69.4	59.7	52.2	48.4
		MCWB	42.9	43.1	45.2	50.2	57.4	61.9	66.0	65.3	61.4	55.7	49.7	46.2
	5%	DB	43.1	44.5	49.1	56.2	65.8	72.0	76.3	74.2	66.7	57.6	50.0	46.1
		MCWB	40.8	41.5	43.0	48.1	56.0	60.4	65.1	64.3	59.5	54.2	48.0	44.3
	10%	DB	40.9	41.9	45.7	52.9	62.3	69.3	73.4	71.7	64.3	55.6	48.1	44.0
		MCWB	38.9	39.1	41.1	46.0	53.6	59.0	63.5	63.1	58.2	52.8	46.6	42.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.6	46.2	49.7	55.2	62.5	67.1	70.5	70.1	65.9	58.8	52.4	49.9
		MCDB	48.4	49.0	57.0	63.1	70.4	75.4	77.8	76.6	69.6	61.0	54.0	51.5
	2%	WB	43.4	43.8	46.0	51.7	59.4	64.3	68.6	67.8	62.8	56.6	50.1	46.5
		MCDB	44.9	46.4	51.4	58.2	66.2	72.4	75.6	74.0	67.1	58.9	51.8	47.9
	5%	WB	41.2	41.6	43.5	49.0	57.0	62.0	66.8	66.2	60.9	54.9	48.3	44.5
		MCDB	42.8	44.1	48.1	54.9	63.3	69.4	73.3	71.8	64.9	57.1	49.6	45.8
	10%	WB	39.3	39.4	41.4	46.7	54.9	60.1	65.1	64.6	59.1	53.3	46.8	42.4
		MCDB	40.5	41.7	45.2	51.8	60.9	67.1	71.3	69.7	62.8	55.4	48.0	43.8
Mean Daily Temperature Range	5% DB	MDBR	8.8	9.7	13.2	16.1	17.4	17.3	16.4	16.7	15.3	11.6	8.5	8.4
		MCDBR	9.0	12.0	18.6	22.2	23.0	23.2	21.9	20.3	18.6	13.4	9.3	8.7
		MCWBR	7.7	8.9	12.0	13.5	13.1	12.2	11.0	10.8	11.4	9.9	8.2	8.0
	5% WB	MCDBR	8.9	10.9	17.3	20.0	19.4	20.7	18.5	17.8	16.9	12.7	8.4	8.8
		MCWBR	8.2	8.6	11.8	12.9	12.1	12.1	10.4	10.7	11.5	10.1	7.7	8.3
Clear-Sky Solar Irradiance	taub	0.305	0.333	0.349	0.383	0.381	0.372	0.399	0.395	0.365	0.353	0.334	0.297	
	taud	2.293	2.323	2.350	2.319	2.387	2.439	2.382	2.394	2.459	2.406	2.311	2.246	
	Ebn at Noon	185	228	256	264	272	276	265	258	250	218	169	152	
	Edh at Noon	16	23	29	35	35	33	35	32	26	22	16	13	
All-Sky Solar Radiation	RadAvg	121	307	785	1360	1799	1948	1763	1431	974	445	165	89	
	RadStd	20	61	71	156	151	112	176	123	108	74	29	11	

Historical Trends

		Heating			Cooling		
--	--	---------	--	--	---------	--	--