

PUUMALA KK URHEILUKENTTA, Finland

WMO: 027180

Lat: 61.5225N

Lon: 28.1850E

Elev: 98

StdP: 100.15

Time Zone: 2.00 (EUE)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -23.7	(c) -20.8	(d) -26.9	(e) 0.3	(f) -23.6	(g) -23.6	(h) 0.5	(i) -20.7	(j) 8.4	(k) -0.3	(l) 8.1	(m) -1.2	(n) 1.5	(o) 250	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	27.9	18.9	26.0	18.3	24.1	17.1	20.2	25.9	19.2	24.2	18.2	22.9	3.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.3	22.7	17.2	12.5	21.9	16.2	11.6	20.9	58.3	26.1	55.2	23.9	51.9	23.0	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.0	(b) 7.2	(c) 6.4	(e) -24.7	(f) 29.2	(g) 4.5	(h) 2.9	(i) -27.9	(j) 31.3	(k) -30.6	(l) 33.0	(m) -33.1	(n) 34.6	(o) -36.4	(p) 36.8		
(a) 8.0	(b) 7.2	(c) 6.4	(e) -24.8	(f) 21.3	(g) 4.2	(h) 1.5	(i) -27.9	(j) 22.4	(k) -30.3	(l) 23.2	(m) -32.6	(n) 24.1	(o) -35.7	(p) 25.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.1	-8.5	-5.7	-2.4	3.6	10.8	14.9	18.4	16.4	11.6	4.5	0.5	-4.1		
	DBStd	9.98	6.93	6.12	4.53	3.43	4.44	3.74	3.95	3.17	3.25	3.53	4.05	6.04		
	HDD10.0	2558	575	439	385	194	44	5	0	1	22	172	285	436		
	HDD18.3	4928	833	672	643	443	234	115	51	76	202	429	535	694		
	CDD10.0	753	0	0	0	1	69	152	259	200	69	2	0	0		
	CDD18.3	83	0	0	0	0	2	12	52	17	0	0	0	0		
	CDH23.3	579	0	0	0	0	29	87	368	95	0	0	0	0		
	CDH26.7	122	0	0	0	0	1	13	88	20	0	0	0	0		
(14) Wind	WSAvg	3.3	3.3	3.6	3.7	3.2	3.0	3.4	2.8	3.0	3.3	3.6	3.6	3.6		
(15) Precipitation	PrecAvg	642	51	39	35	30	41	60	80	72	50	68	60	55		
	PrecMax	746	83	89	73	66	92	98	149	138	124	156	130	94		
	PrecMin	486	9	4	8	10	10	22	25	22	22	16	9	19		
	PrecStd	68	19	20	15	14	23	23	32	36	29	33	28	22		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.9	5.0	8.9	18.0	26.3	28.3	31.5	29.1	20.4	13.2	9.9	7.4		
		MCWB	2.1	2.7	3.6	9.4	15.4	17.6	21.1	20.2	15.6	10.5	8.2	6.7		
	2%	DB	2.0	3.1	6.5	13.9	23.6	25.8	29.0	25.8	18.7	11.7	7.8	4.7		
		MCWB	1.5	1.8	2.9	7.6	14.3	16.8	19.6	18.6	14.8	10.0	6.9	3.8		
	5%	DB	0.7	2.0	4.5	11.2	21.2	23.6	27.1	23.5	17.3	10.7	6.6	3.3		
		MCWB	0.2	1.2	1.6	6.0	12.8	16.0	18.9	17.0	13.9	9.3	5.9	2.5		
	10%	DB	0.1	1.0	2.9	9.3	18.8	21.6	25.3	21.7	16.1	9.7	5.4	2.1		
		MCWB	-0.4	0.5	0.9	5.0	11.9	15.3	18.6	16.4	13.5	8.4	4.7	1.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.4	3.0	4.6	9.8	17.2	19.8	22.1	21.0	16.5	11.5	8.5	6.8		
		MCDB	2.7	4.1	7.3	14.6	23.5	26.1	28.8	27.7	19.0	12.6	9.3	7.3		
	2%	WB	1.6	2.0	3.2	8.2	15.3	18.1	20.8	19.2	15.5	10.6	7.1	4.0		
		MCDB	2.0	2.9	5.7	13.3	20.8	23.5	26.7	23.6	17.7	11.5	7.9	4.5		
	5%	WB	0.6	1.3	2.2	6.8	14.0	16.7	19.9	18.2	14.7	9.7	5.9	2.6		
		MCDB	0.9	1.9	3.9	10.3	19.6	21.9	25.4	22.5	16.6	10.5	6.5	3.3		
	10%	WB	-0.3	0.6	1.3	5.5	12.7	15.6	19.1	17.0	13.8	8.4	4.8	1.5		
		MCDB	0.1	1.1	2.6	8.6	18.1	20.7	24.1	20.7	15.8	9.5	5.4	2.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	4.8	6.5	8.1	9.5	8.4	8.1	7.0	5.5	4.0	3.1	3.6		
		MCDBR	3.7	4.4	8.0	11.6	13.5	11.5	10.8	9.8	7.1	5.3	4.2	3.9		
		MCWBR	3.6	3.7	5.3	6.7	6.1	5.1	4.2	4.0	4.1	4.1	4.1	3.9		
	5% WB	MCDBR	3.4	4.2	6.6	10.1	11.6	10.2	9.9	9.1	6.3	4.8	4.1	3.9		
		MCWBR	3.4	3.6	4.8	6.2	5.9	5.3	4.3	4.1	4.0	4.2	4.1	4.0		
(40) Clear-Sky Solar Irradiance	taub		0.248	0.293	0.320	0.360	0.356	0.353	0.377	0.362	0.338	0.320	0.270	N/A		
	taud		2.057	2.127	2.204	2.344	2.440	2.480	2.428	2.454	2.511	2.407	2.147	N/A		
	Ebn at Noon		446	661	786	830	867	875	840	823	781	649	417	N/A		
	Edh at Noon		39	71	94	101	99	97	100	90	71	56	35	N/A		
(44) All-Sky Solar Radiation	RadAvg		0.23	0.80	2.25	3.66	4.99	5.27	5.13	3.95	2.28	0.92	0.25	0.12		
	RadStd		0.04	0.19	0.31	0.39	0.58	0.34	0.50	0.48	0.26	0.14	0.04	0.01		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)		+0.51	N/A	N/A	N/A	N/A	N/A	-172	N/A	N/A	N/A

Nomenclature: See separate page