

INARI SAARISELKA, Finland

WMO: 027220

Lat: 68.4150N

Lon: 27.4133E

Elev: 991

StdP: 14.18

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.6	-14.7	-23.5	1.6	-18.4	-19.3	2.0	-14.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	75.3	60.2	71.1	58.9	67.1	57.1	62.9	71.3	60.7	68.3	58.5	65.0	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.7	79.3	65.4	57.4	73.0	62.9	55.6	68.1	61.1	28.9	71.3	27.3	68.4	25.9	65.1	69.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
N/A	N/A	N/A	DB	-26.3	78.5	4.7	3.3	-29.7	80.9	-32.5	82.8	-35.1	84.6	-38.6	87.0	
			WB	-26.2	65.1	4.5	3.2	-29.4	67.4	-32.1	69.3	-34.6	71.1	-37.9	73.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	30.7	8.3	10.0	17.1	28.4	40.3	48.5	55.5	51.0	43.1	29.9	20.1	14.5	(6)
(7)		DBStd	18.38	10.89	12.94	9.54	7.83	8.12	7.75	7.33	6.57	6.28	7.88	9.73	10.91	(7)
(8)		HDD50	7450	1292	1119	1018	648	318	121	28	67	219	623	896	1101	(8)
(9)		HDD65	12535	1757	1539	1483	1098	765	498	304	435	656	1088	1346	1566	(9)
(10)		CDD50	405	0	0	0	0	18	75	200	99	13	0	0	0	(10)
(11)		CDD65	16	0	0	0	0	0	3	11	2	0	0	0	0	(11)
(12)		CDH74	156	0	0	0	0	5	22	105	24	0	0	0	0	(12)
(13)		CDH80	16	0	0	0	0	0	1	11	4	0	0	0	0	(13)
(14)	Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)
(15)	Precipitation	PrecAvg	21.2	1.2	1.1	1.0	1.3	1.7	2.4	3.0	2.7	2.1	2.0	1.5	1.3	(15)
(16)		PrecMax	27.4	2.6	3.3	2.3	3.6	3.2	4.7	5.1	5.3	3.9	4.4	2.7	2.5	(16)
(17)		PrecMin	14.4	0.2	0.3	0.2	0.4	0.6	0.3	0.9	0.5	0.5	0.2	0.2	0.2	(17)
(18)		PrecStd	3.3	0.6	0.7	0.6	0.6	0.7	1.1	1.1	1.2	1.0	1.0	0.7	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.9	35.7	39.0	52.1	72.9	77.3	81.5	77.3	62.1	48.0	39.4	35.5	(19)
(20)		0.4%	MCWB	31.1	34.7	34.4	43.5	55.8	60.7	64.1	64.9	54.9	45.2	38.9	33.9	(20)
(21)		2%	DB	28.4	32.0	35.5	45.5	65.1	70.9	76.9	70.9	59.1	45.1	35.2	32.5	(21)
(22)		2%	MCWB	27.6	31.2	32.1	38.3	51.9	57.7	61.1	59.7	53.0	43.4	34.6	32.0	(22)
(23)		5%	DB	26.0	30.2	33.0	42.0	59.3	66.4	73.0	66.0	56.4	42.8	33.4	31.0	(23)
(24)		5%	MCWB	25.3	29.4	30.4	36.2	48.1	54.7	59.7	57.5	51.3	41.4	32.9	30.7	(24)
(25)		10%	DB	23.3	27.6	31.0	39.2	53.7	62.1	69.2	62.2	53.4	40.2	32.1	28.9	(25)
(26)		10%	MCWB	22.7	26.8	29.0	34.4	45.5	52.7	59.0	55.7	49.8	39.3	31.6	28.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.1	34.9	34.8	43.8	55.7	63.0	66.6	65.8	57.1	46.0	39.2	34.2	(27)
(28)		0.4%	MCDB	31.8	35.7	37.9	51.8	70.2	72.3	73.4	75.7	59.8	46.4	39.2	35.2	(28)
(29)		2%	WB	27.7	31.4	32.7	39.2	52.9	60.0	63.8	61.5	54.3	43.7	34.8	32.2	(29)
(30)		2%	MCDB	28.2	31.9	34.9	44.0	63.4	68.7	72.6	68.1	57.6	44.9	35.1	32.5	(30)
(31)		5%	WB	25.5	29.4	30.9	36.7	49.5	56.8	61.8	58.7	52.0	41.5	33.1	30.7	(31)
(32)		5%	MCDB	26.1	30.1	32.7	40.8	57.5	62.9	69.9	64.3	55.4	42.7	33.4	31.0	(32)
(33)		10%	WB	22.8	27.0	29.2	35.1	46.1	53.8	59.9	56.7	50.1	39.4	31.7	28.4	(33)
(34)		10%	MCDB	23.3	27.7	30.9	38.1	52.5	61.6	67.4	60.9	52.8	40.2	32.0	28.8	(34)
(35)	Mean Daily Temperature Range		MDBR	14.2	13.3	18.0	15.8	15.1	14.7	15.4	15.2	13.0	9.4	10.8	12.5	(35)
(36)		5% DB	MCDBR	15.7	9.9	14.7	17.0	23.9	21.5	22.7	20.6	17.3	9.8	8.2	9.0	(36)
(37)			MCWBR	15.7	9.4	11.9	10.9	12.7	10.4	10.2	11.1	11.2	8.2	8.1	9.3	(37)
(38)			5% WB	MCDBR	15.4	10.4	11.1	15.2	22.3	19.1	18.5	18.1	13.9	9.1	8.0	9.1
(39)		MCWBR		15.4	10.0	9.2	10.1	12.6	10.3	9.6	10.3	9.8	8.0	8.0	9.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.188	0.244	0.284	0.314	0.335	0.336	0.347	0.330	0.301	0.262	0.353	N/A	(40)	
(41)		taud	1.915	2.078	2.166	2.229	2.418	2.488	2.475	2.500	2.553	2.294	2.764	N/A	(41)	
(42)		Ebn at Noon	25	171	235	263	272	275	267	259	240	168	42	0	(42)	
(43)		Edh at Noon	2	15	25	32	30	29	28	25	18	12	3	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	10	151	623	1203	1445	1552	1416	1011	532	172	26	0	(44)	
(45)		RadStd	1	14	37	71	146	134	156	93	51	29	3	0	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (31 neighbors)	+1.04	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page