

INARI SAARISELKA, Finland

WMO: 027220

Lat: 68.4150N

Lon: 27.4133E

Elev: 302

StdP: 97.75

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -28.1	(c) -26.0	(d) -30.8	(e) 0.2	(f) -28.0	(g) -28.5	(h) 0.3	(i) -25.9	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.5	(c) 24.0	(d) 15.7	(e) 21.7	(f) 15.0	(g) 19.5	(h) 14.0	(i) 17.2	(j) 21.8	(k) 15.9	(l) 20.2	(m) 14.7	(n) 18.3	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.4	11.3	18.5	14.1	10.4	17.2	13.1	9.7	16.1	49.3	21.8	45.7	20.2	42.3	18.4	20.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) N/A	(b) N/A	(c) N/A	(e) -32.4	(f) 25.8	(g) 2.6	(h) 1.8	(i) -34.3	(j) 27.1	(k) -35.8	(l) 28.2	(m) -37.3	(n) 29.2	(o) -39.2	(p) 30.6		
(4) N/A	(5) N/A	(6) N/A	(e) -32.3	(f) 18.4	(g) 2.5	(h) 1.8	(i) -34.1	(j) 19.7	(k) -35.6	(l) 20.7	(m) -37.0	(n) 21.7	(o) -38.8	(p) 23.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.7	-13.2	-12.2	-8.3	-2.0	4.6	9.2	13.1	10.6	6.2	-1.2	-6.6	-9.7		
	DBStd	10.21	6.05	7.19	5.30	4.35	4.51	4.31	4.07	3.65	3.49	4.38	5.40	6.06		
	HDD10.0	4139	718	622	566	360	177	67	16	37	122	346	498	612		
	HDD18.3	6964	976	855	824	610	425	277	169	242	364	604	748	870		
	CDD10.0	225	0	0	0	0	10	42	111	55	7	0	0	0		
	CDD18.3	9	0	0	0	0	0	2	6	1	0	0	0	0		
	CDH23.3	87	0	0	0	0	3	12	58	13	0	0	0	0		
	CDH26.7	9	0	0	0	0	0	1	6	2	0	0	0	0		
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(15) Precipitation	PrecAvg	538	31	28	26	32	42	60	76	69	54	50	37	33		
	PrecMax	695	67	84	59	91	81	119	130	134	100	112	69	64		
	PrecMin	365	5	7	5	9	16	8	24	12	12	6	6	5		
	PrecStd	85	15	19	14	16	17	29	28	31	25	26	17	14		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.1	2.1	3.9	11.2	22.7	25.1	27.5	25.2	16.7	8.9	4.1	1.9		
		MCWB	-0.5	1.5	1.3	6.4	13.2	15.9	17.8	18.3	12.7	7.3	3.8	1.1		
	2%	DB	-2.0	0.0	2.0	7.5	18.4	21.6	25.0	21.6	15.0	7.3	1.8	0.3		
		MCWB	-2.4	-0.5	0.1	3.5	11.1	14.3	16.1	15.4	11.6	6.4	1.4	0.0		
	5%	DB	-3.3	-1.0	0.6	5.5	15.2	19.1	22.8	18.9	13.5	6.0	0.8	-0.5		
		MCWB	-3.7	-1.4	-0.9	2.3	8.9	12.6	15.4	14.2	10.7	5.2	0.5	-0.7		
	10%	DB	-4.8	-2.4	-0.6	4.0	12.0	16.7	20.7	16.8	11.9	4.6	0.0	-1.7		
		MCWB	-5.2	-2.9	-1.7	1.3	7.5	11.5	15.0	13.2	9.9	4.1	-0.2	-2.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.5	1.6	1.6	6.5	13.2	17.2	19.2	18.8	14.0	7.8	4.0	1.2		
		MCDB	-0.1	2.1	3.3	11.0	21.2	22.4	23.0	24.3	15.5	8.0	4.0	1.8		
	2%	WB	-2.4	-0.4	0.4	4.0	11.6	15.6	17.7	16.4	12.4	6.5	1.6	0.1		
		MCDB	-2.1	0.0	1.6	6.7	17.5	20.4	22.6	20.1	14.2	7.2	1.7	0.3		
	5%	WB	-3.6	-1.5	-0.6	2.6	9.7	13.8	16.5	14.8	11.1	5.3	0.6	-0.7		
		MCDB	-3.3	-1.1	0.4	4.9	14.1	17.2	21.0	17.9	13.0	5.9	0.8	-0.6		
	10%	WB	-5.1	-2.8	-1.6	1.7	7.9	12.1	15.5	13.7	10.1	4.1	-0.2	-2.0		
		MCDB	-4.9	-2.4	-0.6	3.4	11.4	16.4	19.6	16.0	11.6	4.6	0.0	-1.8		
(35) Mean Daily Temperature Range	MDBR		7.9	7.4	10.0	8.8	8.4	8.2	8.5	8.4	7.2	5.2	6.0	7.0		
	5% DB	MCDBR	8.7	5.5	8.2	9.4	13.3	11.9	12.6	11.5	9.6	5.5	4.5	5.0		
		MCWBR	8.7	5.2	6.6	6.1	7.1	5.8	5.7	6.2	6.2	4.5	4.5	5.2		
	5% WB	MCDBR	8.6	5.8	6.2	8.5	12.4	10.6	10.3	10.1	7.7	5.1	4.5	5.1		
		MCWBR	8.5	5.6	5.1	5.6	7.0	5.7	5.3	5.7	5.4	4.4	4.4	5.2		
(40) Clear-Sky Solar Irradiance	taub		0.188	0.244	0.284	0.314	0.335	0.336	0.347	0.330	0.301	0.262	0.353	N/A		
	taud		1.915	2.078	2.166	2.229	2.418	2.488	2.475	2.500	2.553	2.294	2.764	N/A		
	Ebn at Noon		80	538	741	829	857	867	841	817	756	530	131	0		
	Edh at Noon		7	46	79	100	94	91	89	78	57	37	11	0		
(44) All-Sky Solar Radiation	RadAvg		0.03	0.48	1.97	3.79	4.56	4.89	4.46	3.19	1.68	0.54	0.08	0.00		
	RadStd		0.00	0.04	0.12	0.23	0.46	0.42	0.49	0.29	0.16	0.09	0.01	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)		+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page