

JUVA PARTALA, Finland

WMO: 027360

Lat: 61.892N

Lon: 27.885E

Elev: 112

StdP: 99.99

Time Zone: 2.00 (EUE)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.3	-23.6	-30.5	0.2	-27.3	-26.3	0.3	-23.6	6.9	-6.2	6.2	-5.5	0.7	260	0.575

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	27.3	19.2	25.3	18.3	23.5	17.0	20.6	25.4	19.4	23.7	18.2	22.3	2.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.9	22.6	17.7	12.9	21.9	16.5	11.9	20.5	59.8	25.4	55.8	23.6	51.9	22.5	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.9	5.2	4.6		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.2	-9.5	-6.3	-3.3	2.9	10.1	14.0	16.9	15.2	10.4	3.6	-0.2	-4.8	(6)
(7)		DBStd	10.01	7.75	6.71	5.35	3.61	4.54	3.84	3.51	3.15	3.27	3.75	4.38	6.65	(7)
(8)		HDD10.0	2749	604	456	411	213	56	8	1	2	34	199	305	459	(8)
(9)		HDD18.3	5218	863	689	669	463	255	137	71	104	238	456	555	718	(9)
(10)		CDD10.0	617	0	0	0	1	60	129	215	164	46	2	0	0	(10)
(11)		CDD18.3	43	0	0	0	0	1	7	27	8	0	0	0	0	(11)
(12)		CDH23.3	433	0	0	0	0	33	88	240	72	0	0	0	0	(12)
(13)		CDH26.7	74	0	0	0	0	2	12	47	14	0	0	0	0	(13)
(14)	Wind	WSAvg	2.2	2.2	2.4	2.5	2.3	2.4	2.3	1.9	1.8	2.0	2.2	2.3	2.4	(14)
(15)	Precipitation	PrecAvg	616	47	37	33	31	41	65	78	69	52	61	55	49	(15)
(16)		PrecMax	771	85	82	64	66	123	111	123	140	121	146	117	90	(16)
(17)		PrecMin	497	7	5	4	10	9	21	25	16	18	13	9	17	(17)
(18)		PrecStd	72	19	19	15	14	25	21	29	32	28	29	24	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.7	5.3	9.3	17.6	26.4	28.1	30.1	28.6	20.6	13.2	9.7	6.9	(19)
(20)			MCWB	1.8	3.0	3.5	9.5	15.7	18.4	21.0	20.5	15.9	11.3	8.4	5.8	(20)
(21)		2%	DB	1.8	3.2	7.0	13.7	24.0	25.9	28.0	25.2	18.5	11.6	7.8	4.5	(21)
(22)			MCWB	1.3	1.8	3.2	7.4	14.4	17.8	20.0	18.8	14.5	10.1	7.1	3.8	(22)
(23)		5%	DB	0.7	2.1	4.6	11.4	21.7	23.8	26.1	23.1	17.0	10.6	6.3	3.0	(23)
(24)			MCWB	0.2	1.3	1.8	6.0	13.6	16.5	19.5	17.0	13.8	9.4	5.8	2.3	(24)
(25)		10%	DB	0.1	1.1	3.1	9.3	19.1	21.8	24.1	21.3	15.6	9.3	5.0	1.8	(25)
(26)			MCWB	-0.3	0.6	1.3	5.2	12.3	15.8	18.5	16.6	13.3	8.2	4.6	1.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	3.2	4.8	10.0	17.7	20.7	22.5	21.5	16.5	11.8	8.7	6.1	(27)
(28)			MCDWB	2.5	4.5	7.3	15.0	23.8	25.9	27.5	27.3	18.7	12.9	9.4	6.6	(28)
(29)		2%	WB	1.3	2.1	3.4	8.3	16.0	18.9	21.2	19.5	15.4	10.7	7.0	3.8	(29)
(30)			MCDWB	1.7	2.9	5.9	12.4	20.8	24.2	26.3	23.6	17.3	11.3	7.6	4.1	(30)
(31)		5%	WB	0.5	1.4	2.4	6.8	14.5	17.5	20.1	18.2	14.4	9.7	5.9	2.4	(31)
(32)			MCDWB	0.8	2.0	4.2	10.2	19.5	22.3	24.6	22.0	16.2	10.3	6.4	2.8	(32)
(33)		10%	WB	-0.2	0.6	1.5	5.6	13.0	16.1	19.1	17.1	13.6	8.1	4.7	1.3	(33)
(34)			MCDWB	0.1	1.1	2.8	8.7	18.8	20.7	23.0	20.2	15.2	9.2	5.0	1.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	5.8	8.2	8.9	10.4	9.5	9.2	8.8	7.2	5.1	3.5	4.3	(35)
(36)			MCDBR	3.5	4.8	9.3	12.7	15.1	13.1	12.3	12.3	9.8	6.7	4.6	3.9	(36)
(37)			MCWBR	3.5	4.1	6.2	7.6	7.2	6.3	5.8	6.4	6.3	5.3	4.5	3.9	(37)
(38)		5% WB	MCDBR	3.6	4.6	7.4	10.7	12.6	11.6	11.2	10.4	8.1	5.7	4.7	3.9	(38)
(39)			MCWBR	3.7	4.1	5.4	6.7	6.6	6.2	5.9	5.7	5.4	5.0	4.6	3.9	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.242	0.290	0.317	0.356	0.353	0.350	0.374	0.358	0.335	0.317	0.263	0.359	(40)
(41)		taud		2.046	2.129	2.197	2.341	2.446	2.482	2.432	2.460	2.516	2.409	2.140	2.618	(41)
(42)		Ebn at Noon		436	658	786	832	869	877	842	825	781	646	410	283	(42)
(43)		Edh at Noon		37	70	94	101	98	97	100	89	70	54	34	22	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.22	0.79	2.29	3.68	4.93	5.27	5.10	3.92	2.24	0.90	0.24	0.11	(44)
(45)		RadStd		0.04	0.19	0.30	0.41	0.56	0.32	0.50	0.47	0.26	0.15	0.04	0.01	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (39 neighbors)	+0.51	N/A	N/A	N/A	N/A	N/A	-172	N/A	N/A	N/A

Nomenclature: See separate page