

PYHAJARVI OL OJAKYLA, Finland

WMO: 027380

Lat: 63.7358N

Lon: 25.7058E

Elev: 503

StdP: 14.43

Time Zone: 2.00 (EUE)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -20.1	(c) -14.0	(d) -25.2	(e) 1.4	(f) -19.9	(g) -18.4	(h) 2.0	(i) -13.8	(j) 16.8	(k) 26.5	(l) 14.6	(m) 24.8	(n) 1.1	(o) 250	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 20.1	(c) 80.0	(d) 64.8	(e) 76.2	(f) 63.1	(g) 72.7	(h) 61.1	(i) 67.4	(j) 75.3	(k) 65.2	(l) 73.1	(m) 63.2	(n) 70.2	(o) 5.5	(p) 120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.6	92.8	70.2	62.3	85.5	68.2	60.2	79.3	66.3	32.1	75.9	30.4	73.5	28.9	70.4	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.3	(b) 12.6	(c) 11.4	(e) -23.5	(f) 83.7	(g) 6.8	(h) 5.1	(i) -28.4	(j) 87.4	(k) -32.4	(l) 90.4	(m) -36.2	(n) 93.2	(o) -41.2	(p) 97.0		
(a) 14.3	(b) 12.6	(c) 11.4	(e) -23.7	(f) 70.3	(g) 6.8	(h) 3.6	(i) -28.6	(j) 72.9	(k) -32.6	(l) 75.0	(m) -36.4	(n) 77.1	(o) -41.3	(p) 79.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	36.9	13.3	17.3	24.2	35.0	46.8	54.0	59.5	56.1	48.1	36.1	29.6	21.4
	DBStd	17.88	14.11	13.96	9.95	7.12	8.23	7.23	6.30	6.06	6.26	7.02	8.44	12.21
	HDD50	5558	1136	917	800	452	159	38	5	16	106	432	611	886
	HDD65	10296	1601	1337	1265	901	565	338	192	282	507	896	1061	1351
	CDD50	774	0	0	0	0	60	157	301	205	49	2	0	0
	CDD65	36	0	0	0	0	1	7	22	6	0	0	0	0
	CDH74	556	0	0	0	0	56	101	314	85	0	0	0	0
	CDH80	79	0	0	0	0	2	12	57	8	0	0	0	0
Wind	WSAvg	5.2	5.0	5.2	5.9	5.0	5.4	5.3	4.3	4.9	4.6	5.2	5.5	5.5
Precipitation	PrecAvg	23.7	1.6	1.3	1.1	1.2	1.9	2.6	3.1	2.8	2.2	2.1	2.1	1.9
	PrecMax	31.1	3.5	2.4	2.2	2.3	3.6	6.0	5.0	5.2	4.5	3.9	3.8	3.8
	PrecMin	17.8	0.5	0.2	0.1	0.4	0.4	0.8	1.0	0.7	0.8	0.2	0.3	0.6
	PrecStd	3.1	0.7	0.6	0.6	0.6	0.8	1.3	1.1	1.1	1.1	1.0	0.8	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.1	41.1	46.8	64.7	79.3	81.9	84.4	80.9	68.9	56.1	48.8	40.2
		MCWB	35.3	37.5	38.4	49.0	58.7	64.6	67.1	67.4	60.2	52.2	47.3	39.7
	2%	DB	33.6	38.4	43.0	55.8	74.9	76.8	81.2	76.0	64.8	51.6	44.6	37.4
		MCWB	33.0	35.4	36.7	44.2	57.3	63.5	66.5	64.4	57.4	49.0	43.4	36.3
	5%	DB	32.4	35.4	39.1	51.1	70.0	72.2	77.5	72.1	61.5	49.1	41.8	35.2
		MCWB	32.0	34.2	34.7	42.1	56.3	59.6	64.9	61.7	55.6	47.3	41.4	34.4
	10%	DB	31.4	33.1	36.4	47.4	64.3	68.6	73.6	68.4	58.8	46.4	39.5	33.4
		MCWB	30.9	32.2	33.2	40.5	52.3	58.0	62.9	60.4	54.4	44.8	39.2	33.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.6	38.4	39.9	49.8	61.3	67.0	71.7	69.3	61.2	53.0	47.6	39.9
		MCDB	36.4	40.6	44.8	59.8	73.2	75.8	80.3	78.0	67.2	54.7	48.9	39.9
	2%	WB	33.2	35.9	37.5	46.6	59.3	64.6	68.7	65.5	58.8	50.1	43.4	36.6
		MCDB	33.5	37.6	41.7	55.7	70.9	73.0	76.5	73.2	62.8	50.8	44.1	37.0
	5%	WB	32.3	34.2	35.6	43.1	56.7	62.2	66.4	63.4	56.7	47.5	41.3	34.3
		MCDB	32.5	35.5	38.2	49.1	68.3	70.5	74.5	69.3	60.2	48.7	41.8	34.7
	10%	WB	30.9	32.5	33.9	41.0	54.0	59.3	64.6	61.6	55.0	44.9	39.2	33.2
		MCDB	31.3	33.4	35.9	46.3	63.9	66.8	72.3	66.9	58.3	46.4	39.5	33.5
Mean Daily Temperature Range	5% DB	MDBR	11.5	12.8	16.8	17.8	21.2	20.1	20.1	19.6	15.7	10.8	7.0	8.8
		MCDBR	6.9	9.5	15.3	26.3	32.6	26.5	27.0	25.9	21.4	13.8	8.8	7.3
		MCWBR	6.7	8.1	10.9	16.0	16.8	14.2	13.9	15.1	14.5	11.2	8.2	7.1
	5% WB	MCDBR	6.5	8.8	13.1	23.0	30.0	22.9	23.4	21.2	18.4	12.8	8.7	6.9
		MCWBR	6.4	7.7	10.1	14.8	16.0	12.8	13.1	13.1	13.0	11.1	8.2	6.9
Clear-Sky Solar Irradiance	taub	0.218	0.280	0.308	0.348	0.344	0.346	0.367	0.350	0.327	0.307	0.367	0.357	
	taud	1.987	2.128	2.192	2.311	2.451	2.467	2.422	2.462	2.516	2.385	2.674	2.652	
	Ebn at Noon	117	200	246	263	276	277	266	261	245	195	109	62	
	Edh at Noon	9	20	29	32	30	31	31	28	21	16	8	5	
All-Sky Solar Radiation	RadAvg	50	225	696	1176	1535	1685	1583	1198	679	258	62	20	
	RadStd	5	43	69	124	170	142	161	125	74	47	12	2	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page