

RAASEPORI JUSSARO, Finland

WMO: 027570

Lat: 59.821N

Lon: 23.576E

Elev: 75

StdP: 14.66

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.5	9.7	-0.7	5.3	5.0	4.9	7.1	12.6	42.0	33.3	39.9	34.0	14.2	50	0.821

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	74.7	68.1	71.8	66.1	69.3	64.4	69.6	73.7	67.7	71.2	65.3	68.5	12.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.9	102.7	72.4	66.1	96.6	70.6	63.8	88.9	67.9	33.7	73.7	32.1	71.4	30.3	68.7	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
38.4	34.6	31.4	DB	2.2	77.4	6.8	4.1	-2.7	80.3	-6.8	82.7	-10.6	84.9	-15.6	87.9	
			WB	3.3	69.6	7.3	2.8	-2.0	71.6	-6.3	73.2	-10.4	74.7	-15.7	76.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.0	26.0	27.7	30.7	38.1	48.3	56.2	63.4	62.3	56.1	45.6	39.4	33.4
	DBStd	14.11	8.31	8.82	5.72	4.11	5.81	4.25	5.12	4.02	4.60	5.52	6.20	7.37
	HDD50	3423	743	625	597	356	102	3	0	0	10	152	319	516
	HDD65	7723	1208	1045	1062	806	518	265	96	103	268	602	769	981
	CDD50	1242	0	0	0	0	49	189	414	382	192	16	0	0
	CDD65	66	0	0	0	0	0	1	45	20	0	0	0	0
	CDH74	101	0	0	0	0	0	2	86	13	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	15.5	17.2	16.5	15.6	13.2	12.6	13.2	12.4	13.9	15.3	16.9	18.8	20.2
Precipitation	PrecAvg	26.1	2.2	1.6	1.4	1.3	1.3	2.2	2.6	3.1	2.3	2.9	2.8	2.3
	PrecMax	38.5	4.6	4.0	2.6	2.8	2.9	4.0	5.9	6.3	4.9	5.1	5.5	4.5
	PrecMin	17.2	0.4	0.2	0.2	0.2	0.4	0.5	0.2	0.3	0.6	0.7	0.2	0.7
	PrecStd	4.6	1.0	0.9	0.6	0.7	0.6	0.9	1.4	1.4	1.2	1.3	1.2	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.8	40.4	44.0	52.9	67.2	70.0	78.9	75.5	66.6	57.1	50.2	46.2
		MCWB	39.7	36.4	38.5	45.9	54.4	59.7	69.3	69.7	61.8	54.3	49.0	44.8
	2%	DB	39.5	37.8	40.2	48.7	63.0	66.7	76.5	72.5	64.5	55.2	48.8	44.6
		MCWB	38.5	36.5	36.5	43.3	55.1	59.5	68.9	67.4	60.9	53.0	47.7	43.3
	5%	DB	38.1	36.8	38.1	46.0	60.0	64.6	74.0	70.1	63.0	53.8	47.5	43.0
		MCWB	37.2	35.9	35.9	41.5	53.3	58.6	67.8	65.6	59.8	51.9	46.2	41.6
	10%	DB	36.3	35.8	36.8	43.9	56.6	62.6	71.3	68.1	61.7	52.7	46.2	41.6
		MCWB	35.4	35.0	35.2	40.1	51.5	57.3	65.8	63.7	58.8	50.6	44.9	40.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.3	37.9	39.3	46.4	58.0	63.6	71.8	70.5	63.5	55.3	49.5	45.4
		MCDB	40.5	38.9	42.3	51.4	63.5	66.9	75.9	74.3	65.9	56.1	49.7	45.8
	2%	WB	38.8	37.0	37.7	44.1	56.0	61.6	70.5	68.7	61.9	54.0	48.2	43.5
		MCDB	39.4	37.5	39.2	48.0	61.8	65.2	75.0	71.8	63.8	54.9	48.7	44.2
	5%	WB	37.4	36.0	36.6	42.4	54.2	60.0	68.9	66.8	60.6	52.6	46.7	41.9
		MCDB	38.2	36.5	37.7	45.3	59.1	63.5	73.2	69.6	62.4	53.7	47.4	42.8
	10%	WB	35.7	35.1	35.6	40.8	52.0	58.3	67.1	64.6	59.4	51.2	45.2	40.5
		MCDB	36.3	35.7	36.5	43.2	56.1	61.5	70.9	67.2	61.2	52.5	46.0	41.4
Mean Daily Temperature Range	5% DB	MDBR	6.8	5.8	7.0	7.0	8.3	7.9	7.8	7.0	6.5	5.9	5.0	5.7
		MCDBR	5.4	4.6	7.4	10.5	12.2	10.8	10.1	8.4	7.7	6.0	5.2	5.6
		MCWBR	5.2	4.2	5.6	6.6	7.3	6.4	5.8	5.1	5.4	5.3	5.5	5.5
	5% WB	MCDBR	5.2	4.5	6.2	9.2	11.3	9.1	8.6	7.3	6.4	5.2	5.0	5.1
		MCWBR	5.1	4.4	4.9	6.3	7.4	5.9	5.5	5.2	5.1	5.3	5.5	5.4
Clear-Sky Solar Irradiance	taub	0.278	0.311	0.333	0.371	0.366	0.362	0.388	0.382	0.351	0.334	0.309	0.264	
	taud	2.154	2.215	2.281	2.319	2.413	2.467	2.417	2.426	2.497	2.409	2.222	2.090	
	Ebn at Noon	156	216	252	263	274	276	265	257	247	210	142	112	
	Edh at Noon	14	23	29	34	33	32	33	30	24	19	13	10	
All-Sky Solar Radiation	RadAvg	77	245	728	1253	1754	1850	1748	1376	837	363	99	49	
	RadStd	12	44	87	131	173	120	149	135	103	50	18	6	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (58 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	-243	N/A	N/A	N/A	N/A

Nomenclature: See separate page