

ALAJARVI MOKSY, Finland

WMO: 027870

Lat: 63.089N

Lon: 24.261E

Elev: 562

StdP: 14.40

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -16.2	(c) -10.3	(d) -21.6	(e) 1.7	(f) -16.2	(g) -15.0	(h) 2.5	(i) -10.2	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 20.1	(c) 80.7	(d) 64.7	(e) 76.4	(f) 62.0	(g) 73.0	(h) 60.9	(i) 67.0	(j) 75.4	(k) 64.8	(l) 73.2	(m) 62.7	(n) 70.2	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.0	91.2	70.3	61.8	84.2	68.3	59.6	77.7	65.9	31.8	75.3	30.1	73.5	28.6	70.2	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) N/A	(b) N/A	(c) N/A	(e) -19.5	(f) 83.4	(g) 7.6	(h) 4.9	(i) -25.0	(j) 86.9	(k) -29.5	(l) 89.8	(m) -33.7	(n) 92.6	(o) -39.3	(p) 96.2		
(a) N/A	(b) N/A	(c) N/A	(e) -19.8	(f) 68.6	(g) 7.5	(h) 3.5	(i) -25.3	(j) 71.1	(k) -29.7	(l) 73.2	(m) -33.9	(n) 75.1	(o) -39.4	(p) 77.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	37.7	15.4	19.0	24.1	35.6	47.1	53.9	59.9	56.4	48.2	36.9	30.6	23.3	
	DBStd	17.14	12.68	12.54	9.96	6.98	8.31	7.05	6.44	5.85	6.25	6.97	8.13	10.99	
	HDD50	5298	1072	867	802	432	152	37	4	12	105	407	581	827	
	HDD65	10022	1537	1287	1267	881	555	339	185	274	504	870	1031	1292	
	CDD50	793	0	0	0	1	64	155	310	210	51	2	0	0	
	CDD65	41	0	0	0	0	2	6	26	7	0	0	0	0	
	CDH74	624	0	0	0	0	59	125	363	77	0	0	0	0	
	CDH80	121	0	0	0	0	4	24	80	13	0	0	0	0	
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Precipitation	PrecAvg	23.9	1.6	1.3	1.4	1.3	1.7	2.7	3.2	2.4	2.2	2.4	2.0	1.8	
	PrecMax	28.6	2.8	2.5	2.1	2.8	3.3	4.5	4.8	4.1	5.6	3.7	3.9	2.7	
	PrecMin	19.6	0.4	0.1	0.2	0.4	0.4	0.8	0.7	0.8	0.7	0.6	0.2	0.5	
	PrecStd	2.6	0.7	0.7	0.5	0.6	0.8	1.1	1.2	0.9	1.4	1.0	1.0	0.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.3	41.0	46.6	65.4	79.6	83.4	86.1	82.1	68.0	57.1	49.2	41.7	
		MCWB	35.9	37.2	39.0	49.4	59.4	62.9	67.0	68.3	60.1	53.7	47.6	41.4	
	2%	DB	34.5	37.6	42.4	58.3	75.0	77.4	82.0	75.1	64.4	52.0	44.9	37.7	
		MCWB	33.6	35.5	36.8	46.3	57.4	61.4	65.7	63.4	57.9	50.3	44.0	36.5	
	5%	DB	32.9	34.9	39.0	52.1	70.1	72.8	77.9	71.6	61.3	49.7	42.6	35.8	
		MCWB	32.3	34.1	35.0	43.3	55.7	59.3	63.8	60.9	55.7	47.7	42.0	35.0	
	10%	DB	31.7	33.0	36.4	48.2	64.8	68.8	74.1	68.0	58.8	47.1	40.2	34.0	
		MCWB	31.2	32.3	33.5	41.0	52.5	57.5	62.7	59.7	54.6	45.4	39.7	33.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.5	37.7	40.4	51.3	62.0	66.6	70.5	69.5	61.0	53.7	47.9	41.7
			MCDB	37.3	39.8	44.0	60.1	75.0	75.1	81.1	79.8	65.9	56.6	48.9	41.8
2%		WB	33.9	35.7	37.7	47.7	59.3	63.8	67.9	65.8	59.1	50.8	44.3	37.0	
		MCDB	34.3	37.1	40.7	56.7	70.9	73.7	76.0	73.0	62.9	51.8	44.8	37.4	
5%		WB	32.6	34.1	35.8	44.3	56.7	61.3	66.0	63.1	57.1	48.2	42.0	35.1	
		MCDB	33.0	34.9	38.4	51.0	68.7	70.3	74.6	68.1	60.2	49.3	42.5	35.6	
10%		WB	31.2	32.6	33.8	41.5	53.6	58.7	64.0	61.1	55.3	45.6	39.8	33.6	
		MCDB	31.7	33.2	36.1	47.0	64.8	67.0	72.5	66.1	57.9	46.9	40.2	34.1	
Mean Daily Temperature Range	5% DB	MDBR	11.3	12.0	16.7	17.4	22.1	20.3	20.1	18.4	15.4	10.7	6.9	8.2	
		MCDBR	6.7	9.0	14.7	26.4	31.2	28.2	26.7	24.4	19.7	12.9	8.7	7.8	
		MCWBR	6.6	7.7	10.9	16.2	16.5	14.6	12.8	14.2	13.8	10.9	8.5	7.7	
	5% WB	MCDBR	6.5	8.4	12.8	23.0	28.9	23.1	23.2	19.9	17.0	11.7	8.5	7.4	
		MCWBR	6.5	7.5	10.2	15.0	15.8	12.5	12.4	12.3	12.4	10.7	8.4	7.4	
Clear-Sky Solar Irradiance	taub		0.225	0.282	0.309	0.349	0.345	0.345	0.367	0.352	0.328	0.309	0.244	0.356	
	taud		2.021	2.146	2.213	2.336	2.451	2.471	2.426	2.460	2.518	2.396	2.112	2.639	
	Ebn at Noon		127	205	248	264	277	278	267	262	247	200	118	73	
	Edh at Noon		10	20	28	31	31	31	31	28	22	16	9	6	
All-Sky Solar Radiation	RadAvg		55	233	705	1173	1547	1679	1582	1210	698	273	69	25	
	RadStd		7	48	73	129	173	144	161	130	80	53	13	3	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (43 neighbors)	+0.90	N/A	N/A	N/A	N/A	N/A	-256	N/A	N/A	N/A

Nomenclature: See separate page