

SIIKAJOKI REVONLAHTI, Finland

WMO: 028030

Lat: 64.684N

Lon: 25.088E

Elev: 162

StdP: 14.61

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.4	-11.0	-23.1	1.5	-17.4	-15.7	2.4	-10.9	21.8	34.2	18.7	32.4	1.3	100	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	79.6	64.7	75.6	62.9	72.0	61.3	67.6	75.9	65.2	72.6	63.0	69.8	5.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	92.3	70.9	62.3	84.3	68.3	60.1	78.0	66.3	32.1	75.7	30.2	72.4	28.6	70.0	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	13.6	11.6	DB	-18.9	82.0	8.7	5.1	-25.2	85.6	-30.3	88.6	-35.2	91.4	-41.5	95.1	(4)
(5)			WB	-19.5	70.0	8.3	3.8	-25.4	72.8	-30.2	75.0	-34.9	77.1	-40.9	79.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.7	14.8	17.9	24.8	35.5	47.3	54.5	60.8	57.0	48.9	37.3	30.1	22.8		
	DBStd	17.60	12.83	13.52	9.38	6.46	8.19	6.74	6.04	5.78	5.99	6.77	8.43	11.68		
	HDD50	5326	1093	898	782	437	150	29	2	9	91	394	596	845		
	HDD65	9995	1558	1318	1247	886	551	323	159	255	484	858	1046	1310		
	CDD50	854	0	0	0	1	67	163	336	228	57	2	0	0		
	CDD65	45	0	0	0	0	2	7	28	8	0	0	0	0		
	CDH74	509	0	0	0	0	50	97	291	71	0	0	0	0		
	CDH80	91	0	0	0	0	2	18	61	10	0	0	0	0		
	WSAvg	4.9	4.8	5.0	5.2	4.8	5.4	5.2	4.2	4.3	4.2	5.0	5.0	5.4		
	PrecAvg	21.1	1.5	1.1	1.1	1.1	1.7	2.0	3.0	2.3	2.1	1.9	1.8	1.6		
	PrecMax	27.4	2.9	2.2	2.6	2.5	3.6	4.4	5.4	4.6	4.4	3.4	3.6	3.3		
(15) Precipitation	PrecMin	17.1	0.4	0.2	0.2	0.5	0.3	0.2	0.7	0.2	0.8	0.0	0.4	0.4		
	PrecStd	3.1	0.6	0.6	0.6	0.6	0.8	1.2	1.1	1.1	1.0	0.9	0.7	0.7		
	DB	38.4	41.7	46.5	61.0	78.9	82.8	85.1	81.1	69.0	55.8	48.8	40.0			
	MCWB	36.4	38.2	39.6	49.7	58.7	66.0	67.4	68.2	60.4	51.6	45.9	38.3			
	2% DB	35.1	39.1	42.3	54.5	74.5	76.5	81.2	75.0	64.0	51.5	45.3	37.9			
(23) Mean Coincident Wet Bulb Temperatures	MCWB	33.5	36.1	37.0	44.7	57.8	63.5	66.7	63.6	56.7	48.7	43.4	36.3			
	5% DB	33.2	35.9	39.1	50.4	68.5	71.1	76.8	71.1	61.1	49.2	42.5	36.2			
	MCWB	32.5	34.1	35.2	42.3	55.4	58.8	64.4	61.4	55.7	46.9	41.6	35.0			
	10% DB	31.4	33.6	36.7	46.7	62.7	67.7	73.1	67.5	58.6	47.1	40.2	34.5			
	MCWB	30.7	32.6	33.7	40.1	52.1	57.6	63.3	60.3	54.2	45.0	39.4	33.6			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	37.1	38.5	40.3	50.7	61.9	67.5	71.2	69.6	61.4	53.4	46.7	38.7			
	MCDB	38.3	41.1	45.3	55.3	74.1	76.9	79.0	78.9	67.3	54.5	48.2	39.3			
	2% WB	34.1	36.5	37.8	45.9	59.1	64.7	68.7	66.1	58.4	49.4	43.6	36.8			
	MCDB	34.8	38.7	41.1	53.9	70.9	73.3	76.9	73.3	62.3	50.7	44.8	37.6			
	5% WB	32.7	34.4	35.9	42.8	55.9	61.9	66.5	63.3	56.5	47.3	41.5	35.2			
(33) Mean Daily Temperature Range	MCDB	33.3	35.7	38.7	49.2	68.4	69.2	74.2	68.4	59.7	49.1	42.4	36.0			
	10% WB	30.7	32.8	34.1	40.8	52.8	58.9	64.2	61.3	54.9	45.2	39.5	33.7			
	MCDB	31.5	33.7	36.1	45.7	61.2	65.7	71.6	66.1	57.9	47.0	40.2	34.4			
	5% DB	11.7	12.4	14.8	15.7	18.8	17.5	17.8	16.9	14.2	10.2	7.4	8.8			
	MCDBR	9.2	8.9	13.3	22.9	28.4	25.0	24.8	22.5	18.9	12.0	8.9	7.4			
(40) Clear-Sky Solar Irradiance	MCWBR	8.7	7.5	10.0	14.3	14.4	13.2	12.5	12.7	12.4	9.6	8.2	6.7			
	5% WB	9.1	8.3	11.6	20.5	26.7	20.8	20.8	19.0	16.2	11.2	8.1	7.2			
	MCDBR	8.7	7.3	9.1	13.5	14.1	11.6	11.6	11.5	11.1	9.6	7.6	6.8			
	taub	0.210	0.277	0.307	0.346	0.346	0.349	0.369	0.352	0.329	0.307	0.344	0.355			
	taud	1.958	2.116	2.169	2.256	2.433	2.470	2.435	2.473	2.521	2.365	2.560	2.614			
(42) All-Sky Solar Radiation	Ebn at Noon	100	193	242	260	274	275	265	259	241	187	92	43			
	Edh at Noon	8	19	28	33	31	30	31	27	21	15	7	4			
	RadAvg	38	206	670	1193	1569	1754	1614	1205	671	245	53	12			
(45)	RadStd	3	40	67	96	154	144	149	115	68	40	9	1			

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)		+0.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page