

ENONTEKIO, Finland

WMO: 028075

Lat: 68.363N

Lon: 23.424E

Elev: 1005

StdP: 14.17

Time Zone: 2.00 (EUE)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -27.0	(c) -20.5	(d) -32.8	(e) 0.9	(f) -26.6	(g) -26.0	(h) 1.3	(i) -20.5	(j) 21.3	(k) 24.5	(l) 18.8	(m) 23.5	(n) 1.2	(o) 210	(p) 0.758

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	75.3	60.2	71.3	57.7	66.5	56.3	62.0	71.1	59.9	67.3	57.8	64.6	7.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.0	77.3	63.8	56.9	71.6	62.0	55.0	66.8	60.3	28.2	71.5	26.7	67.2	25.4	64.6	68.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	16.8	14.9	-34.7	78.9	5.6	4.2	-38.8	81.9	-42.1	84.4	-45.2	86.7	-49.3	89.7
			-34.9	64.4	5.6	2.9	-39.0	66.4	-42.2	68.1	-45.3	69.7	-49.4	71.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	30.4	7.5	8.2	16.2	28.2	39.7	49.5	56.4	52.1	43.6	30.4	18.3	13.6
	DBStd	19.63	13.67	14.25	11.58	7.98	7.87	6.74	6.65	6.06	6.36	9.42	11.50	13.06
	HDD50	7569	1319	1171	1048	653	334	89	14	49	207	608	950	1127
	HDD65	12626	1784	1591	1513	1103	785	466	276	401	642	1073	1400	1592
	CDD50	433	0	0	0	0	15	74	214	115	15	0	0	0
	CDD65	12	0	0	0	0	0	1	10	1	0	0	0	0
	CDH74	146	0	0	0	0	8	8	115	15	0	0	0	0
	CDH80	13	0	0	0	0	0	0	12	1	0	0	0	0
Wind	WSAvg	6.4	5.4	5.7	6.7	6.8	7.6	8.0	6.9	6.0	6.4	6.0	5.4	5.8
Precipitation	PrecAvg	20.1	1.2	1.1	1.0	1.0	1.5	2.4	2.8	2.8	1.7	1.8	1.5	1.3
	PrecMax	24.8	2.4	2.4	2.4	2.6	2.9	4.3	5.2	5.1	3.7	3.8	2.6	2.9
	PrecMin	14.3	0.3	0.2	0.4	0.3	0.3	0.7	0.7	1.4	0.4	0.5	0.4	0.3
	PrecStd	3.1	0.5	0.5	0.5	0.6	0.7	1.1	1.2	0.9	0.9	0.8	0.7	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	37.7	41.4	51.7	71.9	75.5	82.0	76.7	63.0	50.3	40.9	39.2
		MCWB	32.8	34.8	35.7	42.1	55.7	59.4	63.8	64.1	54.1	46.6	40.4	35.9
	2%	DB	30.5	33.4	37.2	46.3	64.4	69.9	77.1	71.2	59.0	46.8	37.3	35.3
		MCWB	30.0	31.6	33.2	39.0	51.0	56.5	60.3	58.8	51.9	44.7	35.8	33.7
	5%	DB	28.4	30.1	34.0	42.7	58.6	65.9	73.5	66.3	55.6	44.7	33.9	32.1
		MCWB	27.8	29.3	31.0	36.9	48.1	53.8	59.0	57.3	50.6	43.4	33.6	31.5
	10%	DB	25.1	26.8	31.8	39.5	52.2	61.1	69.5	62.8	53.5	42.4	32.0	30.1
		MCWB	24.7	26.3	29.9	34.6	44.2	51.7	58.4	55.6	49.4	41.3	31.9	29.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.9	35.4	36.3	42.8	55.5	62.2	65.4	64.8	55.8	47.5	40.5	36.3
		MCDB	33.7	37.5	41.0	50.4	72.1	71.5	74.2	72.9	60.6	48.4	40.6	38.5
	2%	WB	30.2	31.5	33.5	39.0	51.8	58.3	62.8	60.8	53.5	44.9	35.8	33.3
		MCDB	30.5	32.5	36.4	44.4	62.6	65.5	73.1	67.2	57.5	46.4	36.6	34.2
	5%	WB	27.4	28.9	31.5	37.0	48.2	55.8	61.0	58.4	51.8	43.2	33.5	31.6
		MCDB	27.9	29.6	33.3	41.9	56.5	63.1	69.7	63.9	55.3	44.4	34.0	32.0
	10%	WB	24.7	26.0	29.5	35.1	45.3	53.2	59.1	56.8	50.2	40.7	31.8	29.2
		MCDB	25.1	26.7	31.4	39.0	51.3	60.3	66.7	62.1	53.0	41.6	31.9	29.8
Mean Daily Temperature Range	5% DB	MDBR	14.8	15.0	18.2	15.5	13.9	13.9	15.4	15.3	12.9	10.1	11.9	13.7
		MCDBR	13.2	13.6	13.9	17.3	24.0	20.8	22.3	21.0	16.3	10.5	9.0	10.3
		MCWBR	12.7	12.7	11.4	11.8	13.0	10.0	9.5	10.9	10.6	8.8	8.7	9.6
	5% WB	MCDBR	12.9	12.8	12.6	15.2	21.2	16.4	18.3	16.8	13.1	9.4	8.7	9.7
		MCWBR	12.5	12.1	10.8	10.6	12.1	9.1	9.3	9.7	9.1	8.1	8.5	9.3
Clear-Sky Solar Irradiance	taub		0.182	0.240	0.279	0.308	0.328	0.332	0.339	0.325	0.294	0.257	N/A	N/A
	taud		1.919	2.091	2.188	2.216	2.401	2.490	2.484	2.505	2.561	2.305	N/A	N/A
	Ebn at Noon		28	174	239	265	274	276	270	261	243	172	N/A	0
	Edh at Noon		2	14	24	32	30	29	28	24	18	12	N/A	0
All-Sky Solar Radiation	RadAvg		10	150	627	1259	1591	1567	1473	1049	564	185	27	0
	RadStd		1	13	29	56	154	109	143	73	60	29	3	0

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page