

SAVUKOSKI KK, Finland

WMO: 028150

Lat: 67.286N

Lon: 28.177E

Elev: 591

StdP: 14.39

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.3	-19.8	-31.2	1.0	-25.3	-25.0	1.4	-19.7	12.3	21.1	10.8	25.3	0.1	0	0.665

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	78.0	61.7	73.6	60.0	69.8	58.7	64.5	73.3	62.4	70.8	60.4	67.1	4.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.6	83.8	67.2	59.3	76.9	64.5	57.3	71.5	63.0	29.9	73.1	28.4	71.0	26.9	67.0	72.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.0	9.1	7.7	DB	-31.8	80.4	6.4	4.0	-36.4	83.2	-40.2	85.5	-43.8	87.7	-48.4	90.6
			WB	-31.7	67.7	6.1	2.8	-36.1	69.7	-39.7	71.3	-43.1	72.9	-47.6	74.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	32.7	7.9	11.0	18.4	30.6	43.2	51.7	58.5	53.7	45.3	32.0	22.4	15.9	(6)
	DBStd	19.44	13.26	14.50	10.64	7.93	8.26	7.61	6.66	6.22	5.88	7.75	9.98	12.41	(7)
	HDD50	6920	1305	1092	980	582	245	68	9	32	162	559	827	1059	(8)
	HDD65	11828	1770	1512	1445	1032	676	405	217	354	592	1024	1277	1524	(9)
	CDD50	594	0	0	0	0	35	119	273	147	20	0	0	0	(10)
	CDD65	26	0	0	0	0	0	6	16	4	0	0	0	0	(11)
	CDH74	341	0	0	0	0	22	71	201	47	0	0	0	0	(12)
	CDH80	58	0	0	0	0	1	11	37	9	0	0	0	0	(13)
	WSAvg	3.1	2.3	2.8	3.5	3.5	4.1	3.9	3.3	3.1	3.1	3.0	2.7	2.6	(14)
	PrecAvg	23.3	1.5	1.4	1.2	1.3	1.8	2.6	3.3	2.5	2.2	2.2	1.8	1.6	(15)
(16) Precipitation	PrecMax	30.5	3.1	2.9	2.6	3.1	3.3	4.3	5.4	4.8	4.4	4.3	2.8	2.8	(16)
	PrecMin	17.5	0.6	0.6	0.3	0.3	0.4	0.7	0.7	0.6	0.4	0.8	0.6	0.4	(17)
	PrecStd	3.3	0.6	0.7	0.6	0.6	0.7	1.1	1.2	1.1	1.0	0.9	0.7	0.6	(18)
	PrecStd	3.3	0.6	0.7	0.6	0.6	0.7	1.1	1.2	1.1	1.0	0.9	0.7	0.6	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	36.3	41.7	57.2	77.1	81.7	84.5	80.2	64.6	49.7	41.3	36.1	(19)
		MCWB	32.1	34.9	36.0	45.7	56.6	62.8	64.3	66.2	56.4	48.1	40.2	35.2	(20)
	2%	DB	30.2	33.5	37.5	47.7	70.5	74.5	79.2	72.9	61.1	46.6	37.8	33.6	(21)
		MCWB	29.5	32.5	33.3	39.4	54.6	60.2	62.2	60.9	54.0	44.4	37.0	33.1	(22)
	5%	DB	27.8	32.0	34.7	44.2	63.3	69.2	75.2	68.6	58.0	44.2	35.3	32.3	(23)
		MCWB	27.3	31.2	31.8	37.5	51.0	56.5	61.4	59.4	53.0	42.5	34.8	32.0	(24)
	10%	DB	25.0	29.5	32.7	41.3	57.9	65.0	71.5	65.0	54.9	41.8	33.5	30.7	(25)
		MCWB	24.5	28.8	30.8	35.5	48.1	54.7	60.2	57.6	51.4	40.7	33.1	30.4	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.3	35.1	36.5	45.5	58.0	65.0	68.7	67.6	58.3	49.0	41.1	35.2	(27)
		MCDB	32.9	36.2	40.3	55.9	73.1	76.3	76.3	77.5	62.8	49.6	41.2	36.0	(28)
	2%	WB	29.7	32.9	34.2	40.3	55.4	62.0	65.3	63.2	55.4	44.8	37.1	33.2	(29)
		MCDB	30.2	33.4	36.7	46.4	69.6	72.7	73.1	70.6	59.2	46.0	37.6	33.5	(30)
	5%	WB	27.3	31.3	32.5	38.1	52.3	58.8	63.4	60.6	53.7	42.7	35.0	32.1	(31)
		MCDB	27.8	31.9	34.1	42.8	62.2	65.8	71.7	66.4	56.9	44.1	35.3	32.4	(32)
	10%	WB	24.5	28.8	31.1	36.6	48.7	56.1	61.5	58.5	51.8	40.9	33.2	30.4	(33)
		MCDB	24.9	29.5	32.7	40.2	56.5	63.2	69.2	63.2	54.6	41.8	33.5	30.6	(34)
(36) Mean Daily Temperature Range	5% DB	MDBR	14.1	14.4	19.5	16.8	17.7	16.6	17.5	16.7	13.4	9.0	9.1	12.1	(35)
		MCDBR	14.2	11.2	15.0	19.5	28.4	23.5	25.4	23.3	19.3	10.6	7.5	9.0	(36)
		MCWBR	14.1	10.5	11.6	12.0	14.5	11.0	11.1	12.2	12.6	8.8	7.6	8.9	(37)
	5% WB	MCDBR	14.6	10.8	11.3	16.8	26.1	20.2	20.8	19.7	16.4	9.2	7.5	8.7	(38)
		MCWBR	14.6	10.2	9.3	10.6	14.0	10.8	10.8	11.1	11.5	8.2	7.6	8.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.193	0.257	0.292	0.323	0.341	0.343	0.356	0.337	0.311	0.278	0.352	N/A	(40)
	taud		1.923	2.090	2.152	2.195	2.406	2.469	2.451	2.477	2.533	2.322	2.708	N/A	(41)
	Ebn at Noon		48	177	236	261	272	274	266	259	239	174	58	0	(42)
	Edh at Noon		4	16	26	34	31	30	29	26	19	13	4	0	(43)
(44) All-Sky Solar Radiation	RadAvg		17	173	640	1206	1524	1596	1462	1059	558	182	36	0	(44)
	RadStd		1	25	53	85	147	129	154	101	54	32	5	0	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (28 neighbors)	+1.10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page