

INARI NELLIM, Finland

WMO: 028350

Lat: 68.849N

Lon: 28.299E

Elev: 404

StdP: 14.48

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.8	-21.1	-33.2	0.9	-26.7	-26.9	1.2	-21.1	23.0	24.6	20.8	24.1	2.4	100	0.747

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	76.4	61.4	71.9	59.4	68.2	58.4	63.8	72.1	61.6	69.5	59.5	66.2	8.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.8	80.6	66.1	58.4	74.0	64.0	56.4	68.8	62.1	29.3	71.3	27.7	69.2	26.3	66.2	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	17.4	15.2	-33.1	80.7	3.1	4.9	-35.3	84.2	-37.1	87.1	-38.8	89.9	-41.1	93.5		
(5)			-33.0	66.2	3.1	3.1	-35.2	68.4	-37.0	70.2	-38.8	72.0	-41.0	74.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	32.1	8.1	10.2	17.4	29.5	42.0	50.2	57.1	52.8	45.8	33.2	22.2	15.6		
	DBStd	19.32	13.63	14.79	11.59	8.56	7.80	7.76	7.27	6.50	6.09	7.20	9.87	12.63		
	HDD50	7038	1298	1114	1012	614	274	90	16	43	154	522	834	1067		
	HDD65	12023	1763	1534	1477	1064	714	447	263	383	575	987	1284	1532		
	CDD50	516	0	0	0	0	25	97	236	129	29	0	0	0		
	CDD65	27	0	0	0	0	1	4	18	4	0	0	0	0		
	CDH74	243	0	0	0	0	14	33	159	37	0	0	0	0		
	CDH80	49	0	0	0	0	2	5	33	9	0	0	0	0		
	WSAvg	7.2	6.3	6.1	7.6	7.6	8.0	8.4	7.5	7.0	7.5	7.3	6.4	6.5		
	PrecAvg	19.0	1.0	0.9	0.9	1.0	1.5	2.3	2.9	2.6	1.9	1.8	1.2	1.1		
(15) Precipitation	PrecMax	25.6	2.6	2.5	1.8	3.3	3.3	5.0	4.8	6.2	3.0	4.1	2.1	2.0		
	PrecMin	13.7	0.4	0.2	0.3	0.3	0.6	0.3	0.9	0.4	0.6	0.5	0.2	0.2		
	PrecStd	3.0	0.5	0.6	0.4	0.6	0.6	1.2	1.0	1.4	0.7	0.9	0.5	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.6	38.8	41.7	52.1	74.6	78.5	84.4	79.3	65.8	50.4	40.5	39.2		
		MCWB	33.7	36.6	35.9	44.3	56.8	61.4	63.5	66.2	56.6	46.1	38.6	35.7		
	2%	DB	32.1	34.6	38.1	46.9	67.1	72.4	78.5	71.4	61.7	47.6	37.5	36.0		
		MCWB	30.4	32.4	34.0	39.7	52.2	58.0	61.7	61.3	54.4	44.7	35.7	34.1		
	5%	DB	29.2	32.4	35.8	43.6	59.9	67.9	73.9	67.6	58.9	45.3	35.5	33.8		
		MCWB	27.9	30.6	32.3	37.5	49.4	55.9	61.2	59.1	53.1	43.1	34.2	32.5		
	10%	DB	26.2	29.8	33.4	40.5	54.8	63.3	70.1	64.0	55.7	42.7	33.7	31.6		
		MCWB	25.2	28.3	30.7	35.3	46.6	53.9	59.5	57.2	51.5	41.2	32.5	30.5		
	0.4%	WB	33.8	36.8	36.7	44.1	56.9	63.6	67.5	67.2	58.4	46.8	39.1	36.4		
		MCDB	35.4	38.7	40.6	51.3	71.1	73.5	72.9	76.4	63.9	48.8	40.3	38.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	30.4	32.9	34.7	40.4	53.7	60.4	64.6	62.6	55.8	45.1	36.2	34.4		
		MCDB	31.9	34.4	37.8	45.5	64.5	69.6	72.8	69.6	60.1	47.4	37.2	35.9		
	5%	WB	27.9	30.5	32.7	37.9	50.1	57.3	62.8	60.0	53.5	43.1	34.3	32.6		
		MCDB	29.1	32.4	35.3	42.3	59.5	64.0	71.4	65.7	57.9	45.0	35.3	33.8		
	10%	WB	25.2	28.3	31.0	36.2	47.1	54.9	60.9	58.0	51.8	41.2	32.7	30.5		
		MCDB	26.1	29.7	33.3	39.6	53.5	62.1	68.4	62.9	55.3	42.7	33.6	31.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.3	15.5	19.3	15.7	14.8	13.8	14.4	14.0	12.0	8.3	11.1	14.2		
		MCDBR	14.3	9.9	11.8	16.5	24.8	20.5	22.1	19.5	16.8	9.4	8.0	8.8		
		MCWBR	13.8	8.7	9.1	10.6	12.9	9.6	9.8	10.1	10.6	7.5	7.4	8.4		
		MCDBR	14.4	10.3	10.4	14.9	22.7	18.9	18.1	16.9	14.3	8.8	7.9	9.1		
	5% WB	MCWBR	14.0	9.4	8.4	9.8	12.6	10.0	9.4	9.8	9.5	7.4	7.5	8.7		
(40) Clear-Sky Solar Irradiance	taub		0.197	0.250	0.293	0.325	0.347	0.347	0.359	0.341	0.309	0.268	0.356	N/A		
	taud		1.914	2.062	2.138	2.223	2.397	2.467	2.455	2.484	2.542	2.267	2.712	N/A		
	Ebn at Noon		15	161	228	257	267	271	262	254	234	158	30	0		
	Edh at Noon		2	14	25	32	30	29	29	25	18	12	3	0		
(44) All-Sky Solar Radiation	RadAvg		7	135	583	1120	1408	1531	1394	978	524	162	22	0		
	RadStd		0	13	35	75	143	132	159	95	42	24	3	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (28 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page