

SALLA KK MYLLYTIE, Finland

WMO: 028490

Lat: 66.834N

Lon: 28.674E

Elev: 727

StdP: 14.31

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.0	-21.4	-32.5	0.9	-26.5	-26.4	1.3	-21.1	19.8	24.9	17.2	24.5	1.6	150	0.710

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	76.2	61.7	72.7	59.8	69.3	58.4	64.6	72.2	62.1	69.4	60.0	66.7	7.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.5	83.7	67.9	59.2	77.0	65.4	57.0	71.2	62.6	30.0	72.4	28.2	69.6	26.7	66.5	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	16.9	14.9	13.3	DB	-31.3	80.5	4.7	4.0	-34.7	83.4	-37.4	85.7	-40.1	88.0	-43.5	90.9
(5)				WB	-31.1	67.2	4.6	3.1	-34.4	69.4	-37.1	71.2	-39.6	73.0	-42.9	75.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	32.3	8.9	10.1	18.7	30.1	41.6	52.0	58.1	53.4	44.2	32.3	21.1	15.0
	DBStd	19.68	14.84	14.16	10.81	8.77	8.22	7.15	6.41	6.46	6.74	8.37	11.82	14.33
	HDD50	7044	1275	1116	971	596	283	60	10	39	195	549	866	1084
	HDD65	11970	1740	1536	1436	1046	724	394	228	364	624	1013	1316	1549
	CDD50	569	0	0	0	0	24	120	261	143	21	0	0	0
	CDD65	21	0	0	0	0	0	4	13	4	0	0	0	0
	CDH74	214	0	0	0	0	7	46	125	36	0	0	0	0
	CDH80	27	0	0	0	0	0	5	17	5	0	0	0	0
Wind	WSAvg	6.1	5.2	5.6	6.6	6.6	7.0	6.5	6.0	5.9	6.2	6.2	5.7	5.8
Precipitation	PrecAvg	21.5	1.4	1.2	1.1	1.1	1.7	2.4	3.0	2.4	2.0	1.9	1.6	1.5
	PrecMax	30.9	3.4	2.9	2.1	2.2	2.8	3.9	5.5	4.8	4.8	3.9	2.6	2.9
	PrecMin	16.8	0.4	0.4	0.3	0.4	0.6	0.7	1.1	0.9	0.4	0.6	0.4	0.4
	PrecStd	3.4	0.6	0.6	0.6	0.5	0.6	1.0	0.9	1.1	1.1	0.8	0.6	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.1	36.8	42.7	57.3	74.8	79.8	82.1	78.1	65.0	52.0	44.1	37.4
		MCWB	33.7	35.0	36.4	46.2	55.3	61.7	64.2	65.5	55.9	48.5	42.8	35.8
	2%	DB	32.5	33.6	37.9	49.9	67.3	73.6	77.3	73.0	60.8	48.2	39.7	35.3
		MCWB	31.6	32.4	33.7	40.9	53.0	58.4	62.9	60.7	54.1	45.9	38.5	34.1
	5%	DB	30.5	31.8	35.0	45.8	60.8	69.2	73.7	69.2	57.7	45.5	36.4	33.5
		MCWB	29.7	30.9	32.0	38.5	49.5	56.5	61.1	59.3	52.7	43.6	35.5	32.6
	10%	DB	27.8	29.1	32.9	42.3	56.3	65.4	70.4	65.5	55.1	43.1	34.1	31.6
		MCWB	27.1	28.1	30.7	36.6	47.3	54.1	59.9	58.0	51.6	41.6	33.5	31.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.1	35.4	36.9	46.6	57.1	64.7	68.3	66.8	57.9	49.3	43.2	36.2
		MCDB	34.8	36.7	41.6	56.6	68.9	75.3	76.3	76.4	62.1	51.0	44.0	37.0
	2%	WB	32.1	32.7	34.4	42.0	54.3	60.9	65.5	63.3	55.2	46.3	38.6	34.2
		MCDB	32.7	33.4	37.0	48.3	66.0	70.1	73.0	69.9	58.9	48.1	39.6	35.0
	5%	WB	29.8	30.7	32.6	39.2	51.0	58.0	63.3	60.6	53.6	43.8	35.7	32.7
		MCDB	30.5	31.7	34.6	44.8	60.0	65.9	70.7	66.2	57.0	45.2	36.3	33.4
	10%	WB	27.2	28.2	30.9	37.1	47.7	55.9	61.2	58.6	51.9	41.7	33.6	30.9
		MCDB	27.9	29.0	32.8	41.3	55.1	63.1	68.4	64.0	54.7	43.2	34.1	31.6
Mean Daily Temperature Range	5% DB	MDBR	14.2	14.5	18.2	16.4	15.7	16.4	16.6	16.4	13.4	8.7	10.5	12.1
		MCDBR	11.5	9.4	14.5	19.9	24.6	23.3	22.6	22.8	18.3	9.3	7.2	9.0
		MCWBR	11.4	9.0	11.6	12.5	13.2	11.5	10.7	12.1	12.2	7.9	7.0	8.8
	5% WB	MCDBR	11.5	9.4	12.1	17.4	22.5	18.6	19.0	18.5	15.6	8.7	7.1	8.7
		MCWBR	11.3	9.1	10.0	11.3	13.0	10.4	10.4	10.9	11.0	7.9	6.8	8.7
Clear-Sky Solar Irradiance	taub	0.193	0.258	0.293	0.324	0.341	0.341	0.356	0.337	0.311	0.280	0.352	N/A	
	taud	1.922	2.093	2.148	2.199	2.417	2.471	2.449	2.478	2.533	2.333	2.713	N/A	
	Ebn at Noon	59	181	238	262	272	275	266	260	241	179	67	0	
	Edh at Noon	4	16	27	34	30	30	30	26	19	13	5	0	
All-Sky Solar Radiation	RadAvg	21	180	647	1208	1516	1595	1470	1065	566	183	38	0	
	RadStd	1	30	58	101	144	120	154	104	56	32	5	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (25 neighbors)		+1.08	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page