

SALLA KK MYLLYTIE, Finland

WMO: 028490

Lat: 66.834N

Lon: 28.674E

Elev: 222

StdP: 98.69

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.8	-29.6	-35.8	0.1	-32.5	-32.5	0.2	-29.5	8.9	-3.9	7.7	-4.2	0.7	150	0.710

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	24.6	16.5	22.6	15.5	20.7	14.7	18.1	22.4	16.7	20.8	15.6	19.3	3.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.4	12.0	19.9	15.1	11.0	18.6	13.9	10.2	17.0	52.0	22.4	47.7	20.9	44.3	19.2	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.7	5.9	-35.2	26.9	2.6	2.2	-37.0	28.5	-38.6	29.9	-40.0	31.1	-41.9	32.7		
(5)			-35.1	19.5	2.5	1.7	-36.9	20.8	-38.4	21.8	-39.8	22.8	-41.6	24.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.1	-12.9	-12.1	-7.4	-1.0	5.4	11.1	14.5	11.9	6.8	0.2	-6.0	-9.4
	DBStd	10.93	8.24	7.86	6.01	4.87	4.57	3.97	3.56	3.59	3.75	4.65	6.56	7.96
	HDD10.0	3913	708	620	539	331	157	33	6	22	108	305	481	602
	HDD18.3	6650	967	853	798	581	402	219	127	202	347	563	731	861
	CDD10.0	316	0	0	0	0	13	67	145	79	12	0	0	0
	CDD18.3	12	0	0	0	0	0	2	7	2	0	0	0	0
	CDH23.3	119	0	0	0	0	4	26	69	20	0	0	0	0
	CDH26.7	15	0	0	0	0	0	3	9	3	0	0	0	0
	WSAvg	2.7	2.3	2.5	2.9	3.0	3.1	2.9	2.7	2.7	2.8	2.8	2.5	2.6
	PrecAvg	546	36	31	29	29	43	62	75	61	52	49	41	38
(15) Precipitation	PrecMax	786	86	73	54	57	71	100	139	123	123	100	67	73
	PrecMin	427	9	9	8	10	14	17	28	24	9	15	11	10
	PrecStd	86	16	16	14	12	16	25	24	27	27	21	14	14
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.7	2.7	5.9	14.0	23.8	26.5	27.8	25.6	18.3	11.1	6.7	3.0
		MCWB	0.9	1.7	2.5	7.9	12.9	16.5	17.9	18.6	13.3	9.2	6.0	2.1
	2%	DB	0.3	0.9	3.3	10.0	19.6	23.1	25.2	22.8	16.0	9.0	4.3	1.8
		MCWB	-0.2	0.2	0.9	4.9	11.7	14.7	17.2	16.0	12.3	7.7	3.6	1.2
	5%	DB	-0.8	-0.1	1.7	7.7	16.0	20.7	23.2	20.7	14.3	7.5	2.4	0.8
		MCWB	-1.3	-0.6	0.0	3.6	9.7	13.6	16.2	15.1	11.5	6.5	2.0	0.4
	10%	DB	-2.3	-1.6	0.5	5.7	13.5	18.5	21.3	18.6	12.8	6.2	1.2	-0.2
		MCWB	-2.7	-2.1	-0.7	2.5	8.5	12.3	15.5	14.4	10.9	5.3	0.8	-0.6
	0.4%	WB	1.2	1.9	2.7	8.1	14.0	18.2	20.2	19.4	14.4	9.6	6.2	2.3
		MCDB	1.5	2.6	5.3	13.7	20.5	24.1	24.6	24.6	16.7	10.5	6.7	2.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	0.0	0.4	1.3	5.5	12.4	16.0	18.6	17.4	12.9	7.9	3.7	1.2
		MCDB	0.4	0.8	2.8	9.0	18.9	21.2	22.8	21.1	15.0	9.0	4.2	1.7
	5%	WB	-1.2	-0.7	0.3	4.0	10.5	14.5	17.4	15.9	12.0	6.6	2.0	0.4
		MCDB	-0.8	-0.2	1.4	7.1	15.6	18.9	21.5	19.0	13.9	7.3	2.4	0.8
	10%	WB	-2.6	-2.1	-0.6	2.8	8.7	13.3	16.2	14.8	11.0	5.4	0.9	-0.6
		MCDB	-2.3	-1.7	0.4	5.2	12.8	17.3	20.2	17.8	12.6	6.2	1.2	-0.2
	5% DB	MDBR	7.9	8.1	10.1	9.1	8.7	9.1	9.2	9.1	7.5	4.8	5.8	6.7
		MCDBR	6.4	5.2	8.1	11.1	13.7	12.9	12.5	12.6	10.2	5.1	4.0	5.0
		MCWBR	6.3	5.0	6.4	6.9	7.3	6.4	6.0	6.7	6.8	4.4	3.9	4.9
		MCWBR	6.4	5.2	6.7	9.6	12.5	10.4	10.6	10.3	8.6	4.8	3.9	4.9
(35) Mean Daily Temperature Range	5% WB	MCWBR	6.3	5.0	5.5	6.3	7.2	5.8	5.8	6.0	6.1	4.4	3.8	4.8
	taub		0.193	0.258	0.293	0.324	0.341	0.341	0.356	0.337	0.311	0.280	0.352	N/A
		taud	1.922	2.093	2.148	2.199	2.417	2.471	2.449	2.478	2.533	2.333	2.713	N/A
(42) Clear-Sky Solar Irradiance	Ebn at Noon		185	571	750	827	859	867	839	819	760	564	212	0
		Edh at Noon	14	52	85	106	96	94	93	81	61	42	16	0
	RadAvg		0.07	0.57	2.04	3.81	4.78	5.03	4.63	3.36	1.78	0.58	0.12	0.00
(45) All-Sky Solar Radiation	RadStd		0.00	0.10	0.18	0.32	0.46	0.38	0.48	0.33	0.18	0.10	0.02	0.00

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	+0.60	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page