

SIILINKARI FYR, Finland

WMO: 029430

Lat: 61.5176N

Lon: 23.7539E

Elev: 98

StdP: 100.15

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -23.4	(c) -20.2	(d) -25.9	(e) 0.4	(f) -23.1	(g) -22.6	(h) 0.5	(i) -20.0	(j) 14.3	(k) -4.3	(l) 12.4	(m) -1.9	(n) 2.2	(o) 0	(p) 0.709

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.1	25.9	18.4	24.2	17.7	22.4	17.0	20.0	23.6	19.0	23.0	17.7	21.5	4.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.6	22.1	17.4	12.6	21.3	16.1	11.6	19.6	57.7	23.6	54.4	23.2	50.2	21.5	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.5	10.3	9.3	-23.9	27.3	4.7	2.4	-27.3	29.1	-30.0	30.5	-32.6	31.8	-36.0	33.6
			-24.1	21.3	4.6	1.8	-27.4	22.5	-30.2	23.5	-32.8	24.5	-36.1	25.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.5	-6.7	-5.2	-2.1	3.5	10.6	14.5	17.9	16.4	11.9	5.7	1.6	-2.3
	DBStd	9.35	6.38	6.65	4.65	3.39	4.02	3.41	3.34	2.75	3.04	3.23	3.80	5.40
	HDD10.0	2346	519	426	375	196	42	3	0	0	17	136	252	381
	HDD18.3	4728	777	659	633	444	243	122	51	73	192	392	502	639
	CDD10.0	720	0	0	0	1	59	139	245	198	74	3	0	0
	CDD18.3	61	0	0	0	0	2	8	37	13	0	0	0	0
	CDH23.3	242	0	0	0	0	9	37	160	36	0	0	0	0
	CDH26.7	28	0	0	0	0	0	2	22	3	0	0	0	0
(14) Wind	WSAvg	5.0	4.9	4.9	5.0	4.3	4.6	4.8	4.5	4.7	5.0	5.7	5.6	5.6
(15) Precipitation	PrecAvg	566	36	26	29	33	36	51	71	74	60	55	53	42
	PrecMax	863	74	65	60	89	89	169	132	183	112	129	97	91
	PrecMin	402	12	4	1	1	7	16	21	22	6	12	10	7
	PrecStd	97	16	15	16	20	17	33	34	38	25	29	23	20
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.9	5.4	9.1	15.9	24.8	26.6	28.8	26.9	20.4	13.6	10.0	7.9
		MCWB	3.0	2.9	4.5	9.1	14.9	17.2	19.9	19.4	15.9	11.8	9.3	6.9
	2%	DB	2.7	3.6	6.1	13.1	21.7	24.2	26.8	23.9	18.6	12.1	8.6	5.3
		MCWB	2.0	2.3	3.1	7.2	13.7	16.3	19.4	17.9	15.0	10.7	7.9	4.4
	5%	DB	1.6	2.5	4.6	10.6	19.4	21.9	25.0	22.1	17.0	11.3	7.2	4.1
		MCWB	1.1	1.7	2.4	5.8	13.0	15.6	18.6	17.2	14.0	10.0	6.5	3.3
	10%	DB	0.8	1.5	3.2	8.6	17.2	20.1	23.4	20.5	15.9	10.2	6.1	3.1
		MCWB	0.3	0.9	1.5	4.9	11.6	14.8	18.2	16.1	13.6	9.0	5.4	2.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.3	3.5	5.2	9.7	16.1	19.4	21.3	20.8	16.7	12.4	9.5	7.3
		MCDB	3.8	4.3	7.9	14.7	20.6	22.9	25.6	24.7	19.3	13.6	9.9	8.1
	2%	WB	2.1	2.6	3.7	7.8	14.9	17.4	20.5	19.0	15.7	11.4	8.1	4.5
		MCDB	2.5	3.3	5.6	11.5	20.5	22.1	24.5	22.3	17.7	12.1	8.5	5.2
	5%	WB	1.3	1.8	2.8	6.5	13.7	16.4	19.7	17.8	14.9	10.4	6.6	3.4
		MCDB	1.7	2.6	4.2	9.9	18.3	20.9	23.6	21.1	16.6	11.0	7.1	4.0
	10%	WB	0.4	1.1	1.8	5.4	12.2	15.3	18.8	16.9	14.0	9.0	5.6	2.5
		MCDB	0.9	1.6	3.1	8.2	16.3	19.4	23.1	20.0	15.6	10.1	6.1	3.1
(35) Mean Daily Temperature Range	MDBR		5.3	5.1	6.8	7.0	7.5	6.4	6.1	5.4	4.6	3.6	3.1	3.4
	5% DB	MCDBR	3.4	4.5	7.0	10.7	11.0	9.2	7.9	7.2	6.3	4.5	3.9	3.8
		MCWBR	3.3	3.8	4.9	5.9	5.0	4.0	3.4	3.2	3.4	3.6	3.7	3.7
	5% WB	MCDBR	3.2	4.1	5.9	9.5	9.8	8.1	7.1	6.4	5.9	4.3	3.9	3.8
		MCWBR	3.2	3.6	4.5	5.7	5.1	3.9	3.6	3.4	3.6	3.9	3.8	3.7
(40) Clear-Sky Solar Irradiance	taub		0.249	0.294	0.321	0.355	0.351	0.348	0.373	0.359	0.334	0.321	0.273	0.355
	taud		2.084	2.167	2.253	2.377	2.448	2.481	2.430	2.460	2.522	2.413	2.183	2.596
	Ebn at Noon		451	665	789	838	871	880	844	827	786	649	422	299
	Edh at Noon		38	69	90	98	98	97	100	90	71	55	35	23
(44) All-Sky Solar Radiation	RadAvg		0.22	0.78	2.25	3.67	5.00	5.31	5.03	3.93	2.33	0.99	0.26	0.12
	RadStd		0.04	0.18	0.28	0.42	0.54	0.41	0.51	0.44	0.30	0.19	0.05	0.01

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (57 neighbors)		+0.49	N/A	N/A	N/A	N/A	N/A	-134	N/A	N/A	N/A	

Nomenclature: See separate page