

MIKKELI, Finland

WMO: 029470

Lat: 61.689N

Lon: 27.202E

Elev: 100

StdP: 100.13

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -27.7	(c) -24.0	(d) -30.4	(e) 0.2	(f) -27.4	(g) -26.6	(h) 0.3	(i) -24.0	(j) 7.3	(k) -2.2	(l) 6.6	(m) -2.1	(n) 0.5	(o) 270	(p) 0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	27.0	18.7	25.1	17.6	23.3	16.7	20.1	24.8	18.9	23.3	17.8	21.8	2.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	13.4	22.2	17.2	12.4	20.9	16.1	11.6	19.7	58.2	24.8	54.1	23.3	50.5	21.9	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 6.7	(b) 5.9	(c) 5.2	(e) -29.8	(f) 28.9	(g) 3.9	(h) 1.9	(i) -32.7	(j) 30.3	(k) -35.0	(l) 31.4	(m) -37.2	(n) 32.4	(o) -40.0	(p) 33.8		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.8	-8.1	-7.9	-3.7	2.9	9.0	13.6	16.7	14.8	9.7	4.1	-0.4	-5.4		
	DBStd	9.92	7.48	7.21	5.26	3.84	4.23	3.56	3.14	3.06	3.56	4.15	4.66	6.94		
	HDD10.0	2809	562	501	426	214	69	8	1	2	49	187	313	478		
	HDD18.3	5325	820	734	684	462	289	148	70	116	261	443	563	736		
	CDD10.0	557	0	0	0	2	39	115	208	151	39	3	0	0		
	CDD18.3	31	0	0	0	0	1	5	20	6	0	0	0	0		
	CDH23.3	393	0	0	0	0	23	76	222	73	0	0	0	0		
	CDH26.7	63	0	0	0	0	3	8	43	9	0	0	0	0		
(14) Wind	WSAvg	2.2	2.2	2.2	2.3	2.2	2.3	2.2	1.9	1.8	2.0	2.2	2.4	2.5		
(15) Precipitation	PrecAvg	619	47	38	33	33	41	67	80	69	50	61	55	47		
	PrecMax	781	86	79	63	64	118	135	139	138	115	151	115	86		
	PrecMin	493	7	5	2	12	10	17	33	17	11	13	10	15		
	PrecStd	70	20	19	15	15	24	25	30	33	28	30	24	19		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.5	4.2	10.1	19.4	26.0	27.8	30.0	27.7	21.2	14.0	9.2	6.6		
		MCWB	2.8	2.4	4.9	11.3	15.5	18.2	20.2	19.2	16.0	11.8	7.9	6.0		
	2%	DB	2.2	2.8	6.7	15.6	22.8	25.5	27.8	25.2	19.1	12.2	8.0	4.7		
		MCWB	1.8	1.9	3.0	9.1	13.9	17.0	19.4	18.0	14.8	10.7	6.7	4.2		
	5%	DB	1.4	1.7	4.6	12.7	20.2	23.4	25.8	23.4	17.3	11.2	6.8	3.4		
		MCWB	1.1	1.1	1.9	7.0	12.4	16.1	18.7	17.0	13.9	10.0	6.1	2.9		
	10%	DB	0.6	0.8	2.9	10.2	17.9	21.2	23.9	21.6	15.8	10.1	5.5	2.2		
		MCWB	0.4	0.4	1.1	5.8	11.4	14.9	17.7	16.4	13.2	9.2	5.0	1.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.9	3.0	5.6	12.5	17.0	20.3	21.8	21.0	16.8	12.4	8.5	6.2		
		MCDB	3.2	3.5	9.1	17.3	22.6	25.1	27.0	26.1	19.6	13.4	9.0	6.5		
	2%	WB	1.9	2.0	3.6	9.9	15.2	18.6	20.7	19.1	15.6	11.2	7.1	4.2		
		MCDB	2.1	2.6	5.9	14.4	20.7	23.0	25.7	23.3	18.1	12.0	7.6	4.5		
	5%	WB	1.1	1.2	2.4	7.8	13.6	17.1	19.7	18.0	14.6	10.4	6.0	3.0		
		MCDB	1.4	1.6	3.9	11.6	18.9	21.8	24.2	22.1	16.8	11.1	6.5	3.3		
	10%	WB	0.3	0.3	1.4	6.2	11.9	15.7	18.5	17.1	13.6	9.3	4.9	1.9		
		MCDB	0.5	0.6	2.5	9.6	17.0	20.3	22.7	20.5	15.4	10.0	5.4	2.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.0	7.2	9.2	10.1	11.7	10.7	10.6	10.7	9.1	5.7	4.2	5.3		
		MCDBR	3.9	5.1	10.6	14.9	16.6	14.5	13.8	14.1	11.5	6.7	4.7	4.0		
	5% WB	MCWBR	3.8	4.6	7.4	8.7	8.5	7.1	6.3	7.5	7.6	5.3	4.5	4.0		
		MCWBR	4.1	4.6	8.2	13.4	14.3	12.2	12.0	11.8	10.0	5.4	4.5	3.7		
(40) Clear-Sky Solar Irradiance	taub	taub	0.246	0.293	0.320	0.360	0.356	0.353	0.377	0.362	0.338	0.319	0.269	0.358		
		taud	2.055	2.136	2.202	2.337	2.434	2.472	2.422	2.451	2.508	2.408	2.152	2.598		
	Ebn at Noon	Ebn at Noon	441	659	784	829	865	874	839	822	778	647	412	288		
		Edh at Noon	38	70	94	101	100	98	101	90	71	55	34	23		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.22	0.81	2.30	3.70	4.95	5.24	5.11	3.93	2.27	0.93	0.25	0.11		
	RadStd	RadStd	0.04	0.18	0.29	0.40	0.56	0.33	0.52	0.47	0.27	0.16	0.04	0.01		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.69	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (46 neighbors)		+0.51	N/A	N/A	N/A	N/A	N/A	-164	N/A	N/A	N/A

Nomenclature: See separate page