

KUSTAVI ISOKARI, Finland

WMO: 029640

Lat: 60.722N

Lon: 21.027E

Elev: 4

StdP: 101.28

Time Zone: 2.00 (EUE)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.7	-12.3	-18.0	0.8	-15.5	-14.9	1.0	-11.5	17.3	0.0	16.0	0.0	5.6	110	0.830

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.4	23.2	19.6	21.7	18.6	20.4	17.6	20.4	22.5	19.1	21.0	18.1	20.0	5.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.3	21.8	18.4	13.3	20.5	17.2	12.3	19.4	58.7	22.7	54.5	21.0	51.2	20.1	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 16.1	14.2	12.9		-15.4	24.8	4.5	1.9	-18.6	26.1	-21.2	27.2	-23.8	28.3	-27.0	29.7	
(5)			DB	-16.4	20.3	3.8	1.6	-19.1	21.4	-21.3	22.3	-23.5	23.2	-26.3	24.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-1.9	-2.9	-1.0	3.0	8.4	13.0	17.3	17.3	13.5	8.1	4.2	1.3	
	DBStd	7.70	4.33	4.99	3.48	2.26	2.91	2.66	2.63	2.29	2.38	2.78	3.04	3.92	
	HDD10.0	1869	368	362	341	210	66	5	0	0	3	71	173	270	
	HDD18.3	4266	627	596	599	459	307	162	53	48	146	318	423	528	
	CDD10.0	681	0	0	0	1	18	94	225	225	108	11	0	0	
	CDD18.3	36	0	0	0	0	0	1	20	14	0	0	0	0	
	CDH23.3	41	0	0	0	0	0	1	27	13	0	0	0	0	
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0	
Wind	WSAvg	6.9	7.8	6.9	6.8	6.3	5.9	5.8	5.7	6.2	6.9	7.6	8.2	8.4	
Precipitation	PrecAvg	583	50	36	31	29	34	46	55	67	57	66	56	55	
	PrecMax	726	92	86	75	57	89	95	122	145	142	148	137	139	
	PrecMin	433	6	2	2	0	5	10	1	12	7	6	11	5	
	PrecStd	82	23	20	15	15	18	21	34	36	40	33	29	28	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.1	4.2	5.8	12.1	19.2	21.9	25.7	25.2	19.4	14.4	10.1	7.8	
		MCWB	4.4	2.8	3.6	8.1	13.1	16.8	20.9	21.2	16.9	13.2	9.3	6.9	
	2%	DB	4.3	3.2	4.4	8.9	15.7	19.5	23.8	22.8	18.0	13.3	9.3	6.7	
		MCWB	3.7	2.2	2.8	6.0	12.0	15.4	20.0	19.6	15.9	12.2	8.6	5.8	
	5%	DB	3.7	2.6	3.5	7.2	13.8	17.9	22.3	21.5	17.2	12.4	8.7	6.0	
		MCWB	3.0	1.9	2.3	5.1	11.0	14.7	19.3	18.3	15.3	11.3	7.9	5.1	
	10%	DB	3.0	2.0	2.8	5.9	12.3	16.6	21.0	20.3	16.5	11.7	7.8	5.2	
		MCWB	2.3	1.5	1.9	4.2	10.0	13.9	18.2	17.5	14.8	10.5	6.9	4.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.7	3.2	4.2	8.4	14.5	17.8	22.5	22.3	17.6	13.7	9.6	7.2
			MCDB	4.9	3.7	5.5	11.4	17.4	21.1	24.3	23.9	19.0	14.2	9.8	7.5
2%		WB	4.0	2.5	3.1	6.5	12.7	16.1	21.0	20.1	16.5	12.4	8.9	6.2	
		MCDB	4.2	2.9	4.0	8.5	15.0	18.5	23.0	22.3	17.7	13.1	9.3	6.6	
5%		WB	3.2	2.0	2.6	5.4	11.4	15.2	19.7	19.0	15.7	11.7	8.1	5.2	
		MCDB	3.5	2.5	3.3	6.9	13.5	17.2	21.6	20.6	16.9	12.4	8.7	5.8	
10%		WB	2.4	1.5	2.0	4.5	10.3	14.3	18.7	18.0	15.1	10.9	7.1	4.5	
		MCDB	2.9	1.9	2.8	5.7	12.1	16.1	20.7	19.8	16.3	11.6	7.7	5.1	
Mean Daily Temperature Range	5% DB	MDBR	3.1	3.3	3.6	3.8	4.5	4.2	3.8	3.4	2.9	2.5	2.3	2.6	
		MCDBR	2.5	2.3	3.4	5.9	7.3	6.5	5.5	4.4	3.5	2.5	2.1	2.6	
		MCWBR	2.4	2.2	2.5	3.6	4.1	3.3	2.8	2.5	2.4	2.5	2.3	2.6	
	5% WB	MCDBR	2.5	2.3	3.3	5.5	7.0	5.7	4.9	3.8	3.3	2.5	2.1	2.4	
		MCWBR	2.5	2.2	2.6	3.5	4.2	3.3	2.8	2.6	2.5	2.7	2.3	2.5	
Clear-Sky Solar Irradiance	taub	0.272	0.311	0.329	0.368	0.367	0.357	0.386	0.374	0.347	0.330	0.295	0.374		
	taud	2.164	2.248	2.308	2.322	2.416	2.483	2.430	2.450	2.509	2.406	2.206	2.592		
	Ebn at Noon	468	670	792	826	858	873	834	815	778	650	429	317		
	Edh at Noon	40	67	87	104	102	98	101	92	73	58	38	27		
All-Sky Solar Radiation	RadAvg	0.22	0.82	2.37	3.98	5.50	6.07	5.61	4.36	2.63	1.11	0.29	0.13		
	RadStd	0.03	0.15	0.27	0.37	0.46	0.40	0.51	0.38	0.29	0.17	0.06	0.02		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-119	N/A	N/A	N/A

Nomenclature: See separate page