

INKOO BAGASKAR, Finland

WMO: 029840

Lat: 59.931N

Lon: 24.014E

Elev: 39

StdP: 14.68

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.3	5.7	-3.6	4.6	0.6	1.8	6.0	6.1	36.1	29.4	33.5	29.2	11.7	30	0.762

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	75.1	67.4	72.6	65.9	70.2	64.1	68.9	73.5	67.1	71.4	65.1	69.2	10.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	99.5	72.3	65.2	93.2	70.2	63.3	87.2	68.0	33.1	73.8	31.6	71.4	30.1	69.3	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
34.3	30.7	27.5	-1.4	78.7	8.1	4.0	-7.2	81.5	-12.0	83.8	-16.5	86.1	-22.4	89.0		
			-2.4	69.8	8.0	2.7	-8.1	71.8	-12.8	73.3	-17.3	74.8	-23.2	76.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.5	26.4	24.8	29.4	38.2	48.1	56.9	63.8	62.9	55.2	45.2	37.6	32.1	(6)
	DBStd	14.89	8.94	9.80	6.88	4.52	5.65	4.66	5.00	4.24	4.75	6.04	6.46	8.02	(7)
	HDD50	3643	732	705	639	353	104	3	0	0	12	168	371	556	(8)
	HDD65	7926	1197	1125	1104	803	525	244	85	92	295	614	821	1021	(9)
	CDD50	1269	0	0	0	0	44	212	427	400	167	19	0	0	(10)
	CDD65	75	0	0	0	0	0	2	47	26	0	0	0	0	(11)
	CDH74	129	0	0	0	0	0	4	99	26	0	0	0	0	(12)
	CDH80	5	0	0	0	0	0	0	5	0	0	0	0	0	(13)
	WSAvg	13.7	15.3	13.6	13.4	12.3	12.1	12.3	11.6	12.5	13.6	14.8	16.2	17.0	(14)
(15) Precipitation	PrecAvg	22.2	1.8	1.3	1.1	1.0	1.1	1.9	2.2	2.9	1.9	2.5	2.4	1.9	(15)
	PrecMax	29.6	2.8	3.5	2.0	2.3	3.0	3.3	5.0	5.9	3.5	4.2	6.2	3.2	(16)
	PrecMin	17.2	0.2	0.0	0.2	0.2	0.0	0.6	0.2	0.3	0.6	1.3	0.3	0.5	(17)
	PrecStd	2.9	0.6	0.9	0.4	0.6	0.9	0.7	1.3	1.3	0.9	0.8	1.3	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.3	39.5	45.5	54.4	67.6	72.7	80.1	77.0	67.5	58.1	49.8	45.7	(19)
		MCWB	40.4	36.6	39.7	46.2	56.9	62.9	69.5	68.3	61.4	54.9	48.2	44.6	(20)
	2%	DB	39.5	37.1	41.3	49.9	62.8	68.9	76.6	73.9	64.8	56.2	48.6	44.4	(21)
		MCWB	38.5	35.7	37.1	43.8	54.5	60.9	68.3	66.6	60.2	54.0	47.3	43.3	(22)
	5%	DB	37.9	35.9	38.4	46.9	59.3	66.5	74.1	71.7	63.1	54.6	47.3	43.0	(23)
		MCWB	37.0	34.9	35.7	42.4	52.8	59.6	67.0	65.2	59.3	52.8	46.0	41.8	(24)
	10%	DB	36.4	34.9	36.5	44.6	56.4	64.3	71.7	69.4	61.5	53.0	45.8	41.2	(25)
		MCWB	35.4	34.1	34.6	40.7	50.8	58.5	65.7	63.9	58.3	51.3	44.4	39.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.6	37.6	40.4	47.2	59.0	65.6	71.6	70.5	63.1	56.0	48.9	45.0	(27)
		MCDB	40.9	38.4	44.4	52.5	64.5	69.5	77.4	75.3	65.6	57.1	49.3	45.2	(28)
	2%	WB	38.7	36.1	37.7	44.7	56.2	62.7	69.9	68.1	61.5	54.5	47.6	43.6	(29)
		MCDB	39.2	36.7	40.0	48.6	61.0	67.2	74.8	72.1	63.7	55.6	48.3	44.1	(30)
	5%	WB	37.2	35.1	36.2	43.0	53.8	60.8	68.2	66.5	60.1	53.1	46.3	41.9	(31)
		MCDB	37.8	35.7	37.9	46.3	58.2	65.0	73.1	70.4	62.1	54.4	47.2	42.8	(32)
	10%	WB	35.6	34.2	34.9	41.2	51.3	59.1	66.4	64.7	58.8	51.5	44.6	40.1	(33)
		MCDB	36.3	34.8	36.1	44.0	55.7	63.1	70.9	68.5	61.0	52.7	45.5	41.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	7.3	8.8	8.3	9.5	9.7	9.5	8.9	7.7	6.1	5.4	6.2	(35)
		MCDBR	5.4	5.4	9.5	11.9	13.3	12.8	11.9	10.9	9.3	6.5	5.4	4.9	(36)
	5% WB	MCWBR	5.5	5.0	6.8	7.7	7.7	7.2	6.3	6.2	6.1	5.3	5.6	5.0	(37)
		MCWBR	5.1	5.0	8.3	10.8	11.7	11.2	10.4	9.3	8.0	5.7	5.1	4.8	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.278	0.311	0.333	0.368	0.363	0.360	0.386	0.379	0.349	0.334	0.308	0.262	(40)
		taud	2.142	2.199	2.265	2.320	2.408	2.469	2.421	2.435	2.504	2.404	2.221	2.084	(41)
	Ebn at Noon	Ebn at Noon	154	215	251	263	274	277	266	258	248	209	141	110	(42)
		Edh at Noon	14	23	30	33	33	32	32	30	24	19	13	10	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	78	253	731	1237	1715	1796	1711	1340	816	354	97	48	(44)
	RadStd	RadStd	13	46	90	130	177	128	151	134	103	51	17	6	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (58 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	-241	N/A	N/A	N/A

Nomenclature: See separate page