

INKOO BAGASKAR, Finland

WMO: 029840

Lat: 59.931N

Lon: 24.014E

Elev: 12

StdP: 101.18

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.6	-14.6	-19.8	0.7	-17.5	-16.8	0.9	-14.4	16.2	-1.5	15.0	-1.6	5.2	30	0.762

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.3	24.0	19.7	22.6	18.8	21.2	17.9	20.5	23.1	19.5	21.9	18.4	20.7	4.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.2	22.4	18.4	13.3	21.2	17.4	12.5	20.0	59.1	23.2	55.6	21.9	52.1	20.7	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 15.3	13.7	12.3		-18.5	25.9	4.5	2.2	-21.8	27.5	-24.4	28.8	-26.9	30.0	-30.2	31.6	
(5)			DB	-19.1	21.0	4.5	1.5	-22.3	22.1	-24.9	23.0	-27.4	23.8	-30.7	24.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.4	-3.1	-4.0	-1.4	3.5	8.9	13.9	17.7	17.2	12.9	7.3	3.1	0.0
	DBStd	8.27	4.97	5.45	3.82	2.51	3.14	2.59	2.78	2.36	2.64	3.35	3.59	4.46
	HDD10.0	2024	407	392	355	196	58	2	0	0	7	93	206	309
	HDD18.3	4403	665	625	613	446	292	136	47	51	164	341	456	567
	CDD10.0	705	0	0	0	0	24	118	237	222	93	11	0	0
	CDD18.3	42	0	0	0	0	0	1	26	14	0	0	0	0
	CDH23.3	72	0	0	0	0	0	2	55	14	0	0	0	0
	CDH26.7	3	0	0	0	0	0	0	3	0	0	0	0	0
(14) Wind	WSAvg	6.1	6.8	6.1	6.0	5.5	5.4	5.5	5.2	5.6	6.1	6.6	7.2	7.6
(15) Precipitation	PrecAvg	565	46	34	27	26	29	48	56	74	49	64	62	48
	PrecMax	753	71	89	52	58	75	84	128	150	88	106	157	82
	PrecMin	436	6	1	6	5	1	15	4	7	14	32	8	13
	PrecStd	74	16	23	11	16	22	19	33	33	23	21	34	23
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.2	4.2	7.5	12.4	19.8	22.6	26.7	25.0	19.7	14.5	9.9	7.6
		MCWB	4.7	2.5	4.3	7.9	13.8	17.2	20.8	20.2	16.3	12.7	9.0	7.0
	2%	DB	4.1	2.8	5.1	10.0	17.1	20.5	24.8	23.3	18.2	13.4	9.2	6.9
		MCWB	3.6	2.1	2.8	6.5	12.5	16.0	20.2	19.2	15.6	12.2	8.5	6.3
	5%	DB	3.3	2.2	3.5	8.3	15.1	19.2	23.4	22.0	17.3	12.6	8.5	6.1
		MCWB	2.8	1.6	2.1	5.8	11.6	15.3	19.5	18.4	15.1	11.6	7.8	5.4
	10%	DB	2.4	1.6	2.5	7.0	13.6	18.0	22.1	20.8	16.4	11.7	7.7	5.1
		MCWB	1.9	1.2	1.4	4.9	10.5	14.7	18.7	17.7	14.6	10.7	6.9	4.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.8	3.1	4.7	8.5	15.0	18.7	22.0	21.4	17.3	13.3	9.4	7.2
		MCDB	4.9	3.6	6.9	11.4	18.1	20.8	25.2	24.1	18.7	14.0	9.6	7.4
	2%	WB	3.7	2.3	3.2	7.1	13.4	17.1	21.0	20.1	16.4	12.5	8.7	6.4
		MCDB	4.0	2.6	4.4	9.2	16.1	19.5	23.8	22.3	17.6	13.1	9.0	6.7
	5%	WB	2.9	1.7	2.3	6.1	12.1	16.0	20.1	19.2	15.6	11.7	7.9	5.5
		MCDB	3.2	2.0	3.3	8.0	14.6	18.3	22.8	21.3	16.7	12.4	8.4	6.0
	10%	WB	2.0	1.2	1.6	5.1	10.7	15.1	19.1	18.2	14.9	10.9	7.0	4.5
		MCDB	2.4	1.6	2.3	6.7	13.2	17.3	21.6	20.3	16.1	11.5	7.5	5.0
(35) Mean Daily Temperature Range	5% DB	MDBR	3.8	4.0	4.9	4.6	5.3	5.4	5.3	4.9	4.3	3.4	3.0	3.4
		MCDBR	3.0	3.0	5.3	6.6	7.4	7.1	6.6	6.1	5.1	3.6	3.0	2.7
		MCWBR	3.0	2.8	3.8	4.3	4.3	4.0	3.5	3.4	3.4	2.9	3.1	2.8
	5% WB	MCDBR	2.9	2.8	4.6	6.0	6.5	6.2	5.8	5.2	4.4	3.1	2.8	2.7
		MCWBR	3.0	2.7	3.5	4.1	4.2	3.8	3.3	3.2	3.2	2.8	3.0	2.8
(40) Clear-Sky Solar Irradiance	taub		0.278	0.311	0.333	0.368	0.363	0.360	0.386	0.379	0.349	0.334	0.308	0.262
	taud		2.142	2.199	2.265	2.320	2.408	2.469	2.421	2.435	2.504	2.404	2.221	2.084
	Ebn at Noon		485	678	791	830	864	873	837	813	781	659	446	347
	Edh at Noon		44	72	93	105	104	100	102	94	75	60	41	31
(44) All-Sky Solar Radiation	RadAvg		0.25	0.80	2.31	3.90	5.41	5.66	5.39	4.22	2.57	1.12	0.31	0.15
	RadStd		0.04	0.14	0.28	0.41	0.56	0.41	0.48	0.42	0.32	0.16	0.06	0.02

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (58 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	-134	N/A	N/A	N/A

Nomenclature: See separate page