

SCATSTA, United Kingdom

WMO: 030064

Lat: 60.433N

Lon: 1.296W

Elev: 81

StdP: 14.65

Time Zone: 0.00 (EUW)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	26.6	29.2	21.1	15.8	29.7	23.3	17.6	32.1	42.5	41.1	40.2	42.7	3.7	190	0.847

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.0	64.8	59.5	62.5	58.0	60.7	57.0	60.3	63.7	58.9	61.7	57.4	60.0	16.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.0	74.8	62.0	57.3	70.4	60.1	55.8	66.4	58.5	26.8	64.1	25.5	61.8	24.7	59.6	66.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.1	33.0	29.4	DB	22.1	70.3	3.0	2.7	19.9	72.2	18.1	73.7	16.4	75.2	14.2	77.2	(4)
(5)			WB	21.8	63.9	3.4	2.0	19.3	65.4	17.4	66.5	15.5	67.7	13.0	69.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.3	39.1	38.9	41.2	43.8	47.2	51.1	55.2	55.1	52.5	47.7	42.7	41.1
	DBStd	7.09	4.72	4.48	4.30	4.29	4.27	3.45	3.56	3.04	3.43	3.88	4.56	4.94
	HDD50	1851	337	310	274	190	107	25	2	2	16	90	220	278
	HDD65	6811	802	730	739	637	553	418	305	306	375	535	669	742
	CDD50	516	0	0	0	3	19	58	162	161	91	20	1	1
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	15.1	16.7	16.0	16.0	15.2	13.8	12.9	12.6	12.9	15.1	15.8	16.1	17.7
Precipitation	PrecAvg	46.0	5.8	4.5	4.2	2.5	2.4	2.2	2.4	3.3	3.7	4.6	5.1	5.4
	PrecMax	55.7	11.3	7.0	7.6	4.3	5.0	4.2	5.1	6.5	5.5	7.0	7.8	9.4
	PrecMin	38.7	1.9	2.0	1.4	0.9	0.4	0.4	0.9	1.5	1.1	1.9	2.2	2.1
	PrecStd	4.7	2.1	1.3	1.2	0.7	1.0	1.0	1.0	1.2	1.1	1.3	1.3	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	52.0	50.7	57.1	66.3	68.3	69.8	65.9	63.0	57.4	53.7	52.2
		MCWB	49.1	48.3	47.9	51.3	58.2	59.9	63.6	59.9	57.9	54.4	51.8	50.1
	2%	DB	48.5	48.6	49.7	53.7	60.4	61.1	66.0	62.9	59.4	55.6	52.0	50.4
		MCWB	47.4	47.1	47.4	48.8	54.3	56.2	61.2	58.6	55.9	53.0	50.1	49.1
	5%	DB	48.0	47.2	48.3	51.6	55.8	57.6	62.7	61.1	58.7	54.0	50.4	50.0
		MCWB	46.8	45.9	46.9	47.8	51.2	53.4	58.4	57.6	55.4	51.6	48.9	48.8
	10%	DB	46.3	46.2	46.8	49.9	53.6	56.5	60.8	59.9	57.3	53.5	49.7	48.4
		MCWB	45.1	44.8	45.2	46.9	49.5	52.6	57.1	56.6	54.7	51.2	48.2	47.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.4	49.3	49.0	51.6	58.9	60.4	64.0	61.1	59.6	55.4	52.6	51.1
		MCDB	49.8	50.2	49.8	55.6	66.0	67.3	68.6	63.9	62.7	57.3	53.8	52.4
	2%	WB	47.5	47.3	47.8	49.9	54.6	56.8	61.7	59.4	57.3	53.9	50.8	49.5
		MCDB	48.0	48.4	48.4	52.2	58.9	61.0	65.0	62.0	59.1	55.6	51.8	50.2
	5%	WB	46.2	45.8	46.8	48.5	52.1	54.9	59.5	58.4	56.2	52.9	49.4	48.6
		MCDB	47.2	47.0	47.8	50.3	55.4	57.7	62.1	60.9	58.2	54.5	50.4	49.3
	10%	WB	44.7	44.2	45.4	47.4	50.3	53.4	57.5	57.3	55.2	51.7	47.8	47.0
		MCDB	45.9	45.4	46.6	49.2	52.6	55.9	60.0	59.7	57.4	53.5	49.0	48.2
Mean Daily Temperature Range	5% DB	MDBR	6.9	7.5	7.8	9.0	9.7	8.8	8.5	9.0	7.6	8.0	7.0	7.6
		MCDBR	7.8	7.7	7.5	10.1	13.3	11.3	11.3	9.7	8.9	7.7	7.1	8.2
		MCWBR	8.0	7.3	7.2	7.2	9.2	7.8	7.3	7.0	6.8	6.8	7.4	8.7
	5% WB	MCDBR	7.4	7.7	7.0	8.6	12.8	10.5	11.4	9.0	8.0	6.3	6.8	7.8
		MCWBR	8.0	7.8	7.2	6.8	9.3	7.6	7.9	7.1	6.8	6.1	7.5	8.6
Clear-Sky Solar Irradiance	taub	0.335	0.355	0.369	0.383	0.373	0.366	0.380	0.367	0.363	0.347	0.329	0.413	
	taud	2.078	2.197	2.270	2.295	2.393	2.453	2.430	2.468	2.436	2.318	2.133	2.395	
	Ebn at Noon	119	193	236	257	271	274	267	262	240	197	120	79	
	Edh at Noon	15	23	30	34	33	32	32	29	25	20	14	10	
All-Sky Solar Radiation	RadAvg	71	230	573	1066	1487	1539	1389	1130	684	342	104	45	
	RadStd	7	26	40	63	92	164	121	108	62	35	10	3	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (20 neighbors)	+0.61	+0.90	+1.30	N/A	N/A	N/A	-167	-221	N/A	N/A	

Nomenclature: See separate page