

SULE SKERRY, United Kingdom

WMO: 030100

Lat: 59.084N

Lon: 4.407W

Elev: 39

StdP: 14.68

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	34.8	36.4	26.0	20.0	38.5	28.1	22.0	38.8	52.4	42.8	49.0	43.4	22.2	230	0.926

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.4	62.0	59.6	60.5	58.4	59.1	57.3	60.2	61.6	59.1	60.4	58.0	59.1	14.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.4	75.8	61.1	58.3	72.8	59.9	57.3	70.2	58.8	26.7	61.9	25.8	60.6	25.1	59.2	69.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 45.6	41.3	36.8	DB	32.1	64.2	2.8	3.4	30.0	66.7	28.4	68.7	26.8	70.6	24.8	73.0	(4)
(5)			WB	29.2	63.0	2.2	3.4	27.6	65.4	26.3	67.4	25.1	69.3	23.5	71.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.9	43.9	42.9	43.6	45.7	48.2	51.7	55.1	56.2	54.6	51.4	47.7	45.0
	DBStd	5.52	3.09	3.28	3.53	3.00	2.95	2.37	2.44	2.35	2.69	3.01	3.74	3.73
	HDD50	1060	189	200	197	130	70	9	0	0	2	21	84	158
	HDD65	5886	654	620	662	578	522	398	307	273	312	421	518	621
	CDD50	649	0	0	0	2	13	61	158	192	140	65	15	3
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	19.1	24.4	23.1	21.5	18.4	16.1	14.3	13.0	13.8	16.3	22.1	23.1	23.2
Precipitation	PrecAvg	51.8	5.8	4.7	4.5	3.2	3.0	3.0	3.0	3.6	4.3	5.4	5.7	5.8
	PrecMax	65.4	10.2	8.8	9.4	4.8	5.8	4.9	4.9	6.7	10.8	9.8	8.3	9.8
	PrecMin	40.6	1.5	1.7	1.7	1.6	0.6	1.3	1.5	1.4	1.6	2.2	1.8	1.5
	PrecStd	5.9	2.4	1.9	1.8	0.9	1.2	1.0	1.0	1.3	1.7	1.7	1.6	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.5	51.6	51.5	53.2	56.5	59.3	63.1	65.0	63.2	58.6	57.9	54.0
		MCWB	49.5	49.3	49.1	50.9	54.2	56.7	60.5	62.2	60.5	55.9	56.2	51.9
	2%	DB	50.2	50.0	49.8	51.3	54.2	57.2	61.0	62.5	60.9	57.1	54.8	52.6
		MCWB	48.4	48.3	48.1	49.3	52.1	55.1	58.5	60.0	59.0	54.9	53.0	50.9
	5%	DB	49.3	48.6	48.8	50.3	52.8	55.8	59.7	60.9	59.0	56.0	53.7	51.3
		MCWB	47.6	47.0	47.2	48.4	51.0	53.8	57.5	58.9	57.3	54.1	52.0	49.6
	10%	DB	48.4	47.5	47.9	49.4	51.8	54.8	58.4	59.2	57.8	55.2	52.6	50.1
		MCWB	46.8	45.8	46.4	47.7	50.1	53.0	56.6	57.5	56.3	53.4	50.8	48.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.1	50.3	49.7	51.7	54.8	57.4	61.3	62.9	61.2	57.0	56.6	52.8
		MCDB	50.9	51.3	50.4	52.8	56.1	58.6	62.7	64.7	62.8	57.9	57.7	53.6
	2%	WB	48.9	48.6	48.6	49.8	52.5	55.6	59.3	60.8	59.5	55.7	53.7	51.3
		MCDB	49.8	49.5	49.5	50.9	53.7	56.7	60.5	62.2	60.9	56.4	54.5	52.3
	5%	WB	48.0	47.4	47.7	48.8	51.4	54.4	58.2	59.5	58.1	54.8	52.4	50.0
		MCDB	49.0	48.4	48.6	49.9	52.5	55.5	59.3	60.8	59.1	55.6	53.4	51.2
	10%	WB	47.0	46.2	46.7	48.1	50.4	53.4	57.1	58.4	56.9	54.0	51.2	48.6
		MCDB	48.3	47.4	47.9	49.1	51.5	54.4	58.3	59.6	57.7	55.0	52.5	50.0
Mean Daily Temperature Range	5% DB	MDBR	4.5	4.5	4.0	3.8	3.8	3.6	3.7	3.4	3.7	4.0	4.5	4.8
		MCDBR	5.4	5.4	4.4	4.3	4.6	4.6	5.1	4.6	4.5	4.6	5.0	5.7
		MCWBR	5.9	5.7	4.5	4.0	4.3	4.2	4.6	4.1	4.1	5.0	5.6	6.3
	5% WB	MCDBR	5.3	5.4	4.4	4.1	4.4	4.6	5.0	4.4	4.4	4.7	4.9	5.4
		MCWBR	6.0	5.8	4.7	4.1	4.3	4.4	4.7	4.0	4.3	5.4	5.6	6.3
Clear-Sky Solar Irradiance	taub	0.334	0.353	0.368	0.386	0.378	0.372	0.381	0.370	0.363	0.348	0.329	0.317	
	taud	2.131	2.244	2.305	2.309	2.396	2.454	2.444	2.478	2.462	2.358	2.188	2.089	
	Ebn at Noon	138	204	242	259	271	274	268	263	244	206	140	101	
	Edh at Noon	16	23	29	34	34	32	32	29	25	21	15	12	
All-Sky Solar Radiation	RadAvg	93	274	628	1118	1522	1522	1403	1158	747	370	132	60	
	RadStd	11	31	43	87	119	124	111	77	51	33	13	6	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page