

HYSKEIR LH, United Kingdom

WMO: 030240

Lat: 56.967N

Lon: 6.683W

Elev: 33

StdP: 14.68

Time Zone: 0.00 (EUW)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	35.6	37.0	26.6	20.6	38.4	28.5	22.5	38.8	61.7	44.7	56.9	44.7	17.9	90	0.893

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.6	65.4	60.4	63.0	59.0	60.9	57.7	61.2	64.4	59.5	62.0	58.3	60.3	7.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.7	76.4	62.6	58.3	72.8	60.8	57.3	70.0	59.5	27.2	64.6	26.1	62.4	25.3	60.5	68.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
51.1	46.3	40.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			30.4	62.9	3.4	2.8	28.0	64.9	26.0	66.5	24.1	68.1	21.6	70.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.3	43.2	43.0	43.3	46.0	50.8	53.6	56.6	56.5	54.3	50.8	47.7	45.3	
	DBStd	5.84	3.20	3.09	2.91	2.65	4.07	3.24	3.04	2.35	2.38	3.35	3.07	3.07	
	HDD50	1034	211	196	207	121	35	4	0	0	1	32	81	146	
	HDD65	5729	676	616	672	570	440	342	261	263	321	439	520	609	
	CDD50	782	0	0	0	1	60	112	205	203	131	58	11	1	
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0	
	CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	19.0	24.9	23.3	22.4	17.4	14.6	13.7	13.3	15.0	18.1	20.5	22.9	22.5	
Precipitation	PrecAvg	77.5	9.2	6.8	6.3	4.6	3.9	3.9	4.9	5.7	6.7	8.4	8.4	8.7	
	PrecMax	102.4	15.2	15.0	12.4	7.4	9.8	7.6	7.3	12.8	12.4	15.2	13.5	14.1	
	PrecMin	57.2	3.7	2.1	2.0	1.9	1.3	1.1	1.5	1.9	2.2	2.2	4.8	2.0	
	PrecStd	10.6	2.8	3.5	2.5	1.6	1.9	1.5	1.4	2.2	2.7	3.4	2.4	3.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.9	50.1	50.1	54.9	66.5	66.5	70.8	67.3	63.0	58.4	54.5	53.1	
		MCWB	49.7	48.7	48.3	50.5	58.2	60.5	63.8	62.5	59.1	55.0	52.2	51.9	
	2%	DB	49.7	48.9	49.1	52.3	62.0	63.2	65.7	63.6	60.3	56.8	53.5	51.7	
		MCWB	48.4	47.8	47.5	48.8	55.8	58.3	61.3	60.3	57.0	53.7	51.9	50.3	
	5%	DB	48.6	48.2	48.2	50.6	58.7	60.3	63.0	61.2	58.9	55.8	52.7	50.8	
		MCWB	47.2	47.0	46.8	48.0	53.9	56.5	59.4	58.5	56.3	53.3	51.0	49.4	
	10%	DB	47.7	47.2	47.3	49.4	56.2	58.1	60.9	59.7	57.8	54.9	51.9	50.0	
		MCWB	46.2	45.8	46.0	47.2	52.3	54.9	58.1	57.3	55.4	52.7	50.1	48.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.4	49.0	49.2	51.3	59.9	60.9	64.7	63.6	60.1	55.8	53.4	52.6
			MCDB	50.6	49.3	49.4	53.6	65.9	65.9	69.7	67.0	62.4	57.2	53.6	52.8
2%		WB	48.9	48.2	48.1	49.6	56.3	58.5	61.7	60.8	58.3	54.7	52.5	50.7	
		MCDB	49.4	48.6	48.6	51.4	61.1	62.4	65.1	63.2	59.4	55.8	53.2	51.1	
5%		WB	47.7	47.4	47.2	48.6	54.2	56.7	59.9	59.2	57.1	54.0	51.5	50.0	
		MCDB	48.4	47.9	47.9	49.9	58.0	59.7	62.5	60.7	58.4	55.2	52.6	50.4	
10%		WB	46.6	46.3	46.5	47.8	52.6	55.3	58.4	58.1	55.9	53.3	50.4	49.0	
		MCDB	47.5	47.1	47.2	49.0	55.6	57.5	60.5	59.4	57.2	54.7	51.7	49.9	
Mean Daily Temperature Range		5% DB	MDBR	4.2	3.8	4.4	5.2	6.5	5.7	5.2	4.6	4.7	4.1	3.6	4.0
			MCDBR	5.2	3.7	4.4	6.7	10.4	9.4	8.7	6.9	6.3	4.5	4.0	4.4
	MCWBR		6.0	4.3	4.7	5.2	7.0	6.2	5.8	5.1	4.9	4.3	4.8	5.3	
	5% WB	MCDBR	5.1	3.3	4.4	5.7	9.6	8.3	8.3	6.1	5.7	3.9	3.9	4.2	
		MCWBR	6.0	4.2	4.9	5.0	6.7	5.8	5.9	4.9	5.3	4.8	5.1	5.5	
Clear-Sky Solar Irradiance	taub	0.352	0.358	0.374	0.385	0.388	0.376	0.379	0.369	0.369	0.353	0.338	0.333		
	taud	2.143	2.253	2.292	2.318	2.365	2.440	2.443	2.478	2.448	2.377	2.221	2.125		
	Ebn at Noon	153	214	245	263	270	274	271	266	247	216	160	125		
	Edh at Noon	19	25	31	35	35	33	32	30	26	22	17	15		
All-Sky Solar Radiation	RadAvg	125	325	701	1217	1594	1628	1494	1199	790	412	166	84		
	RadStd	13	31	51	82	119	162	103	79	43	41	15	10		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page