

SKYE LUSA, United Kingdom

WMO: 030370

Lat: 57.250N

Lon: 5.800W

Elev: 18

StdP: 101.11

Time Zone: 0.00 (EUW)

Period: 98-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.0	-1.7	-5.7	2.3	0.0	-4.3	2.6	0.4	16.0	6.1	14.5	6.0	1.4	120	0.651

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.6	21.2	15.9	19.3	15.1	17.8	14.3	17.0	19.8	15.9	18.1	15.1	17.0	3.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.7	11.2	17.9	14.9	10.6	16.8	14.1	10.1	16.0	47.6	19.8	44.6	18.2	42.2	17.0	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.2	11.3	9.8	DB	-4.1	24.7	1.4	2.0	-5.1	26.2	-6.0	27.4	-6.8	28.5	-7.8	30.0	(4)
(5)			WB	-4.6	18.7	1.4	1.2	-5.6	19.6	-6.4	20.3	-7.2	21.0	-8.2	21.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	5.0	4.9	6.1	7.7	9.9	12.2	13.8	13.8	12.6	9.8	7.1	5.1		
	DBStd	4.13	2.70	2.41	2.44	2.57	2.49	2.16	1.93	1.94	2.10	2.47	2.71	3.29		
	HDD10.0	814	154	142	123	77	31	4	0	1	4	34	91	153		
	HDD18.3	3402	413	376	380	319	261	183	142	142	173	266	337	410		
	CDD10.0	457	0	0	1	8	29	72	117	117	81	27	4	1		
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0		
	CDH23.3	17	0	0	0	0	1	3	5	7	0	0	0	0		
	CDH26.7	1	0	0	0	0	0	0	1	1	0	0	0	0		
	WSAvg	4.1	4.8	4.6	4.6	4.1	3.9	3.8	3.6	3.6	3.8	4.0	4.4	4.6		
(15) Precipitation	PrecAvg	1829	212	158	144	100	110	94	102	124	162	200	207	214		
	PrecMax	2195	292	380	226	198	265	171	197	233	284	349	290	361		
	PrecMin	1178	83	27	32	41	20	32	40	50	49	58	111	33		
	PrecStd	262	60	84	53	38	57	33	36	51	74	79	53	97		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	11.5	15.0	18.8	22.1	22.6	23.6	24.1	20.8	17.5	14.5	13.1		
		MCWB	9.5	8.9	10.5	12.3	14.2	16.0	18.1	18.7	15.5	13.5	12.0	11.3		
	2%	DB	10.5	10.2	11.9	15.1	18.4	19.3	20.7	20.3	18.6	15.8	12.7	11.8		
		MCWB	9.3	8.9	9.0	10.0	12.8	14.4	16.5	16.2	14.7	12.8	10.8	10.6		
	5%	DB	9.7	9.5	10.6	13.3	15.9	17.2	18.8	18.2	17.1	14.5	11.9	10.8		
		MCWB	8.8	8.3	8.6	9.6	11.7	13.7	15.5	15.1	14.1	12.2	10.5	9.8		
	10%	DB	8.9	8.7	9.7	11.7	14.0	15.8	17.1	16.9	15.9	13.5	11.1	9.9		
		MCWB	8.0	7.5	8.1	9.0	10.8	12.9	14.4	14.4	13.6	11.6	9.8	8.9		
	0.4%	WB	10.5	10.2	11.0	12.7	15.3	16.5	18.8	19.0	16.9	14.6	13.3	11.9		
		MCDB	10.8	10.5	13.2	17.1	20.3	20.9	23.2	22.1	19.3	15.9	14.3	12.5		
	2%	WB	9.8	9.4	9.9	11.2	13.4	15.1	17.1	16.9	15.6	13.6	11.6	10.8		
		MCDB	10.3	9.9	11.0	13.6	17.1	18.2	19.9	19.3	17.3	15.0	12.3	11.4		
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	9.0	8.7	9.1	10.2	12.2	14.2	15.9	15.7	14.7	12.8	10.7	10.0		
		MCDB	9.6	9.4	10.3	12.3	15.1	16.6	18.1	17.5	16.3	14.1	11.6	10.7		
	10%	WB	8.1	7.7	8.4	9.4	11.2	13.4	14.9	14.8	14.0	11.9	9.9	8.9		
		MCDB	8.9	8.6	9.6	11.4	13.4	15.4	16.6	16.4	15.4	13.2	11.0	9.9		
		MDBR	4.3	5.0	5.9	6.8	6.9	6.2	5.6	5.9	5.8	5.5	4.8	4.7		
		MCDBR	4.4	5.2	6.7	9.3	10.4	8.6	8.7	8.5	7.6	6.4	5.1	5.1		
(36) Mean Daily Temperature Range	5% DB	MCWBR	4.4	4.5	4.8	5.4	5.9	4.9	5.1	5.1	4.7	4.6	4.6	5.0		
		MCDBR	4.1	4.4	5.9	7.8	8.8	7.6	7.9	7.6	6.4	5.6	5.0	5.1		
	5% WB	MCWBR	4.4	4.3	4.8	5.0	5.5	4.8	5.1	5.3	4.7	4.7	4.9	5.4		
(40) Clear-Sky Solar Irradiance	taub		0.345	0.353	0.372	0.385	0.389	0.379	0.382	0.368	0.365	0.348	0.332	0.329		
	taud		2.136	2.238	2.265	2.285	2.326	2.396	2.400	2.447	2.436	2.375	2.222	2.108		
	Ebn at Noon		481	674	772	826	846	861	849	838	781	681	502	383		
	Edh at Noon		58	79	99	113	115	109	107	95	84	68	52	45		
(44) All-Sky Solar Radiation	RadAvg		0.38	0.99	2.05	3.49	4.64	4.58	4.29	3.42	2.33	1.23	0.51	0.27		
	RadStd		0.05	0.12	0.17	0.26	0.37	0.47	0.39	0.24	0.16	0.14	0.05	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page