

BEALACH NA BA, United Kingdom

WMO: 030390

Lat: 57.4181N

Lon: 5.6886W

Elev: 773

StdP: 92.38

Time Zone: 0.00 (EUW)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.8	-4.9	-12.7	1.4	0.1	-9.3	1.9	-1.9	46.3	0.9	42.2	1.3	10.6	100	1.157

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.4	17.1	12.7	15.4	11.8	13.7	10.7	14.1	15.8	12.8	14.3	11.7	13.1	4.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.4	10.5	14.6	12.2	9.7	13.3	11.1	9.0	12.0	41.9	15.8	38.5	14.5	35.6	13.3	18.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.8	31.7	26.1	DB	-6.4	20.0	1.5	1.9	-7.5	21.3	-8.4	22.4	-9.3	23.4	-10.4	24.8	(4)
(5)			WB	-7.7	15.5	1.6	2.4	-8.8	17.2	-9.7	18.6	-10.6	19.9	-11.7	21.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.1	0.0	-0.1	0.9	2.9	5.1	7.4	9.1	8.7	7.4	4.7	2.2	0.9	(6)
(7)		DBStd	4.33	2.46	2.68	3.05	3.23	3.51	3.01	2.91	2.24	2.45	2.63	2.64	2.75	(7)
(8)		HDD10.0	2216	309	283	283	216	161	90	52	54	85	164	235	283	(8)
(9)		HDD18.3	5190	568	517	541	464	412	327	285	300	329	422	485	542	(9)
(10)		CDD10.0	68	0	0	1	2	7	13	26	13	6	1	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	10.9	13.8	12.3	12.5	10.1	8.7	8.3	8.2	9.2	10.2	10.6	12.9	14.1	(14)
(15)	Precipitation	PrecAvg	1972	232	189	175	118	111	98	106	129	163	207	211	230	(15)
(16)		PrecMax	2639	377	405	440	207	286	174	198	254	293	375	330	399	(16)
(17)		PrecMin	1219	72	31	30	46	16	35	47	51	39	59	91	42	(17)
(18)		PrecStd	313	79	100	80	42	54	34	33	56	72	82	67	103	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.7	7.9	11.8	14.7	17.6	18.7	19.6	18.7	16.1	12.9	10.0	8.9	(19)
(20)			MCWB	6.2	6.4	9.5	7.4	12.5	11.5	13.5	15.7	11.6	9.9	8.6	6.4	(20)
(21)		2%	DB	5.7	5.7	8.9	11.3	14.8	16.0	17.1	15.0	13.6	10.9	8.1	7.3	(21)
(22)			MCWB	5.2	4.8	4.9	6.8	9.9	11.5	13.7	12.7	10.6	9.7	7.4	6.1	(22)
(23)		5%	DB	4.9	4.7	6.3	8.6	12.3	13.7	15.3	13.2	11.8	9.7	6.9	6.3	(23)
(24)			MCWB	4.3	4.1	5.0	6.0	8.0	10.0	12.9	11.8	10.2	8.6	6.6	5.7	(24)
(25)		10%	DB	4.0	3.7	4.8	7.0	10.1	11.7	13.4	11.8	10.7	8.5	5.9	5.2	(25)
(26)			MCWB	3.7	2.9	4.1	5.5	7.3	9.1	11.5	10.6	9.8	7.7	5.5	4.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.3	6.7	11.1	8.9	14.8	13.2	15.7	16.3	13.6	11.2	9.3	7.7	(27)
(28)			MCDWB	6.4	7.2	12.2	11.3	16.8	16.0	16.7	17.9	15.1	11.6	9.7	7.8	(28)
(29)		2%	WB	5.5	5.3	6.7	7.9	11.0	12.1	14.3	13.6	11.6	10.1	7.9	6.6	(29)
(30)			MCDWB	5.6	5.8	7.5	9.7	14.0	15.0	16.0	14.5	12.2	10.7	8.1	6.7	(30)
(31)		5%	WB	4.6	4.5	5.4	6.8	9.2	10.8	13.1	12.3	10.7	9.0	6.7	5.6	(31)
(32)			MCDWB	4.7	4.7	6.0	8.2	11.3	13.4	14.8	13.0	11.3	9.3	6.9	5.9	(32)
(33)		10%	WB	3.6	3.2	4.1	5.6	8.0	9.6	11.8	11.0	9.9	7.8	5.7	4.5	(33)
(34)			MCDWB	3.7	3.5	4.6	6.9	10.0	11.3	13.2	11.7	10.5	8.3	5.9	4.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.2	3.0	3.2	3.7	4.1	3.8	3.4	3.1	3.3	3.2	3.1	3.4	(35)
(36)			MCDBR	4.6	4.1	4.7	5.9	6.4	5.8	5.4	4.7	4.4	4.8	4.8	5.3	(36)
(37)			MCWBR	4.5	3.8	3.8	3.8	4.4	4.2	4.3	3.9	4.0	4.5	4.8	5.0	(37)
(38)		5% WB	MCDWB	4.5	4.2	4.4	5.2	5.8	5.2	4.7	4.4	4.2	5.1	4.9	5.1	(38)
(39)			MCWBR	4.5	4.1	4.1	3.8	4.7	4.3	4.1	4.0	4.1	4.8	4.8	5.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.294	0.310	0.326	0.337	0.340	0.333	0.336	0.325	0.321	0.309	0.286	0.274	(40)	
(41)		taud	2.203	2.350	2.400	2.417	2.445	2.487	2.485	2.524	2.533	2.479	2.284	2.132	(41)	
(42)		Ebn at Noon	557	741	833	880	898	907	896	885	836	741	573	457	(42)	
(43)		Edh at Noon	52	69	86	98	102	99	97	87	75	60	47	41	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.38	0.98	2.02	3.42	4.58	4.50	4.22	3.36	2.31	1.22	0.51	0.26	(44)	
(45)		RadStd	0.05	0.12	0.17	0.26	0.36	0.46	0.41	0.23	0.17	0.14	0.05	0.03	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page