

AONACH MOR, United Kingdom

WMO: 030410

Lat: 56.822N

Lon: 4.969W

Elev: 1130

StdP: 88.47

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.1	-8.2	-16.9	1.0	0.1	-12.6	1.5	-1.6	29.8	0.3	27.7	-0.2	8.9	30	1.243

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.9	16.0	11.9	14.0	10.4	12.5	10.0	13.0	14.4	11.7	12.8	10.8	11.9	7.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.5	10.3	13.3	11.3	9.6	12.1	10.3	8.9	11.2	40.2	14.4	36.7	12.9	34.3	12.0	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
32.6	26.1	22.3	-10.5	17.7	1.2	2.1	-11.4	19.2	-12.2	20.5	-12.9	21.7	-13.8	23.3
			-10.9	13.8	1.3	1.6	-11.8	15.0	-12.6	15.9	-13.3	16.8	-14.2	18.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.0	-2.1	-2.7	-1.4	0.3	2.6	5.3	7.6	7.4	5.6	2.8	-0.1	-1.5
	DBStd	4.84	3.01	3.11	3.51	3.46	4.01	3.26	3.29	2.76	2.83	2.91	3.04	3.51
	HDD10.0	2954	374	354	353	292	233	147	91	92	134	224	304	356
	HDD18.3	5956	633	588	611	542	488	392	332	339	381	482	554	614
	CDD10.0	41	0	0	0	1	4	5	17	11	3	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	10.8	12.9	12.1	11.4	10.0	9.5	9.6	9.3	9.2	10.1	11.6	11.9	12.6
Precipitation	PrecAvg	2008	268	194	182	113	102	97	108	122	154	207	213	246
	PrecMax	2603	496	432	449	196	262	177	180	282	310	368	388	551
	PrecMin	1335	88	57	35	55	21	35	47	24	40	63	96	29
	PrecStd	326	104	113	96	38	57	36	33	54	69	90	77	138
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	6.9	10.1	12.4	16.1	16.5	19.4	17.8	15.0	11.3	8.5	8.8
		MCWB	6.9	6.5	5.3	8.4	9.8	12.8	13.6	12.4	8.8	8.4	4.9	5.6
	2%	DB	5.3	4.9	7.6	9.2	12.7	13.5	16.3	15.0	12.6	9.5	6.7	6.2
		MCWB	4.3	3.9	3.8	5.1	8.6	10.2	12.4	10.7	9.2	8.1	5.6	5.1
	5%	DB	3.7	3.4	5.0	6.7	10.5	11.6	14.1	12.9	11.1	8.2	5.5	4.9
		MCWB	2.9	2.6	3.2	4.5	6.8	9.3	11.3	10.8	9.3	7.5	5.0	4.4
	10%	DB	2.5	1.9	3.3	5.0	8.2	10.1	12.4	11.4	9.7	7.0	4.3	3.6
		MCWB	1.8	1.5	2.6	3.3	5.7	8.5	10.5	10.1	8.3	6.4	4.0	3.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	6.9	6.6	9.7	11.7	14.6	15.5	13.9	12.4	10.3	7.6	6.9
		MCDB	7.6	6.9	6.9	12.0	13.9	15.4	17.3	16.2	13.1	10.4	7.8	6.9
	2%	WB	4.6	4.8	4.9	6.8	9.8	11.2	13.4	12.1	10.9	8.7	6.1	5.4
		MCDB	4.9	4.8	6.8	7.8	12.5	12.3	15.0	13.1	11.5	8.9	6.2	5.5
	5%	WB	3.2	3.1	3.7	5.1	7.7	10.0	12.1	11.2	9.8	7.6	4.9	4.3
		MCDB	3.4	3.2	4.7	6.2	9.6	11.0	13.3	12.2	10.3	7.9	5.1	4.5
	10%	WB	1.8	1.6	2.5	3.7	6.1	8.7	10.9	10.2	8.5	6.4	3.8	2.9
		MCDB	2.0	1.7	3.3	4.4	7.9	9.7	12.1	11.1	9.2	6.7	4.0	3.1
Mean Daily Temperature Range	5% DB	MDBR	4.0	3.8	4.0	4.2	4.5	4.2	3.9	3.6	3.7	3.6	3.6	4.1
		MCDBR	6.4	5.3	6.1	6.0	6.4	5.4	5.8	5.1	5.2	5.6	5.9	5.9
		MCWBR	6.1	5.1	5.1	4.6	4.7	4.6	4.9	4.4	4.8	5.0	5.7	6.0
	5% WB	MCDBR	6.3	5.3	5.6	5.1	5.6	4.7	4.8	4.4	5.1	5.3	5.5	6.1
		MCWBR	6.2	5.4	5.2	4.6	4.7	4.7	4.7	4.5	5.1	5.2	5.5	6.1
Clear-Sky Solar Irradiance	taub	0.273	0.290	0.308	0.320	0.324	0.321	0.322	0.310	0.303	0.293	0.270	0.255	
	taud	2.258	2.403	2.426	2.430	2.450	2.480	2.476	2.522	2.549	2.522	2.347	2.182	
	Ebn at Noon	618	783	861	901	916	921	912	904	862	776	628	524	
	Edh at Noon	50	67	84	97	102	100	98	88	74	59	45	40	
All-Sky Solar Radiation	RadAvg	0.40	1.02	2.04	3.42	4.52	4.39	4.17	3.31	2.29	1.22	0.53	0.30	
	RadStd	0.06	0.14	0.18	0.27	0.40	0.48	0.43	0.28	0.18	0.16	0.05	0.04	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page